

**CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION**

RECOMMISSIONNING OF THERMAL/NUCLEAR UNITS AS ON: 11-09-2025

Sub-Report - 14

Station	Unit No	Capacity (MW)	Date of Maintanance	Sync Date	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
PANIPAT TPS	6	210.00	28/08/2025 12:40	11/09/2025 20:00	FURNACE FIRE OUT /FLAME FAILURE
ROPAR TPS	3	210.00	11/09/2025 08:31	11/09/2025 20:32	FURNACE FIRE OUT /FLAME FAILURE
ROPAR TPS	3		25/08/2025 11:05	11/09/2025 03:35	LOW SYSTEM DEMAND
ROPAR TPS	6	210.00	11/09/2025 08:10	11/09/2025 10:06	GENEARTOR MISC.
ROPAR TPS	6		31/08/2025 10:45	11/09/2025 05:23	TURBINE INSPECTION MISC
AURAIYA CCPP	2	111.19	10/09/2025 23:09	11/09/2025 15:17	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	2	130.19	10/09/2025 23:15	11/09/2025 14:37	CONSERVATION OF MAIN FUEL/RSD
JAWAHARPUR STPP	1	660.00	26/08/2025 06:49	11/09/2025 11:03	AIR PREHEATERS PROBLEM
JAWAHARPUR STPP	2	660.00	11/09/2025 07:45	11/09/2025 14:35	TURBINE MISC.
JAWAHARPUR STPP	2		10/09/2025 21:18	11/09/2025 05:05	H.P. AND L.P. bypass system
SVPL TPP	1	63.00	11/09/2025 16:19	11/09/2025 18:27	GENEARTOR MISC.
GANDHAR CCPP	3	144.30	10/09/2025 23:00	11/09/2025 14:29	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	2	106.00	10/09/2025 23:09	11/09/2025 16:30	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	4	106.00	10/09/2025 23:10	11/09/2025 13:04	CONSERVATION OF MAIN FUEL/RSD
AKRIMOTA LIG TPS	2	125.00	05/09/2025 11:08	11/09/2025 16:57	DRUM LEVEL HIGH/ low
KUTCH LIG. TPS	3	75.00	11/09/2025 03:47	11/09/2025 08:55	FURNACE FIRE OUT /FLAME FAILURE
DHUVARAN CCPP	5	376.10	26/08/2025 23:34	11/09/2025 12:30	RESERVE SHUT DOWN/ STANDBY.
UNOSUGEN CCPP	1	382.50	13/08/2025 00:00	11/09/2025 13:15	RSD/LOW SCHEDULE
RATNAGIRI CCPP	5	213.00	11/09/2025 00:21	11/09/2025 13:51	GT- LOW SYSTEM DAMAND
RATNAGIRI CCPP	7	213.00	11/09/2025 01:04	11/09/2025 14:20	GT- LOW SYSTEM DAMAND
CHANDRAPUR(MAHARASHTRA) STPS	7	500.00	06/09/2025 05:14	11/09/2025 16:55	SWITCH YARD/TRIPPING OF TRANSMISSION LINES/BUS BAR PROBLEM
THAMMINAPATNAM TPS	3	350.00	11/09/2025 12:33	11/09/2025 17:19	BOILER MISC. PROBLEM
KUDGI STPP	3	800.00	15/08/2025 09:50	11/09/2025 04:40	RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	3	210.00	09/09/2025 15:24	11/09/2025 08:20	WATER WALL TUBE LEAKAGE
NEYVELI TPS-II	6	210.00	10/09/2025 16:24	11/09/2025 16:20	FUEL SUPPLY & OTHER MISC. PROBLEMS
NEYVELI TPS-II	6		11/09/2025 19:20	11/09/2025 22:20	DRUM LEVEL LOW
OPG Power Generation Private Limited	2	77.00	11/09/2025 03:00	11/09/2025 17:39	RSD/LOW SCHEDULE
OPG Power Generation Private Limited	4	180.00	07/09/2025 02:29	11/09/2025 15:38	WATER WALL TUBE LEAKAGE
IB VALLEY TPS	4	660.00	05/09/2025 08:17	11/09/2025 03:48	BOILER AUX. MISC. PROMLEMS
JSW Energy Utkal Limited	1	350.00	10/09/2025 22:51	11/09/2025 03:03	BOILER FEED PUMP/MOTOR PROBLEM
JSW Energy Utkal Limited	1		11/09/2025 14:57	11/09/2025 17:12	BOILER FEED PUMP/MOTOR PROBLEM
D.P.L. TPS	7	300.00	11/09/2025 16:40	11/09/2025 19:51	FURNACE DRAFT ABNORMAL

Station	Unit No	Capacity (MW)	Date of Maintanance	Sync Date	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
KATHALGURI CCPP	5	33.50	11/09/2025 00:00	11/09/2025 23:59	Fuel Shortage
KATHALGURI CCPP	7	30.00	11/09/2025 00:00	11/09/2025 23:59	MISCELLANEOUS PLANNED MAINTENANCE
LAKWA REPLACEMENT POWER PROJECT	6	9.96	11/09/2025 00:00	11/09/2025 18:45	GRID DISTURBANCE
AGARTALA GT	3	21.00	11/09/2025 00:00	11/09/2025 23:59	Fuel Shortage
Total		7,726.75			