

**DAILY MAINTENANCE REPORT (THERMAL AND NUCLEAR UNITS) FOR 500 AND ABOVE 11-12-2025**

| State/System  | Power Station                   | Unit No. | Planned Maintenance (MW) | Forced Maintenance (Major) (MW) | Forced Maintenance (Minor) (MW) | Others Maintenance (MW) | Date& Time of Maintenance<br>DD/MM/YYYY<br>HH24:MM | Expected/sync Date of Return<br>DD/MM/YYYY<br>HH24:MM | Reasons/Present Status                  |
|---------------|---------------------------------|----------|--------------------------|---------------------------------|---------------------------------|-------------------------|----------------------------------------------------|-------------------------------------------------------|-----------------------------------------|
| 1             | 2                               | 3        | 4                        | 5                               | 6                               | 7                       | 8                                                  | 9                                                     | 10                                      |
| Haryana       | INDIRA GANDHI STPP              | 2        | 500.00                   | 0.00                            | 0.00                            | 0.00                    | 31/10/2025 23:00                                   |                                                       | ANNUAL MAINTENANCE                      |
| Haryana       | RAJIV GANDHI TPS                | 2        | 0.00                     | 600.00                          | 0.00                            | 0.00                    | 03/11/2025 00:00                                   |                                                       | RSD/LOW SCHEDULE                        |
| Punjab        | TALWANDI SABO TPP               | 2        | 660.00                   | 0.00                            | 0.00                            | 0.00                    | 19/11/2025 22:30                                   |                                                       | BOILER OVERHAUL/ ANNUAL MAINTENANCE     |
| Rajasthan     | RAJASTHAN A.P.S.                | 7        | 0.00                     | 700.00                          | 0.00                            | 0.00                    | 04/10/2025 16:34                                   |                                                       | TURBINE VIBRATION HIGH                  |
| Uttar Pradesh | RIHAND STPS                     | 4        | 500.00                   | 0.00                            | 0.00                            | 0.00                    | 29/10/2025 23:54                                   |                                                       | OVERHAULING WORKS                       |
| Uttar Pradesh | ANPARA TPS                      | 7        | 500.00                   | 0.00                            | 0.00                            | 0.00                    | 31/10/2025 01:00                                   | 11/12/2025 17:30                                      | CAPITAL MAINTENANCE                     |
| Uttar Pradesh | JAWAHARPUR STPP                 | 2        | 0.00                     | 660.00                          | 0.00                            | 0.00                    | 07/10/2025 00:58                                   |                                                       | RESERVE SHUT DOWN / STANDBY UNIT        |
| Uttar Pradesh | OBRA TPS                        | 15       | 0.00                     | 0.00                            | 660.00                          | 0.00                    | 08/12/2025 13:28                                   |                                                       | TUBE LKG. AT LOW TEMP. SUPERHEATER ZONE |
| Uttar Pradesh | PANKI TPS EXT                   | 1        | 660.00                   | 0.00                            | 0.00                            | 0.00                    | 30/11/2025 22:42                                   |                                                       | BOILER OVERHAUL/ ANNUAL MAINTENANCE     |
| Uttar Pradesh | ANPARA C TPS                    | 1        | 600.00                   | 0.00                            | 0.00                            | 0.00                    | 09/11/2025 00:24                                   |                                                       | BOILER OVERHAUL/ ANNUAL MAINTENANCE     |
| Uttar Pradesh | LALITPUR TPS                    | 1        | 660.00                   | 0.00                            | 0.00                            | 0.00                    | 15/11/2025 01:16                                   |                                                       | BOILER OVERHAUL/ ANNUAL MAINTENANCE     |
| Uttar Pradesh | PRAYAGRAJ TPP                   | 3        | 660.00                   | 0.00                            | 0.00                            | 0.00                    | 16/11/2025 00:31                                   |                                                       | BOILER OVERHAUL/ ANNUAL MAINTENANCE     |
| Chhatisgarh   | SIPAT STPS                      | 2        | 660.00                   | 0.00                            | 0.00                            | 0.00                    | 14/11/2025 04:02                                   |                                                       | BOILER OVERHAUL/ ANNUAL MAINTENANCE     |
| Chhatisgarh   | MARWA TPS                       | 2        | 0.00                     | 0.00                            | 500.00                          | 0.00                    | 09/12/2025 19:02                                   | 11/12/2025 12:03                                      | WATER WALL TUBE LEAKAGE                 |
| Chhatisgarh   | ADANI POWER LIMITED RAIGARH TPP | 1        | 0.00                     | 0.00                            | 600.00                          | 0.00                    | 01/12/2025 04:05                                   |                                                       | AIR PREHEATERS PROBLEM                  |
| Chhatisgarh   | AKALTARA TPS                    | 2        | 0.00                     | 0.00                            | 0.00                            | 0.00                    | 11/10/2025 22:44                                   |                                                       |                                         |
| Chhatisgarh   | BARADARHA TPS                   | 2        | 600.00                   | 0.00                            | 0.00                            | 0.00                    | 05/11/2025 00:11                                   | 11/12/2025 15:33                                      | BOILER OVERHAUL/ ANNUAL MAINTENANCE     |

**DAILY MAINTENANCE REPORT (THERMAL AND NUCLEAR UNITS) FOR 500 AND ABOVE 11-12-2025**

| State/System   | Power Station                  | Unit No. | Planned Maintenance (MW) | Forced Maintenance (Major) (MW) | Forced Maintenance (Minor) (MW) | Others Maintenance (MW) | Date& Time of Maintenance<br>DD/MM/YYYY<br>HH24:MM | Expected/sync Date of Return<br>DD/MM/YYYY<br>HH24:MM | Reasons/Present Status                     |
|----------------|--------------------------------|----------|--------------------------|---------------------------------|---------------------------------|-------------------------|----------------------------------------------------|-------------------------------------------------------|--------------------------------------------|
| 1              | 2                              | 3        | 4                        | 5                               | 6                               | 7                       | 8                                                  | 9                                                     | 10                                         |
| Gujarat        | MUNDRA UMTTP                   | 1        | 0.00                     | 800.00                          | 0.00                            | 0.00                    | 03/07/2025 11:54                                   |                                                       | AIR PREHEATERS PROBLEM                     |
| Gujarat        | MUNDRA UMTTP                   | 2        | 0.00                     | 800.00                          | 0.00                            | 0.00                    | 02/07/2025 22:59                                   |                                                       | F.D. FANS PROBLEM                          |
| Gujarat        | MUNDRA UMTTP                   | 3        | 0.00                     | 800.00                          | 0.00                            | 0.00                    | 02/07/2025 00:22                                   |                                                       | TURBINE CONTROL VALVE PROBLEM              |
| Gujarat        | MUNDRA UMTTP                   | 4        | 0.00                     | 800.00                          | 0.00                            | 0.00                    | 01/07/2025 08:55                                   |                                                       | COOLING WATER SYSTEM PROBLEM/PIPES REPLACE |
| Gujarat        | MUNDRA UMTTP                   | 5        | 0.00                     | 800.00                          | 0.00                            | 0.00                    | 02/07/2025 08:55                                   |                                                       | TURBINE MISC. PROBLEMS                     |
| Madhya Pradesh | VINDHYACHAL STPS               | 7        | 500.00                   | 0.00                            | 0.00                            | 0.00                    | 18/11/2025 00:31                                   |                                                       | OVERHAULING WORKS                          |
| Maharashtra    | TARAPUR                        | 3        | 540.00                   | 0.00                            | 0.00                            | 0.00                    | 04/11/2025 22:00                                   |                                                       | ANNUAL MAINTENANCE                         |
| Maharashtra    | BHUSAWAL TPS                   | 4        | 0.00                     | 500.00                          | 0.00                            | 0.00                    | 20/10/2025 21:01                                   |                                                       | RESERVE SHUT DOWN / STANDBY UNIT           |
| Maharashtra    | BHUSAWAL TPS                   | 5        | 0.00                     | 500.00                          | 0.00                            | 0.00                    | 01/10/2025 22:00                                   |                                                       | RSD/LOW SCHEDULE                           |
| Maharashtra    | ADANI POWER LIMITED TIRODA TPP | 3        | 660.00                   | 0.00                            | 0.00                            | 0.00                    | 01/12/2025 02:16                                   |                                                       | SCHEDULED ANNUAL MAINTENANCE               |
| Andhra Pradesh | SIMHADRI                       | 1        | 500.00                   | 0.00                            | 0.00                            | 0.00                    | 23/11/2025 00:00                                   |                                                       | BOILER OVERHAUL/ ANNUAL MAINTENANCE        |
| Andhra Pradesh | DAMODARAM SANJEEVAIAH TPS      | 3        | 0.00                     | 0.00                            | 0.00                            | 0.00                    | 11/12/2025 08:12                                   | 11/12/2025 13:53                                      | BOILER FEED PUMP/MOTOR PROBLEM             |
| Andhra Pradesh | PAINAMPURAM TPP                | 1        | 660.00                   | 0.00                            | 0.00                            | 0.00                    | 30/11/2025 23:22                                   |                                                       | SCHEDULED ANNUAL MAINTENANCE               |
| Karnataka      | BELLARY TPS                    | 2        | 0.00                     | 0.00                            | 500.00                          | 0.00                    | 10/12/2025 00:00                                   |                                                       | TUBE LKG. AT LOW TEMP. SUPERHEATER ZONE    |
| Karnataka      | YERMARUS TPP                   | 2        | 800.00                   | 0.00                            | 0.00                            | 0.00                    | 26/11/2025 00:16                                   |                                                       | SCHEDULED ANNUAL MAINTENANCE               |
| Karnataka      | ADANI POWER LIMITED UDUPI TPP  | 1        | 0.00                     | 0.00                            | 600.00                          | 0.00                    | 30/11/2025 23:55                                   |                                                       | RSD/LOW SCHEDULE                           |
| Tamil Nadu     | VALLUR TPP                     | 1        | 500.00                   | 0.00                            | 0.00                            | 0.00                    | 01/12/2025 01:26                                   |                                                       | SCHEDULED ANNUAL MAINTENANCE               |
| Tamil Nadu     | KUDANKULAM                     | 2        | 1,000.00                 | 0.00                            | 0.00                            | 0.00                    | 27/10/2025 06:06                                   |                                                       | ANNUAL MAINTENANCE                         |
| Tamil Nadu     | METTUR TPS-II                  | 1        | 600.00                   | 0.00                            | 0.00                            | 0.00                    | 01/12/2025 01:42                                   |                                                       | SCHEDULED ANNUAL MAINTENANCE               |

**DAILY MAINTENANCE REPORT (THERMAL AND NUCLEAR UNITS) FOR 500 AND ABOVE 11-12-2025**

| State/System | Power Station   | Unit No. | Planned Maintenance (MW) | Forced Maintenance (Major) (MW) | Forced Maintenance (Minor) (MW) | Others Maintenance (MW) | Date& Time of Maintenance<br>DD/MM/YYYY<br>HH24:MM | Expected/sync Date of Return<br>DD/MM/YYYY<br>HH24:MM | Reasons/Present Status              |
|--------------|-----------------|----------|--------------------------|---------------------------------|---------------------------------|-------------------------|----------------------------------------------------|-------------------------------------------------------|-------------------------------------|
| 1            | 2               | 3        | 4                        | 5                               | 6                               | 7                       | 8                                                  | 9                                                     | 10                                  |
| Tamil Nadu   | ITPCL TPP       | 1        | 0.00                     | 600.00                          | 0.00                            | 0.00                    | 01/11/2025 11:46                                   |                                                       | RSD/LOW SCHEDULE                    |
| Telangana    | RAMAGUNDEM STPS | 4        | 500.00                   | 0.00                            | 0.00                            | 0.00                    | 17/11/2025 00:11                                   |                                                       | BOILER OVERHAUL/ ANNUAL MAINTENANCE |
| Telangana    | SINGARENI TPP   | 1        | 0.00                     | 0.00                            | 600.00                          | 0.00                    | 10/12/2025 10:22                                   |                                                       | WATER WALL TUBE LEAKAGE             |
| Bihar        | BARH STPS       | 5        | 0.00                     | 0.00                            | 660.00                          | 0.00                    | 10/12/2025 17:46                                   | 11/12/2025 23:14                                      | C&I PROBLEM                         |
| Bihar        | NABINAGAR STPP  | 1        | 660.00                   | 0.00                            | 0.00                            | 0.00                    | 01/12/2025 02:07                                   |                                                       | BOILER OVERHAUL/ ANNUAL MAINTENANCE |
| Jharkhand    | MAITHON RB TPP  | 1        | 525.00                   | 0.00                            | 0.00                            | 0.00                    | 12/11/2025 00:05                                   |                                                       | SCHEDULED ANNUAL MAINTENANCE        |
| Odisha       | DERANG TPP      | 1        | 600.00                   | 0.00                            | 0.00                            | 0.00                    | 30/11/2025 23:54                                   |                                                       | BOILER OVERHAUL/ ANNUAL MAINTENANCE |
| Odisha       | DERANG TPP      | 2        | 0.00                     | 0.00                            | 0.00                            | 0.00                    | 09/12/2025 13:31                                   | 11/12/2025 02:09                                      | I.D. FANS PROBLEM                   |
| West Bengal  | FARAKKA STPS    | 4        | 500.00                   | 0.00                            | 0.00                            | 0.00                    | 31/10/2025 03:28                                   |                                                       | BOILER OVERHAUL/ ANNUAL MAINTENANCE |
| <b>Total</b> |                 |          | <b>14,545.00</b>         | <b>7,560.00</b>                 | <b>4,120.00</b>                 | <b>0.00</b>             |                                                    |                                                       |                                     |

**Remarks:-**

**Report Version :-**