

CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION

THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 11-Dec-2025

Sub - Report 15

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
SVPL TPP	1	63.00	12/11/25, 8:45 PM		I.D. FANS PROBLEM
GANDHAR CCPP	2		12/11/25, 6:40 PM	2025-12-11	CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	2	144.30	12/11/25, 8:00 AM	2025-12-11 15:58:00	CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	3		12/11/25, 6:39 PM	2025-12-11	CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	3	144.30	12/11/25, 7:56 AM	2025-12-11 15:41:00	CONSERVATION OF MAIN FUEL/RSD
PARLI TPS	6	250.00	12/11/25, 6:44 AM	2025-12-11 10:18:00	C&I PROBLEM
RAICHUR TPS	6	210.00	12/11/25, 8:49 AM	2025-12-11 11:34:00	INSTRUMENT AIR SYSTEM FAILURE
RAICHUR TPS	8	250.00	12/11/25, 4:55 AM	2025-12-11 17:57:00	GENERATOR PROTECTION RELAY OPERATION PROBLEM
TUTICORIN TPS	5		12/11/25, 6:44 PM	2025-12-11 19:31:00	FURNACE FIRE OUT /FLAME FAILURE
TUTICORIN TPS	5	210.00	12/11/25, 6:05 PM	2025-12-11 18:33:00	MISC. SHORT DURATION MAINTENANCE
DAMODARAM SANJEEVAIAH TPS	3	800.00	12/11/25, 8:12 AM	2025-12-11 13:53:00	BOILER FEED PUMP/MOTOR PROBLEM
KOLAGHAT TPS	3	210.00	12/11/25, 9:20 PM		BOILER OVERHAUL/ ANNUAL MAINTENANCE
LAKWA REPLACEMENT POWER PROJECT	1	9.96	12/11/25, 7:30 PM		GRID DISTURBENCE
LAKWA REPLACEMENT POWER PROJECT	7		12/11/25, 5:37 PM	2025-12-11 17:51:00	GRID DISTURBENCE
LAKWA REPLACEMENT POWER PROJECT	7		12/11/25, 9:07 AM	2025-12-11 16:49:00	GRID DISTURBENCE
LAKWA REPLACEMENT POWER PROJECT	7	9.96	12/11/25, 7:03 AM	2025-12-11 07:50:00	MISC. SHORT DURATION MAINTENANCE
KATHALGURI CCPP	7	30.00	12/11/25, 12:00 AM	2025-12-11 23:59:59	MISC. SHORT DURATION MAINTENANCE
Total		2331.53			

Remarks:-

Report Version :-