

**CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION**

RECOMMISSIONING OF THERMAL/NUCLEAR UNITS AS ON: 12-09-2020

Sub-Report - 14

Station	Unit No	Capacity (MW)	Date of Maintanance	Sync Date	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
KOTA TPS	5	210.00	03/08/2020 11:16	12/09/2020 12:06	Low system demand/ costly fuel
JALIPA KAPURDI TPP	8	135.00	12/09/2020 12:02	12/09/2020 19:38	BOILER MISC. PROBLEM
OBRA TPS	12	200.00	12/09/2020 11:07	12/09/2020 22:56	ELECTRICAL MISCELLANEOUS PROBLEMS
ANPARA C TPS	1	600.00	12/09/2020 04:10	12/09/2020 15:49	ELECTRICAL MISCELLANEOUS PROBLEMS
KORBA-III	1	120.00	10/09/2020 22:25	12/09/2020 04:23	FURNACE DRAFT ABNORMAL
KAHALGAON TPS	6	500.00	12/09/2020 16:43	12/09/2020 19:19	P.A. FANS PROBLEM
MAHADEV PRASAD STPP	1	270.00	05/09/2020 00:00	12/09/2020 04:05	TUBE LKG. AT LOW TEMP. SUPERHEATER ZONE
IB VALLEY TPS	4	660.00	07/09/2020 17:54	12/09/2020 10:57	BOILER MISC. PROBLEM
MEJIA TPS	1	210.00	08/09/2020 07:30	12/09/2020 16:55	Low system demand/ costly fuel
SAGARDIGHI TPS	4	500.00	12/09/2020 09:20	12/09/2020 12:19	FURNACE DRAFT ABNORMAL
LAKWA REPLACEMENT POWER PROJECT	2	9.96	12/09/2020 15:15	12/09/2020 19:27	Fuel Shortage
LAKWA REPLACEMENT POWER PROJECT	6	9.96	12/09/2020 16:07	12/09/2020 17:39	Fuel Shortage
Total		3,424.93			