

**CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION**

THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 12-09-2020

Sub-Report - 15

Station	Unit No	Capacity (MW)	Date of Maintanance	Expected/Sync Date of return	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
JALIPA KAPURDI TPP	8	135.00	12/09/2020 12:02		BOILER MISC. PROBLEM
OBRA TPS	12	200.00	12/09/2020 11:07		ELECTRICAL MISCELLANEOUS PROBLEMS
ANPARA C TPS	1	600.00	12/09/2020 04:10	12/09/2020	ELECTRICAL MISCELLANEOUS PROBLEMS
NAWAPARA TPP	1	300.00	12/09/2020 15:22		WET/ POOR QUALITY COAL
GANDHI NAGAR TPS	4	210.00	12/09/2020 12:40		RSD/LOW SCHEDULE
UKAI TPS	3	200.00	12/09/2020 16:53		RSD/LOW SCHEDULE
UKAI TPS	5	210.00	12/09/2020 16:48		RSD/LOW SCHEDULE
PARLI TPS	6	250.00	12/09/2020 00:00		RSD/LOW SCHEDULE
TIRORA TPS	5	660.00	12/09/2020 20:54		TURBINE MISC. PROBLEM
SIMHADRI	1	500.00	12/09/2020 19:34	15/09/2020	CONSERVATION OF MAIN FUEL/RSD
UDUPI TPP	1	600.00	12/09/2020 11:59		RSD/LOW SCHEDULE
NORTH CHENNAI TPS	1	210.00	12/09/2020 08:38		RSD/LOW SCHEDULE
NORTH CHENNAI TPS	4	600.00	12/09/2020 19:53		Low system demand/ costly fuel
TUTICORIN TPS	4	210.00	12/09/2020 07:52	14/09/2020	BOILER AUX. MISC. PROMLEMS
KAHALGAON TPS	6	500.00	12/09/2020 16:43	12/09/2020	P.A. FANS PROBLEM
DURGAPUR STEEL TPS	1	500.00	12/09/2020 03:04		WATER WALL TUBE LEAKAGE
BAKRESWAR TPS	4	210.00	12/09/2020 10:48		WATER WALL TUBE LEAKAGE
SAGARDIGHI TPS	4	500.00	12/09/2020 09:20		FURNACE DRAFT ABNORMAL
LAKWA GT	6	20.00	12/09/2020 00:00	15/09/2020	C&I PROBLEM
LAKWA REPLACEMENT POWER PROJECT	1	9.96	12/09/2020 01:04		Fuel Shortage
LAKWA REPLACEMENT POWER PROJECT	2	9.96	12/09/2020 15:15		Fuel Shortage
LAKWA REPLACEMENT POWER PROJECT	6	9.96	12/09/2020 16:07		Fuel Shortage
NAMRUP CAPP	3	21.00	12/09/2020 16:01		Fuel Shortage
Total		6665.90			