CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION

RECOMMISSIONNING OF THERMAL/NUCLEAR UNITS AS: 12-Nov-2026 **Sub - Report 14**

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
ROPAR TPS	5	210.0	11/7/26, 7:30PM	11/12/26, 9:50AM	RSD/LOW SCHEDULE
SURATGARH TPS	3	250.0	11/10/26, 11:54PM	11/12/26, 12:34PM	RSD/LOW SCHEDULE
JALIPA KAPURDI TPP	6	135.0	11/10/26, 1:31AM	11/12/26, 11:25AM	BOILER MISC. PROBLEM
HARDUAGANJ TPS	9	250.0	11/12/26, 11:55AM	11/12/26, 2:23PM	FURNACE FIRE OUT /FLAME FAILURE
ADANI POWER LIMITED RAIPUR TPP	2	685.0	11/11/26, 3:27PM	11/12/26, 2:56AM	P.A. FANS PROBLEM
GANDHI NAGAR TPS	5	210.0	11/9/26, 11:00AM	11/12/26, 1:26AM	RSD/LOW SCHEDULE
WANAKBORI TPS	2	210.0	11/8/26, 10:00PM	11/12/26, 3:55PM	RESERVE SHUT DOWN / STANDBY UNIT
WANAKBORI TPS	6	210.0	11/9/26, 8:20AM	11/12/26, 2:44PM	RSD/LOW SCHEDULE
WANAKBORI TPS	7	210.0	11/9/26, 11:00AM	11/12/26, 1:17PM	RSD/LOW SCHEDULE
MAUDA TPS	3	660.0	11/11/26, 4:00AM	11/12/26, 10:27AM	RSD/LOW SCHEDULE
NORTH CHENNAI TPS STAGE 3	6	800.0	11/2/26, 1:44AM	11/12/26, 11:48PM	TRANSMISSION CONSTRAINTS
TUTICORIN (P) TPP	2	150.0	11/9/26, 10:09AM	11/12/26, 11:47PM	TURBINE MISC. PROBLEM
NEYVELI TPS-II	3	210.0	11/10/26, 10:30AM	11/12/26, 5:47PM	RSD/LOW SCHEDULE
NEYVELI TPS-II EXP	2	250.0	11/6/26, 12:43AM	11/12/26, 6:02AM	TURBINE MISC. PROBLEM
VALLUR TPP	3	500.0	11/6/26, 11:58AM	11/12/26, 11:18AM	RESERVE SHUT DOWN / STANDBY UNIT
Nagai TPP	1	150.0	11/12/26, 12:32AM	11/12/26, 6:49AM	TURBINE MISC. PROBLEM
SINGARENI TPP	1	600.0	11/10/26, 9:32AM	11/12/26, 9:55AM	WATER WALL TUBE LEAKAGE
SIMHAPURI TPS	2	150.0	11/12/26, 4:47AM	11/12/26, 9:06AM	AIR SUPPLY FAILURE
NABINAGAR STPP	1	660.0	11/12/26, 11:56AM	11/12/26, 10:20PM	ELECTRICAL MISCELLANEOUS PROBLEMS
TENUGHAT TPS	2	210.0	11/12/26, 3:35PM	11/12/26, 5:56PM	MILLING SYSTEM /RC FEEDER PROBLEM
PATRATU STPP	2	800.0	11/11/26, 9:05PM	11/12/26, 2:21AM	MAL-FUNCTION OF RELAY
AGARTALA GT	5	25.5	11/3/26, 12:00AM	11/12/26, 4:29PM	Fuel Shortage
LAKWA GT	6	20.0	11/12/26, 12:00AM	11/12/26, 2:54PM	GT-COMPRESSOR SYSTEM
LAKWA REPLACEMENT POWER PROJECT	6	9.965	11/12/26, 8:00AM	11/12/26, 9:32AM	MISC. SHORT DURATION MAINTENANCE WORKS
LAKWA REPLACEMENT POWER PROJECT	6		11/12/26, 2:30PM	11/12/26, 7:00PM	MISC. SHORT DURATION MAINTENANCE WORKS

Total	7565.47			

Note: 1.Actual generation is gross generation from stations above 25 MW. It excludes generation from RES.
2.Data published in this report is for operational purpose only and not for commercial purpose.
3.Generation data/Outage data are compiled based on data submitted directly by the utilities.

Remarks:-

Report Version :-