CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION

THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 12-Nov-2026

Sub - Report 15

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
TALWANDI SABO TPP	2	660.00	11/12/26, 12:31AM		ABNORMAL BOILER OPERATIONAL PARAMETER
HARDUAGANJ TPS	9	250.00	11/12/26, 11:55AM	2026-11-12 14:23:00	FURNACE FIRE OUT /FLAME FAILURE
SASAN UMTPP	4	660.00	11/12/26, 7:08AM		SUPER HEATER TUBE LEAKAGE
SABARMATI (D-F STATIONS)	3	121.00	11/12/26, 12:00AM		BOILER OVERHAUL/ ANNUAL MAINTENANCE
RAICHUR TPS	3	210.00	11/12/26, 4:37AM		WATER WALL TUBE LEAKAGE
RAICHUR TPS	7	210.00	11/12/26, 9:49AM		WATER WALL TUBE LEAKAGE
Nagai TPP	1	150.00	11/12/26, 12:51PM		TURBINE MISC. PROBLEM
Nagai TPP	1		11/12/26, 12:32AM	2026-11-12 06:49:00	TURBINE MISC. PROBLEM
TELANGANA STPP PH-1	1	800.00	11/12/26, 12:10AM		SCHEDULED ANNUAL MAINTENANCE
SIMHAPURI TPS	2	150.00	11/12/26, 4:47AM	2026-11-12 09:06:00	AIR SUPPLY FAILURE
MEENAKSHI ENERGY LTD	3	350.00	11/12/26, 5:44PM		BOILER MISC. PROBLEM
NABINAGAR STPP	1	660.00	11/12/26, 11:56AM	2026-11-12 22:20:00	ELECTRICAL MISCELLANEOUS PROBLEMS
SAGARDIGHI TPS	2	300.00	11/12/26, 9:04PM		MISC. SHORT DURATION MAINTENANCE
TENUGHAT TPS	2	210.00	11/12/26, 3:35PM	2026-11-12 17:56:00	MILLING SYSTEM /RC FEEDER PROBLEM
MONARCHAK CCPP	1	65.40	11/12/26, 12:00AM		MISCELLANEOUS PLANNED MAINTENANCE
MONARCHAK CCPP	2	35.60	11/12/26, 12:00AM		MISCELLANEOUS PLANNED MAINTENANCE
LAKWA GT	6	20.00	11/12/26, 12:00AM	2026-11-12 14:54:00	GT-COMPRESSOR SYSTEM
LAKWA REPLACEMENT POWER PROJECT	6		11/12/26, 8:00AM	2026-11-12 09:32:00	MISC. SHORT DURATION MAINTENANCE WORKS
LAKWA REPLACEMENT POWER PROJECT	6	9.96	11/12/26, 2:30PM	2026-11-12 19:00:00	MISC. SHORT DURATION MAINTENANCE WORKS
Total		4861.97			

Note: 1.Actual generation is gross generation from stations above 25 MW. It excludes generation from RES.
2.Data published in this report is for operational purpose only and not for commercial purpose.
3.Generation data/Outage data are compiled based on data submitted directly by the utilities.

Remarks:-

Report Version :-