

DAILY MAINTENANCE REPORT (THERMAL AND NUCLEAR UNITS) FOR 500 AND ABOVE 13-06-2026

State/System	Power Station	Unit No.	Planned Maintenance (MW)	Forced Maintenance (Major) (MW)	Forced Maintenance (Minor) (MW)	Others Maintenance (MW)	Date & Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6	7	8	9	10
Rajasthan	KALISINDH TPS	2	0.00	0.00	600.00	0.00	11/06/2026 00:29	13/06/2026 19:35	TUBE LKG. AT LOW TEMP. SUPERHEATER ZONE
Uttar Pradesh	KHURJA TPP	1	0.00	0.00	660.00	0.00	06/06/2026 01:42		ABNORMAL BOILER OPERATIONAL PARAMETER
Uttar Pradesh	RIHAND STPS	3	0.00	0.00	0.00	0.00	13/06/2026 03:24	13/06/2026 09:54	UAT MISC.
Uttar Pradesh	JAWAHARPUR STPP	1	0.00	0.00	660.00	0.00	11/06/2026 13:25		RSD/LOW SCHEDULE
Uttar Pradesh	JAWAHARPUR STPP	2	0.00	0.00	660.00	0.00	11/06/2026 13:12		RSD/LOW SCHEDULE
Uttar Pradesh	PANKI TPS EXT	1	0.00	0.00	0.00	0.00	13/06/2026 06:39	13/06/2026 14:05	ELECTRICAL FAULT
Chhatisgarh	KORBA STPS	5	500.00	0.00	0.00	0.00	15/05/2026 12:07		OVERHAULING WORKS
Chhatisgarh	MARWA TPS	1	0.00	0.00	0.00	0.00	13/06/2026 11:11	13/06/2026 17:16	ELECTRICAL FAULT
Chhatisgarh	Vedanta Ltd Chhattisgarh TPP	1	0.00	600.00	0.00	0.00	14/04/2026 14:33		P.A. FANS PROBLEM
Gujarat	SALAYA TPP	2	0.00	0.00	0.00	0.00	09/06/2026 13:15	13/06/2026 04:04	WATER SHORTAGE DUE TO DROUGHT
Madhya Pradesh	SHREE SINGAJI TPP	1	0.00	0.00	0.00	0.00	13/06/2026 13:37	13/06/2026 15:52	WATER WALL TUBE LEAKAGE
Maharashtra	CHANDRAPUR (MAHARASHTRA) STPS	8	0.00	0.00	500.00	0.00	11/06/2026 12:14	13/06/2026 20:51	WATER WALL TUBE LEAKAGE
Andhra Pradesh	DAMODARAM SANJEEVAIAH TPS	3	0.00	0.00	800.00	0.00	13/06/2026 07:00		TURBINE MISC. PROBLEM
Andhra Pradesh	Dr. N.TATA RAO TPS	8	0.00	0.00	800.00	0.00	12/06/2026 23:43		WATER WALL TUBE LEAKAGE
Tamil Nadu	VALLUR TPP	2	500.00	0.00	0.00	0.00	11/06/2026 23:55		SCHEDULED ANNUAL MAINTENANCE
Tamil Nadu	NORTH CHENNAI TPS STAGE 2	4	0.00	0.00	600.00	0.00	12/06/2026 22:29		WATER WALL TUBE LEAKAGE
Tamil Nadu	TUTICORIN TPP ST- IV	1	0.00	525.00	0.00	0.00	28/05/2026 15:40	13/06/2026 23:47	GRID DISTURBANCE
Telangana	YADADRI TPS	1	0.00	0.00	800.00	0.00	13/06/2026 06:56	13/06/2026 21:01	GEN. COOLING SYSTEM FAILURE
Telangana	YADADRI TPS	3	0.00	0.00	800.00	0.00	07/06/2026 01:00		TURBINE MISC.

DAILY MAINTENANCE REPORT (THERMAL AND NUCLEAR UNITS) FOR 500 AND ABOVE 13-06-2026

State/System	Power Station	Unit No.	Planned Maintenance (MW)	Forced Maintenance (Major) (MW)	Forced Maintenance (Minor) (MW)	Others Maintenance (MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6	7	8	9	10
Bihar	BARH STPS	2	0.00	0.00	660.00	0.00	11/06/2026 09:03		TUBE LKG. AT LOW TEMP. SUPERHEATER ZONE
Bihar	BARH STPS	4	0.00	0.00	660.00	0.00	11/06/2026 00:51	13/06/2026 15:00	WATER WALL TUBE LEAKAGE
Jharkhand	NORTH KARANPURA TPP	1	0.00	0.00	660.00	0.00	13/06/2026 18:02		WATER WALL TUBE LEAKAGE
Jharkhand	PATRATU STPP	2	800.00	0.00	0.00	0.00	13/05/2026 12:23		MISCELLANEOUS PLANNED MAINTENANCE
Odisha	TALCHER STPS	6	500.00	0.00	0.00	0.00	10/06/2026 02:12		OVERHAULING WORKS
West Bengal	FARAKKA STPS	4	0.00	0.00	500.00	0.00	11/06/2026 11:17		WATER WALL TUBE LEAKAGE
West Bengal	RAGHUNATHPUR TPP	2	0.00	600.00	0.00	0.00	14/04/2026 17:51		TURBINE VIBRATIONS HIGH
Total			2,300.00	1,725.00	9,360.00	0.00			

Note: 1.Actual generation is gross generation from stations above 25 MW. It excludes generation from RES.
 2.Data published in this report is for operational purpose only and not for commercial purpose.
 3.Generation data/Outage data are compiled based on data submitted directly by the utilities."

Remarks:-

Report Version

:-