

**CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION**

RECOMMISSIONING OF THERMAL/NUCLEAR UNITS AS: 13-Jun-2026

Sub - Report 14

Station	Unit No.	Capacity(MW)	Date of Maintanance DD/MM/YYYY HH24:MM	Sync Date DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
GOINDWAL SAHIB TPP	1	270.0	6/11/26, 7:37 PM	6/13/26, 3:41 AM	ELECTRICAL MISCELLANEOUS PROBLEMS
KALISINDH TPS	2	600.0	6/11/26, 12:29 AM	6/13/26, 7:35 PM	TUBE LKG. AT LOW TEMP. SUPERHEATER ZONE
SHREE CEMENT LTD TPS	3	19.0	6/13/26, 7:02 AM	6/13/26, 6:32 PM	RSD/LOW SCHEDULE
SHREE CEMENT LTD TPS	4	19.0	6/13/26, 7:02 AM	6/13/26, 6:29 PM	RSD/LOW SCHEDULE
SHREE CEMENT LTD TPS	5	6.0	6/13/26, 6:57 AM	6/13/26, 6:35 PM	RSD/LOW SCHEDULE
PANKI TPS EXT	1	660.0	6/13/26, 6:39 AM	6/13/26, 2:05 PM	ELECTRICAL FAULT
RIHAND STPS	3	500.0	6/13/26, 3:24 AM	6/13/26, 9:54 AM	UAT MISC.
MARWA TPS	1	500.0	6/13/26, 11:11 AM	6/13/26, 5:16 PM	ELECTRICAL FAULT
SHREE SINGAJI TPP	1	600.0	6/13/26, 1:37 PM	6/13/26, 3:52 PM	WATER WALL TUBE LEAKAGE
UKAI TPS	4	200.0	6/13/26, 10:11 AM	6/13/26, 11:46 AM	FURNACE FIRE OUT /FLAME FAILURE
SALAYA TPP	2	600.0	6/9/26, 1:15 PM	6/13/26, 4:04 AM	WATER SHORTAGE DUE TO DROUGHT
CHANDRAPUR(MAHARASHTRA) STPS	8	500.0	6/11/26, 12:14 PM	6/13/26, 8:51 PM	WATER WALL TUBE LEAKAGE
WARDHA WARORA TPP	4	135.0	6/13/26, 6:42 PM	6/13/26, 8:30 PM	WATER WALL TUBE LEAKAGE
SHIRPUR TPP	1	150.0	6/12/26, 2:45 AM	6/13/26, 6:34 AM	ASH HANDLING SYSTEM PROBLEM
TUTICORIN TPP ST-IV	1	525.0	5/28/26, 3:40 PM	6/13/26, 11:47 PM	GRID DISTURBANCE
YADADRI TPS	1	800.0	6/13/26, 6:56 AM	6/13/26, 9:01 PM	GEN. COOLING SYSTEM FAILURE
BARH STPS	4	660.0	6/11/26, 12:51 AM	6/13/26, 3:00 PM	WATER WALL TUBE LEAKAGE
NORTH KARANPURA TPP	1	660.0	6/12/26, 4:27 PM	6/13/26, 4:46 AM	TURBINE VIBRATIONS HIGH
AGARTALA GT	1	21.0	6/13/26, 12:00 AM	6/13/26, 11:59 PM	Fuel Shortage
KATHALGURI CCPP	1	33.5	6/13/26, 12:00 AM	6/13/26, 11:59 PM	Fuel Shortage
Total		7458.50			

Note: 1.Actual generation is gross generation from stations above 25 MW. It excludes generation from RES.
2.Data published in this report is for operational purpose only and not for commercial purpose.
3.Generation data/Outage data are compiled based on data submitted directly by the utilities."

Remarks:-

Report Version :-