

**CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION**

THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 13-Jun-2026

Sub - Report 15

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
SURATGARH TPS	3	250.00	6/13/26, 7:22 AM		RSD/LOW SCHEDULE
SURATGARH TPS	6	250.00	6/13/26, 7:18 AM		RSD/LOW SCHEDULE
SHREE CEMENT LTD TPS	3	19.00	6/13/26, 7:02 AM	2026-06-13 18:32:00	RSD/LOW SCHEDULE
SHREE CEMENT LTD TPS	4	19.00	6/13/26, 7:02 AM	2026-06-13 18:29:00	RSD/LOW SCHEDULE
SHREE CEMENT LTD TPS	5	6.00	6/13/26, 6:57 AM	2026-06-13 18:35:00	RSD/LOW SCHEDULE
PANKI TPS EXT	1	660.00	6/13/26, 6:39 AM	2026-06-13 14:05:00	ELECTRICAL FAULT
RIHAND STPS	3	500.00	6/13/26, 3:24 AM	2026-06-13 09:54:00	UAT MISC.
MARWA TPS	1	500.00	6/13/26, 11:11 AM	2026-06-13 17:16:00	ELECTRICAL FAULT
SHREE SINGAJI TPP	1	600.00	6/13/26, 1:37 PM	2026-06-13 15:52:00	WATER WALL TUBE LEAKAGE
UKAI TPS	4	200.00	6/13/26, 10:11 AM	2026-06-13 11:46:00	FURNACE FIRE OUT /FLAME FAILURE
AKRIMOTA LIG TPS	1	125.00	6/13/26, 12:18 AM		MISCELLANEOUS
KHAPARKHEDA TPS	4	210.00	6/13/26, 9:28 AM		BOILER OVERHAUL/ ANNUAL MAINTENANCE
PARAS TPS	3	250.00	6/13/26, 4:38 PM		WATER WALL TUBE LEAKAGE
WARDHA WARORA TPP	4	135.00	6/13/26, 6:42 PM	2026-06-13 20:30:00	WATER WALL TUBE LEAKAGE
RAICHUR TPS	6	210.00	6/13/26, 10:53 AM	2026-06-14	WATER WALL TUBE LEAKAGE
NEYVELI (EXT) TPS	1	210.00	6/13/26, 11:01 PM		WATER WALL TUBE LEAKAGE
NEYVELI TPS-II EXP	2	250.00	6/13/26, 10:16 AM		WATER WALL TUBE LEAKAGE
YADADRI TPS	1	800.00	6/13/26, 6:56 AM	2026-06-13 21:01:12	GEN. COOLING SYSTEM FAILURE
Dr. N.TATA RAO TPS	2	210.00	6/13/26, 5:36 AM		WATER WALL TUBE LEAKAGE
DAMODARAM SANJEEVAIAH TPS	3	800.00	6/13/26, 7:00 AM		TURBINE MISC. PROBLEM
MEENAKSHI ENERGY LTD	1	150.00	6/13/26, 11:55 AM		MAIN STEAM LINE PROBLEM
MEENAKSHI ENERGY LTD	4	350.00	6/13/26, 5:59 PM		BOILER FEED PUMP/MOTOR PROBLEM
SOUTHERN REPL. TPS	2	67.50	6/13/26, 12:12 PM	2026-06-14	WATER WALL TUBE LEAKAGE
NORTH KARANPURA TPP	1	660.00	6/13/26, 6:02 PM		WATER WALL TUBE LEAKAGE
IB VALLEY TPS	2	210.00	6/13/26, 11:33 PM	2026-06-14	FURNACE FIRE OUT /FLAME FAILURE
AGARTALA GT	1	21.00	6/13/26, 12:00 AM	2026-06-13 23:59:59	Fuel Shortage
LAKWA REPLACEMENT POWER PROJECT	2	9.96	6/13/26, 8:28 AM		GRID DISTURBENCE
KATHALGURI CCPP	1	33.50	6/13/26, 12:00 AM	2026-06-13 23:59:59	Fuel Shortage

Total	7705.97			
--------------	---------	--	--	--

Note: 1.Actual generation is gross generation from stations above 25 MW. It excludes generation from RES.
2.Data published in this report is for operational purpose only and not for commercial purpose.
3.Generation data/Outage data are compiled based on data submitted directly by the utilities."

Remarks:-

Report Version :-