

CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION

RECOMMISSIONNING OF THERMAL/NUCLEAR UNITS AS: 13-Aug-2026

Sub - Report 14

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
TALWANDI SABO TPP	1	660.0	8/10/26, 10:42AM		ABNORMAL BOILER OPERATIONAL PARAMETER
PANIPAT TPS	6	210.0	8/13/26, 2:29PM		BOILER MISC. PROBLEM
KOTA TPS	3	210.0	8/9/26, 2:59PM		I.D. FANS PROBLEM
KOTA TPS	4	210.0	8/12/26, 6:49PM		STATION TRANSFORMER PROBLEM
KOTA TPS	5	210.0	8/12/26, 6:32PM		STATION TRANSFORMER PROBLEM
SURATGARH TPS	5	250.0	8/1/26, 12:04AM		GENERATOR TRANSFORMER
SURATGARH TPS	6	250.0	8/9/26, 10:38AM		RSD/LOW SCHEDULE
JALIPA KAPURDI TPP	8	135.0	8/9/26, 12:22PM		BOILER MISC. PROBLEM
BARSINGSAR LIGNITE	1	125.0	8/7/26, 2:58AM		BOILER MISC. PROBLEM
SHREE CEMENT LTD TPS	3	19.0	8/13/26, 5:00AM		RSD/LOW SCHEDULE
SHREE CEMENT LTD TPS	4	19.0	8/13/26, 5:00AM		RSD/LOW SCHEDULE
SHREE CEMENT LTD TPS	5	6.0	8/13/26, 4:52AM		RSD/LOW SCHEDULE
LALITPUR TPS	3	660.0	8/12/26, 10:51PM		TURBINE MISC. PROBLEM
KORBA STPS	5	500.0	8/12/26, 8:31PM		FURNACE FIRE OUT /FLAME FAILURE
ADANI POWER LIMITED RAIPUR TPP	2	685.0	8/13/26, 3:52AM		FURNACE FIRE OUT /FLAME FAILURE
MAHAN TPP	1	600.0	8/12/26, 4:47PM		TRIPPING OF TRANSMISSION LINE
VINDHYACHAL STPS	12	500.0	8/12/26, 12:51PM		DRUM LEVEL HIGH/ low
SUGEN CCPP	1	382.5	8/9/26, 12:00AM		RSD/LOW SCHEDULE
SURAT LIG. TPS	4	125.0	8/9/26, 5:34AM		WATER WALL TUBE LEAKAGE
SOLAPUR STPS	2	660.0	8/13/26, 2:43PM		C&I PROBLEM
WARDHA WARORA TPP	2	135.0	8/12/26, 1:20PM		CONDENSER LOW VACCUM
BASIN BRIDGE GT (Liq.)	4	30.0	8/13/26, 12:00AM		MISC. SHORT DURATION MAINTENANCE WORKS
TUTICORIN (P) TPP	2	150.0	8/5/26, 8:03AM		BOILER MISC. PROBLEM
NEYVELI TPS-II	7	210.0	8/3/26, 12:17PM		RESERVE SHUT DOWN / STANDBY UNIT
VALLUR TPP	3	500.0	8/10/26, 12:05AM		FURNACE FIRE OUT /FLAME FAILURE
RAYALASEEMA TPS	3	210.0	8/13/26, 3:43PM		TURBINE OIL SYSTEM PROBLEM
NABINAGAR TPP	4	250.0	8/12/26, 1:20AM		TURBINE MISC.
Maadurga Thermal Power Company Ltd.	2	30.0	8/13/26, 7:50AM		GEN. COOLING SYSTEM FAILURE
AGARTALA GT	2	21.0	8/13/26, 12:00AM		MINOR MAINTENANCE WORKS

RECOMMISSIONING OF THERMAL/NUCLEAR UNITS AS: 13-Aug-2026					Sub - Report 14
Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
AGARTALA GT	4	21.0	8/13/26, 12:00AM		Fuel Shortage
AGARTALA GT	5	25.5	8/13/26, 12:00AM		Fuel Shortage
MONARCHAK CCPP	1	65.4	8/13/26, 12:00AM		Fuel Shortage
MONARCHAK CCPP	2	35.6	8/13/26, 12:00AM		Fuel Shortage
LAKWA REPLACEMENT POWER PROJECT	4	9.965	8/13/26, 7:35PM		MINOR MAINTENANCE WORKS
KATHALGURI CCPP	8	30.0	8/13/26, 12:00AM		MISCELLANEOUS PLANNED MAINTENANCE
Total		8139.97			

Remarks:-

Report Version :-