

CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION

THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 13-Aug-2026

Sub - Report 15

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
PANIPAT TPS	6	210.00	8/13/26, 2:29PM	2026-08-13 19:27:00	BOILER MISC. PROBLEM
JALIPA KAPURDI TPP	3	135.00	8/13/26, 8:22PM		BOILER MISC. PROBLEM
SHREE CEMENT LTD TPS	3	19.00	8/13/26, 5:00AM	2026-08-13 18:28:00	RSD/LOW SCHEDULE
SHREE CEMENT LTD TPS	4	19.00	8/13/26, 5:00AM	2026-08-13 18:27:00	RSD/LOW SCHEDULE
SHREE CEMENT LTD TPS	5	6.00	8/13/26, 4:52AM	2026-08-13 18:30:00	RSD/LOW SCHEDULE
ADANI POWER LIMITED RAIPUR TPP	2	685.00	8/13/26, 3:52AM	2026-08-13 07:13:00	FURNACE FIRE OUT /FLAME FAILURE
SOLAPUR STPS	2	660.00	8/13/26, 2:43PM	2026-08-13 19:57:00	C&I PROBLEM
BASIN BRIDGE GT (Liq.)	4	30.00	8/13/26, 12:00AM	2026-08-13 14:36:00	MISC. SHORT DURATION MAINTENANCE WORKS
TUTICORIN (P) TPP	1	150.00	8/13/26, 10:39PM		P.A. FANS PROBLEM
Tulsyan NEC Limited	2	35.00	8/13/26, 5:15AM		ESP PROBLEM
OPG Power Generation Private Limited	3	80.00	8/13/26, 10:30PM		TURBINE BEARING PROBLEM
YADADRI TPS	4	800.00	8/13/26, 1:13AM		BOILER AUX. MISC. PROMLEMS
RAYALASEEMA TPS	3	210.00	8/13/26, 3:43PM	2026-08-13 20:08:00	TURBINE OIL SYSTEM PROBLEM
SAGARDIGHI TPS	2	300.00	8/13/26, 6:23PM		BOILER AUX. MISC. PROMLEMS
Maadurga Thermal Power Company Ltd.	1	30.00	8/13/26, 3:26AM	2026-08-14	GEN. COOLING SYSTEM FAILURE
Maadurga Thermal Power Company Ltd.	2	30.00	8/13/26, 7:50AM	2026-08-13 14:53:00	GEN. COOLING SYSTEM FAILURE
KAMALANGA TPS	2	350.00	8/13/26, 7:32PM		TURBINE PIPES AND VALVES PROBLEM
JSW Energy Utkal Limited	2	350.00	8/13/26, 1:19PM	2026-08-13	CONDENSER TUBE LEAKAGE/ CLEANING
AGARTALA GT	2	21.00	8/13/26, 12:00AM	2026-08-13 23:59:59	MINOR MAINTENANCE WORKS
AGARTALA GT	4	21.00	8/13/26, 12:00AM	2026-08-13 23:59:59	Fuel Shortage
AGARTALA GT	5	25.50	8/13/26, 12:00AM	2026-08-13 23:59:59	Fuel Shortage
MONARCHAK CCPP	1	65.40	8/13/26, 12:00AM	2026-08-13 23:59:59	Fuel Shortage
MONARCHAK CCPP	2	35.60	8/13/26, 12:00AM	2026-08-13 23:59:59	Fuel Shortage
LAKWA REPLACEMENT POWER PROJECT	3	9.96	8/13/26, 8:00AM		SCHEDULED ANNUAL MAINTENANCE
LAKWA REPLACEMENT POWER PROJECT	4	9.96	8/13/26, 7:35PM	2026-08-13 22:05:48	MINOR MAINTENANCE WORKS
KATHALGURI CCPP	8	30.00	8/13/26, 12:00AM	2026-08-13 23:59:59	MISCELLANEOUS PLANNED MAINTENANCE

Total	4317.43			
-------	---------	--	--	--

Remarks:-

Report Version :-