

**CENTRAL ELECTRICITY AUTHORITY  
G O & D WING  
OPERATION PERFORMANCE MONITORING DIVISION**

**THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 13-09-2019**

Sub-Report - 15

| Station                         | Unit No | Capacity (MW) | Date of Maintanance | Expected/Sync Date of return | remarks                                      |
|---------------------------------|---------|---------------|---------------------|------------------------------|--|
|                                 |         |               | DD/MM/YYYY HH:24MM  | DD/MM/YYYY HH:24MM           |  |
| 1                               | 2       | 3             | 4                   | 5                            | 6  |
| RAJIV GANDHI TPS                | 2       | 600.00        | 13/09/2019 07:53    |                              | BOILER FEED PUMP/MOTOR PROBLEM               |
| TALWANDI SABO TPP               | 3       | 660.00        | 13/09/2019 19:01    |                              | BOILER MISC. PROBLEM                         |
| KORBA-WEST TPS                  | 2       | 210.00        | 13/09/2019 20:28    |                              | WATER WALL TUBE LEAKAGE                      |
| KUTCH LIG. TPS                  | 3       | 75.00         | 13/09/2019 06:03    |                              | TURBINE MISC. PROBLEM                        |
| KUTCH LIG. TPS                  | 4       | 75.00         | 13/09/2019 22:43    |                              | FURNACE DRAFT ABNORMAL                       |
| MUNDRA UMTTP                    | 4       | 800.00        | 13/09/2019 13:29    | 13/09/2019                   | H.P. AND L.P. bypass system                  |
| SASAN UMTTP                     | 3       | 660.00        | 13/09/2019 08:37    |                              | STATION TRANSFORMER PROBLEM                  |
| KHAPARKHEDA TPS                 | 1       | 210.00        | 13/09/2019 14:05    |                              | COAL SHORTAGE                                |
| KHAPARKHEDA TPS                 | 4       | 210.00        | 13/09/2019 00:59    |                              | FURNACE DRAFT ABNORMAL                       |
| NEYVELI TPS- I                  | 4       | 50.00         | 13/09/2019 00:16    |                              | ECONOMISER TUBE LEAKAGE                      |
| KOTHAGUDEM TPS                  | 4       | 60.00         | 13/09/2019 16:03    |                              | HYDROGEN PRESSURE PROBLEM                    |
| BARAUNI TPS                     | 7       | 105.00        | 13/09/2019 15:45    |                              | GENERATOR PROTECTION RELAY OPERATION PROBLEM |
| KAMALANGA TPS                   | 1       | 350.00        | 13/09/2019 01:14    |                              | COAL SHORTAGE                                |
| MEJIA TPS                       | 6       | 250.00        | 13/09/2019 00:31    |                              | WATER WALL TUBE LEAKAGE                      |
| BONGAIGAON TPP                  | 2       | 250.00        | 13/09/2019 10:32    |                              | RSD/LOW SCHEDULE                             |
| LAKWA REPLACEMENT POWER PROJECT | 3       | 9.96          | 13/09/2019 10:48    | 14/09/2019                   | MINOR MAINTENANCE WORKS                      |
| LAKWA REPLACEMENT POWER PROJECT | 3       |               | 13/09/2019 00:00    | 13/09/2019                   | FUEL SUPPLY & OTHER MISC. PROBLEMS           |
| LAKWA REPLACEMENT POWER PROJECT | 4       | 9.96          | 13/09/2019 00:00    |                              | FUEL SUPPLY & OTHER MISC. PROBLEMS           |
| LAKWA REPLACEMENT POWER PROJECT | 5       | 9.96          | 13/09/2019 07:11    |                              | FUEL SUPPLY & OTHER MISC. PROBLEMS           |
| LAKWA REPLACEMENT POWER PROJECT | 7       | 9.96          | 13/09/2019 08:33    |                              | FUEL SUPPLY & OTHER MISC. PROBLEMS           |
| LAKWA REPLACEMENT POWER PROJECT | 7       |               | 13/09/2019 20:25    |                              | FUEL SUPPLY & OTHER MISC. PROBLEMS           |
| NAMRUP CCPP                     | 3       | 21.00         | 13/09/2019 15:08    | 14/09/2019                   | Fuel Shortage                                |
| NAMRUP CCPP                     | 3       |               | 13/09/2019 00:00    | 13/09/2019                   | Fuel Shortage                                |
| NAMRUP CCPP                     | 6       | 22.00         | 13/09/2019 14:35    | 14/09/2019                   | Fuel Shortage                                |
| NAMRUP CCPP                     | 6       |               | 13/09/2019 00:00    | 13/09/2019                   | Fuel Shortage                                |
| Total                           |         | 4647.86       |                     |                              |  |