

CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION

DAILY MAINTENANCE REPORT (COAL, LIGNITE AND NUCLEAR) 13-10-2026

Sub-Report-10

State/System	Power Station	Unit No.	Planned Maintenance (MW)	Forced Maintenance (Major) (MW)	Forced Maintenance (Minor) (MW)	Others Maintenance (MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6	7	8	9	10
Northern									
Haryana	RAJIV GANDHI TPS	2	0.00	0.00	600.00	0.00	13/10/2026 15:30		TURBINE OIL SYSTEM PROBLEM
Punjab	ROPAR TPS	5	0.00	0.00	210.00	0.00	11/10/2026 10:50		RSD/LOW SCHEDULE
Punjab	ROPAR TPS	6	0.00	210.00	0.00	0.00	27/09/2026 11:32		FURNACE DRAFT ABNORMAL
Rajasthan	DAE (RAJASTHAN)	1	0.00	0.00	0.00	0.00	09/10/2004 22:58		GENERATOR EARTH FAULT
Rajasthan	KALISINDH TPS	1	0.00	600.00	0.00	0.00	27/08/2026 16:33		FURNACE DRAFT ABNORMAL
Rajasthan	JALIPA KAPURDI TPP	4	0.00	135.00	0.00	0.00	06/09/2026 01:43		BOILER MISC. PROBLEM
Rajasthan	JALIPA KAPURDI TPP	8	0.00	0.00	0.00	0.00	13/10/2026 23:57		C&I PROBLEM
Rajasthan	SHREE CEMENT LTD TPS	3	0.00	0.00	0.00	0.00	13/10/2026 08:00	13/10/2026 14:57	RSD/LOW SCHEDULE
Rajasthan	SHREE CEMENT LTD TPS	4	0.00	0.00	0.00	0.00	13/10/2026 08:00	13/10/2026 14:55	RSD/LOW SCHEDULE
Rajasthan	SHREE CEMENT LTD TPS	5	0.00	0.00	0.00	0.00	13/10/2026 07:55	13/10/2026 14:59	RSD/LOW SCHEDULE
Uttar Pradesh	GHATAMPUR TPP	3	0.00	660.00	0.00	0.00	26/09/2026 17:32		COAL FEEDING PROBLEM IN PLANT
Uttar Pradesh	SINGRAULI STPS	1	200.00	0.00	0.00	0.00	03/09/2026 23:59		OVERHAULING WORKS
Uttar Pradesh	UNCHA HAR TPS	5	0.00	0.00	210.00	0.00	10/10/2026 12:50		REHEATER TUBE LEAKAGE
Uttar Pradesh	ANPARA TPS	7	0.00	0.00	500.00	0.00	13/10/2026 08:45		ECONOMISER TUBE LEAKAGE
Uttar Pradesh	HARDUAGANJ TPS	8	0.00	0.00	0.00	0.00	14/01/2026 22:17		RESERVE SHUT DOWN / STANDBY UNIT
Uttar Pradesh	HARDUAGANJ TPS	9	0.00	0.00	250.00	0.00	13/10/2026 19:30		WATER WALL TUBE LEAKAGE
Uttar Pradesh	JAWAHARPUR STPP	1	0.00	0.00	660.00	0.00	09/10/2026 11:19		WATER WALL TUBE LEAKAGE

DAILY MAINTENANCE REPORT (COAL, LIGNITE AND NUCLEAR) 13-10-2026

Sub-Report-10

State/System	Power Station	Unit No.	Planned Maintenance (MW)	Forced Maintenance (Major) (MW)	Forced Maintenance (Minor) (MW)	Others Maintenance (MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6	7	8	9	10
Uttar Pradesh	OBRA TPS	9	0.00	0.00	200.00	0.00	08/10/2026 16:15	13/10/2026 13:29	FURNACE FIRE OUT /FLAME FAILURE
Uttar Pradesh	PRAYAGRAJ TPP	1	0.00	0.00	660.00	0.00	12/10/2026 03:52		SUPER HEATER TUBE LEAKAGE
Uttar Pradesh	UTRAULA TPS	1	0.00	0.00	0.00	0.00	13/10/2026 09:54	13/10/2026 15:43	GRID DISTURBANCE
Total Northern			200.00	1,605.00	3,290.00	0.00			
Western									
Chhatisgarh	DSPM TPS	1	250.00	0.00	0.00	0.00	10/10/2026 03:20		BOILER OVERHAUL/ ANNUAL MAINTENANCE
Chhatisgarh	ADANI POWER LIMITED RAIGARH TPP	1	0.00	0.00	600.00	0.00	11/10/2026 06:43		TURBINE CONTROL VALVE PROBLEM
Chhatisgarh	JSW Mahanadi Power Company Limited	3	0.00	0.00	600.00	0.00	12/10/2026 17:28		F.D. FANS PROBLEM
Chhatisgarh	KASAIPALLI TPP	1	0.00	135.00	0.00	0.00	11/09/2026 18:13		COAL SHORTAGE
Chhatisgarh	KATGHORA TPP	1	0.00	0.00	0.00	0.00	15/10/2012 00:28		No Fuel Supply Agreement
Chhatisgarh	PATHADI TPP	1	300.00	0.00	0.00	0.00	26/09/2026 00:00		BOILER OVERHAUL/ ANNUAL MAINTENANCE
Chhatisgarh	SALORA TPP	1	0.00	0.00	0.00	0.00	19/10/2014 04:30		No Fuel Supply Agreement
Chhatisgarh	SVPL TPP	1	0.00	0.00	63.00	0.00	10/10/2026 17:31		COOLING WATER PUMP PROBLEM
Chhatisgarh	UCHPINDA TPP	1	0.00	0.00	360.00	0.00	10/10/2026 17:32		CONDENSER TUBE LEAKAGE/ CLEANING
Chhatisgarh	Vedanta Ltd Chhattisgarh TPP	1	0.00	600.00	0.00	0.00	14/04/2026 14:33		P.A. FANS PROBLEM
Gujarat	AKRIMOTA LIG TPS	1	125.00	0.00	0.00	0.00	01/10/2026 00:10		BOILER OVERHAUL/ ANNUAL MAINTENANCE
Gujarat	AKRIMOTA LIG TPS	2	0.00	0.00	125.00	0.00	12/10/2026 10:45		FUEL SUPPLY & OTHER MISC. PROBLEMS

DAILY MAINTENANCE REPORT (COAL, LIGNITE AND NUCLEAR) 13-10-2026

Sub-Report-10

State/System	Power Station	Unit No.	Planned Maintenance (MW)	Forced Maintenance (Major) (MW)	Forced Maintenance (Minor) (MW)	Others Maintenance (MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6	7	8	9	10
Gujarat	BHAVNAGAR CFBC TPP	1	0.00	250.00	0.00	0.00	17/09/2026 01:32		AIR PREHEATERS PROBLEM
Gujarat	GANDHI NAGAR TPS	3	0.00	0.00	210.00	0.00	07/10/2026 23:47		TURBINE BEARING PROBLEM
Gujarat	KUTCH LIG. TPS	4	0.00	75.00	0.00	0.00	05/07/2023 07:05		COOLING TOWER PROBLEM
Gujarat	UKAI TPS	3	0.00	0.00	200.00	0.00	05/10/2026 22:05	13/10/2026 22:12	TURBO-VISORY SYSTEM PROBLEM
Gujarat	UKAI TPS	4	200.00	0.00	0.00	0.00	24/09/2026 00:00		BOILER OVERHAUL/ ANNUAL MAINTENANCE
Gujarat	UKAI TPS	5	0.00	0.00	210.00	0.00	13/10/2026 19:26		REHEATER TUBE LEAKAGE
Gujarat	WANAKBORI TPS	1	0.00	0.00	210.00	0.00	09/10/2026 14:25		FURNACE FIRE OUT /FLAME FAILURE
Gujarat	WANAKBORI TPS	5	0.00	0.00	210.00	0.00	29/09/2026 00:11		P.A. FANS PROBLEM
Gujarat	ADANI POWER LIMITED MUNDRA TPP - III	9	0.00	0.00	660.00	0.00	12/10/2026 01:05		MISCELLANEOUS
Madhya Pradesh	GADARWARA TPP	2	800.00	0.00	0.00	0.00	16/09/2026 00:00		BOILER OVERHAUL/ ANNUAL MAINTENANCE
Madhya Pradesh	KHARGONE STPP	2	0.00	0.00	0.00	0.00	09/10/2026 13:59	13/10/2026 10:05	AIR PREHEATERS PROBLEM
Madhya Pradesh	VINDHYACHAL STPS	4	0.00	0.00	210.00	0.00	12/10/2026 16:53		WATER WALL TUBE LEAKAGE
Madhya Pradesh	SANJAY GANDHI TPS	1	0.00	210.00	0.00	0.00	11/09/2026 02:59		BOILER AUX. MISC. PROMLEMS
Madhya Pradesh	SANJAY GANDHI TPS	2	0.00	0.00	210.00	0.00	07/10/2026 18:54	13/10/2026 02:59	WATER WALL TUBE LEAKAGE
Madhya Pradesh	SANJAY GANDHI TPS	3	0.00	0.00	210.00	0.00	11/10/2026 20:31		WATER WALL TUBE LEAKAGE
Madhya Pradesh	SHREE SINGAJI TPP	1	0.00	0.00	0.00	0.00	12/10/2026 22:17	13/10/2026 08:33	TURBINE VIBRATIONS HIGH
Madhya Pradesh	SHREE SINGAJI TPP	2	0.00	0.00	600.00	0.00	12/10/2026 17:52		WATER WALL TUBE LEAKAGE
Madhya Pradesh	ANUPPUR TPP	2	0.00	0.00	625.00	0.00	11/10/2026 09:56	13/10/2026 14:03	AIR PREHEATERS PROBLEM

DAILY MAINTENANCE REPORT (COAL, LIGNITE AND NUCLEAR) 13-10-2026

Sub-Report-10

State/System	Power Station	Unit No.	Planned Maintenance (MW)	Forced Maintenance (Major) (MW)	Forced Maintenance (Minor) (MW)	Others Maintenance (MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6	7	8	9	10
Madhya Pradesh	BINA TPS	1	0.00	0.00	250.00	0.00	13/10/2026 05:56		WATER WALL TUBE LEAKAGE
Madhya Pradesh	BINA TPS	2	250.00	0.00	0.00	0.00	30/09/2026 23:57		BOILER OVERHAUL/ ANNUAL MAINTENANCE
Madhya Pradesh	MAHAN TPP	1	0.00	0.00	600.00	0.00	10/10/2026 00:43		AIR PREHEATERS PROBLEM
Maharashtra	BHUSAWAL TPS	5	0.00	0.00	500.00	0.00	08/10/2026 12:28		FURNACE CLINKER FORMATION
Maharashtra	CHANDRAPUR (MAHARASHTRA) STPS	7	0.00	0.00	500.00	0.00	13/10/2026 19:09	13/10/2026 22:08	COOLING WATER PUMP PROBLEM
Maharashtra	KHAPARKHEDA TPS	3	0.00	0.00	210.00	0.00	11/10/2026 01:20		BOILER FEED PUMP/MOTOR PROBLEM
Maharashtra	KORADI TPS	10	660.00	0.00	0.00	0.00	21/08/2026 01:07		BOILER OVERHAUL/ ANNUAL MAINTENANCE
Maharashtra	AMRAVATI TPS	4	0.00	0.00	270.00	0.00	13/10/2026 15:00	13/10/2026 18:12	GEN. TRANSFORMER PROTECTION RELAY OPERATION PROBLEM
Maharashtra	BUTIBORI TPP	1	0.00	0.00	300.00	0.00	11/10/2026 03:15		AIR PREHEATERS PROBLEM
Maharashtra	GMR WARORA TPS	2	0.00	0.00	0.00	0.00	13/10/2026 12:34	13/10/2026 16:44	DC SUPPLY PROBLEM
Maharashtra	MIHAN TPS	1	0.00	61.51	0.00	0.00	10/01/2013 15:50		No Fuel Supply Agreement
Maharashtra	MIHAN TPS	2	0.00	61.50	0.00	0.00	05/11/2013 11:53		No Fuel Supply Agreement
Maharashtra	MIHAN TPS	3	0.00	61.50	0.00	0.00	10/06/2013 18:00		No Fuel Supply Agreement
Maharashtra	MIHAN TPS	4	0.00	61.50	0.00	0.00	20/08/2013 10:00		No Fuel Supply Agreement
Maharashtra	NASIK (P) TPS	1	0.00	0.00	0.00	0.00	04/03/2014 18:10		UNIT LIKELY TO BE SCRAPPED.
Maharashtra	NASIK (P) TPS	2	0.00	0.00	0.00	0.00	16/02/2017 00:46		UNIT LIKELY TO BE SCRAPPED.
Maharashtra	NASIK (P) TPS	3	0.00	0.00	0.00	0.00	14/04/2017 01:45		UNIT LIKELY TO BE SCRAPPED.
Maharashtra	NASIK (P) TPS	4	0.00	0.00	0.00	0.00	20/05/2017 00:25		UNIT LIKELY TO BE SCRAPPED.

DAILY MAINTENANCE REPORT (COAL, LIGNITE AND NUCLEAR) 13-10-2026

Sub-Report-10

State/System	Power Station	Unit No.	Planned Maintenance (MW)	Forced Maintenance (Major) (MW)	Forced Maintenance (Minor) (MW)	Others Maintenance (MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6	7	8	9	10
Maharashtra	NASIK (P) TPS	5	0.00	0.00	0.00	0.00	30/05/2017 15:24		UNIT LIKELY TO BE SCRAPPED.
Total Western			2,585.00	1,516.01	7,933.00	0.00			
Southern									
Andhra Pradesh	MEENAKSHI ENERGY LTD	1	0.00	0.00	150.00	0.00	13/10/2026 16:23	13/10/2026 19:19	MAL-FUNCTION OF RELAY
Andhra Pradesh	MEENAKSHI ENERGY LTD	3	0.00	0.00	0.00	0.00	13/10/2026 02:07	13/10/2026 05:51	MAL-FUNCTION OF RELAY
Andhra Pradesh	SGPL TPP	1	0.00	0.00	660.00	0.00	10/10/2026 07:20		BOILER MISC. PROBLEM
Karnataka	KUDGI STPP	1	800.00	0.00	0.00	0.00	22/08/2026 00:00		BOILER OVERHAUL/ ANNUAL MAINTENANCE
Karnataka	KAIGA	1	220.00	0.00	0.00	0.00	31/03/2025 23:11		MISCELLANEOUS PLANNED MAINTENANCE
Karnataka	RAICHUR TPS	1	0.00	210.00	0.00	0.00	15/03/2024 00:00		COAL FEEDING SYSTEM FAILURE.
Karnataka	RAICHUR TPS	2	0.00	0.00	210.00	0.00	29/09/2026 16:36		MAL-FUNCTION OF RELAY
Karnataka	RAICHUR TPS	3	0.00	0.00	210.00	0.00	12/10/2026 17:53		TUBE LKG. AT LOW TEMP. SUPERHEATER ZONE
Karnataka	RAICHUR TPS	7	0.00	0.00	210.00	0.00	10/10/2026 23:22		REHEATER TUBE LEAKAGE
Karnataka	ADANI POWER LIMITED UDUPI TPP	2	600.00	0.00	0.00	0.00	20/09/2026 23:59		BOILER OVERHAUL/ ANNUAL MAINTENANCE
Karnataka	TORANGALLU TPS (SBU-II)	3	300.00	0.00	0.00	0.00	01/07/2026 04:05		R AND M / REFURBISHMENT WORKS
Tamil Nadu	NEYVELI (EXT) TPS	2	0.00	0.00	210.00	0.00	13/10/2026 11:11		AIR PREHEATERS PROBLEM
Tamil Nadu	NEYVELI NEW TPP	1	0.00	0.00	500.00	0.00	03/10/2026 00:10		ELECTRICAL MISCELLANEOUS PROBLEMS
Tamil Nadu	NEYVELI TPS-II	4	210.00	0.00	0.00	0.00	26/08/2026 00:00		SCHEDULED ANNUAL MAINTENANCE
Tamil Nadu	NEYVELI TPS-II	6	0.00	0.00	0.00	0.00	13/10/2026 22:21		SUPER HEATER TUBE LEAKAGE

DAILY MAINTENANCE REPORT (COAL, LIGNITE AND NUCLEAR) 13-10-2026

Sub-Report-10

State/System	Power Station	Unit No.	Planned Maintenance (MW)	Forced Maintenance (Major) (MW)	Forced Maintenance (Minor) (MW)	Others Maintenance (MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6	7	8	9	10
Tamil Nadu	NEYVELI TPS-II	7	0.00	0.00	210.00	0.00	13/10/2026 16:03		BOILER AUX. MISC. PROMLEMS
Tamil Nadu	NEYVELI TPS-II EXP	1	0.00	0.00	250.00	0.00	13/10/2026 18:36		WATER WALL TUBE LEAKAGE
Tamil Nadu	NEYVELI TPS-II EXP	2	0.00	0.00	250.00	0.00	02/10/2026 00:52		BOILER AUX. MISC. PROMLEMS
Tamil Nadu	MADRAS A.P.S.	1	0.00	220.00	0.00	0.00	30/01/2018 16:30		REACTOR MAINTENANCE WORKS.
Tamil Nadu	NORTH CHENNAI TPS STAGE 1	2	0.00	0.00	210.00	0.00	11/10/2026 18:18	13/10/2026 07:43	WATER WALL TUBE LEAKAGE
Tamil Nadu	NORTH CHENNAI TPS STAGE 2	5	0.00	0.00	600.00	0.00	12/10/2026 12:35		WATER WALL TUBE LEAKAGE
Tamil Nadu	TUTICORIN TPS	1	0.00	210.00	0.00	0.00	15/03/2025 21:50		FIRE IN CABLE GALLERY.
Tamil Nadu	Nagai TPP	1	0.00	0.00	0.00	0.00	13/10/2026 05:14	13/10/2026 06:07	GENERATOR PROTECTION RELAY OPERATION PROBLEM
Tamil Nadu	TCP Limited	1	63.50	0.00	0.00	0.00	16/07/2021 05:21		MISCELLANEOUS PLANNED MAINTENANCE
Telangana	RAMAGUNDEM STPS	6	0.00	0.00	500.00	0.00	07/10/2026 02:58		AIR PREHEATERS PROBLEM
Telangana	BHADRADRI TPP	2	0.00	0.00	270.00	0.00	13/10/2026 15:31		AIR PREHEATERS PROBLEM
Telangana	BHADRADRI TPP	3	0.00	270.00	0.00	0.00	09/09/2026 12:36		ELECTRICAL MISCELLANEOUS PROBLEMS
Telangana	YADADRI TPS	1	0.00	0.00	800.00	0.00	28/09/2026 13:37		FURNACE FIRE OUT /FLAME FAILURE
Total Southern			2,193.50	910.00	5,240.00	0.00			
Eastern									
Bihar	BARH STPS	4	0.00	0.00	660.00	0.00	11/10/2026 10:39		WATER WALL TUBE LEAKAGE
Bihar	BUXAR TPP	1	0.00	0.00	660.00	0.00	03/10/2026 10:43		BOILER FEED PUMP/MOTOR PROBLEM
Bihar	KAHALGAON TPS	4	0.00	0.00	210.00	0.00	06/10/2026 12:00		GEN. COOLING SYSTEM FAILURE

DAILY MAINTENANCE REPORT (COAL, LIGNITE AND NUCLEAR) 13-10-2026

Sub-Report-10

State/System	Power Station	Unit No.	Planned Maintenance (MW)	Forced Maintenance (Major) (MW)	Forced Maintenance (Minor) (MW)	Others Maintenance (MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6	7	8	9	10
Bihar	KAHALGAON TPS	6	500.00	0.00	0.00	0.00	25/09/2026 00:09		OVERHAULING WORKS
Jharkhand	TENUGHAT TPS	1	0.00	0.00	210.00	0.00	11/10/2026 15:53	13/10/2026 18:47	WATER WALL TUBE LEAKAGE
Jharkhand	MAHADEV PRASAD STPP	1	0.00	0.00	270.00	0.00	13/10/2026 08:57		WATER WALL TUBE LEAKAGE
Odisha	TALCHER STPS	5	0.00	0.00	500.00	0.00	12/10/2026 01:58		TURBINE MISC.
Odisha	IB VALLEY TPS	4	660.00	0.00	0.00	0.00	14/09/2026 23:24		SCHEDULED ANNUAL MAINTENANCE
Odisha	KAMALANGA TPS	3	0.00	0.00	350.00	0.00	02/10/2026 23:24		TURBINE OIL SYSTEM PROBLEM
West Bengal	MEJIA TPS	2	0.00	210.00	0.00	0.00	10/09/2026 14:38		STATOR/ STATOR EARTH FAULT
West Bengal	MEJIA TPS	5	0.00	250.00	0.00	0.00	12/08/2026 20:04		GENERATOR PROTECTION RELAY OPERATION PROBLEM
West Bengal	KOLAGHAT TPS	3	0.00	210.00	0.00	0.00	18/06/2026 19:37		FIRE IN GEN. BUSHING/ BUSHING FAILURE
West Bengal	TITAGARH TPS	1	0.00	0.00	0.00	0.00	10/10/2016 04:57		RESERVE SHUT DOWN / STANDBY UNIT
West Bengal	TITAGARH TPS	2	0.00	0.00	0.00	0.00	09/10/2016 04:57		RESERVE SHUT DOWN / STANDBY UNIT
West Bengal	TITAGARH TPS	3	0.00	0.00	0.00	0.00	10/10/2016 04:18		RESERVE SHUT DOWN / STANDBY UNIT
West Bengal	TITAGARH TPS	4	0.00	0.00	0.00	0.00	09/10/2016 05:36		RESERVE SHUT DOWN / STANDBY UNIT
Total Eastern			1,160.00	670.00	2,860.00	0.00			

Total	6,138.50	4,701.01	19,323.00	0.00			
-------	----------	----------	-----------	------	--	--	--

Remarks:-

Report Version :-