

**CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION**

RECOMMISSIONING OF THERMAL/NUCLEAR UNITS AS: 14-May-2026

Sub - Report 14

Station	Unit No.	Capacity(MW)	Date of Maintanance DD/MM/YYYY HH24:MM	Sync Date DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
I.P.CCPP	2	30.0	5/14/26, 11:00 AM	5/14/26, 1:45 PM	MINOR MAINTENANCE WORKS
PRAGATI CCPP	1	104.6	5/12/26, 8:07 PM	5/14/26, 8:04 PM	GT-MISCELLANEOUS PROBLEMS
PRAGATI CCPP	3	121.2	5/12/26, 8:07 PM	5/14/26, 11:13 PM	GT-MISCELLANEOUS PROBLEMS
JALIPA KAPURDI TPP	5	135.0	5/11/26, 2:17 PM	5/14/26, 6:35 AM	BOILER MISC. PROBLEM
CHHABRA-I PH-1 TPP	1	250.0	5/13/26, 12:00 AM	5/14/26, 8:59 PM	BOILER MISC. PROBLEM
KALISINDH TPS	2	600.0	5/14/26, 4:49 AM	5/14/26, 11:56 AM	GENERATOR MISCELLANEOUS MAINTENANCE
OBRA TPS	12	200.0	5/14/26, 1:41 PM	5/14/26, 5:23 PM	I.D. FANS PROBLEM
OBRA TPS	14	660.0	5/7/26, 12:08 AM	5/14/26, 4:13 AM	TUBE LKG. AT LOW TEMP. SUPERHEATER ZONE
HARDUAGANJ TPS	8	250.0	5/13/26, 4:10 PM	5/14/26, 1:13 AM	ELECTRICAL FAULT
PARICHHA TPS	4	210.0	5/13/26, 9:53 PM	5/14/26, 3:20 AM	WATER WALL TUBE LEAKAGE
DSPM TPS	1	250.0	5/13/26, 11:00 AM	5/14/26, 6:39 AM	TUBE LKG. AT LOW TEMP. SUPERHEATER ZONE
SANJAY GANDHI TPS	5	500.0	5/12/26, 8:28 AM	5/14/26, 11:50 PM	WATER WALL TUBE LEAKAGE
SASAN UMTTP	4	660.0	5/13/26, 6:12 AM	5/14/26, 5:47 PM	REHEATER TUBE LEAKAGE
SASAN UMTTP	6	660.0	5/12/26, 12:57 PM	5/14/26, 7:41 AM	REHEATER TUBE LEAKAGE
WANAKBORI TPS	2	210.0	5/13/26, 7:39 AM	5/14/26, 12:02 AM	TURBINE BEARING PROBLEM
SABARMATI (D-F STATIONS)	1	120.0	5/13/26, 3:49 PM	5/14/26, 10:08 AM	MAIN STEAM LINE PROBLEM
NASIK TPS	5	210.0	5/8/26, 8:38 PM	5/14/26, 6:37 AM	RSD/LOW SCHEDULE
KHAPARKHEDA TPS	2	210.0	5/14/26, 7:20 PM	5/14/26, 9:52 PM	FURNACE FIRE OUT /FLAME FAILURE
RATNAGIRI CCPP	5	213.0	5/14/26, 1:21 AM	5/14/26, 3:22 PM	GT- LOW SYSTEM DAMAND
RATNAGIRI CCPP	8	213.0	5/14/26, 12:48 AM	5/14/26, 4:15 PM	GT- LOW SYSTEM DAMAND
GMR WARORA TPS	1	300.0	5/12/26, 11:10 PM	5/14/26, 1:20 AM	ASH HANDLING SYSTEM PROBLEM
AMRAVATI TPS	1	270.0	5/13/26, 11:45 AM	5/14/26, 8:19 PM	TURBINE CONTROL VALVE PROBLEM
NEYVELI TPS-II	2	210.0	5/12/26, 9:58 AM	5/14/26, 1:28 PM	WATER WALL TUBE LEAKAGE
NEYVELI TPS-II EXP	2	250.0	5/14/26, 4:10 AM	5/14/26, 7:49 AM	TURBINE VIBRATIONS HIGH
TELANGANA STPP PH-1	1	800.0	5/13/26, 11:08 PM	5/14/26, 4:54 AM	ECONOMISER TUBE LEAKAGE
MEENAKSHI ENERGY LTD	1	150.0	5/6/26, 3:01 PM	5/14/26, 2:06 AM	P.A. FANS PROBLEM
MUZAFFARPUR TPS	4	195.0	5/13/26, 7:46 PM	5/14/26, 1:15 AM	GEN. TRANS DAMAGED
MEJIA TPS	7	500.0	5/8/26, 1:38 AM	5/14/26, 6:42 AM	BARRING GEAR PROBLEM
TENUGHAT TPS	2	210.0	5/12/26, 4:29 AM	5/14/26, 6:48 PM	WATER WALL TUBE LEAKAGE

Station	Unit No.	Capacity(MW)	Date of Maintanance DD/MM/YYYY HH24:MM	Sync Date DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
NORTH KARANPURA TPP	1	660.0	5/9/26, 11:52 PM	5/14/26, 5:54 PM	WATER WALL TUBE LEAKAGE
AGARTALA GT	2	21.0	5/14/26, 12:00 AM	5/14/26, 2:59 PM	Fuel Shortage
KATHALGURI CCPP	5	33.5	5/14/26, 12:00 AM	5/14/26, 11:59 PM	Low system demand/ costly fuel
Total		9406.30			

Note: 1.Actual generation is gross generation from stations above 25 MW. It excludes generation from RES.
2.Data published in this report is for operational purpose only and not for commercial purpose.
3.Generation data/Outage data are compiled based on data submitted directly by the utilities."

Remarks:-

Report Version :-