

**CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION**

THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 14-May-2026

Sub - Report 15

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
TALWANDI SABO TPP	1	660.00	5/14/26, 4:00 PM		ABNORMAL SOUND
I.P.CCPP	2	30.00	5/14/26, 11:00 AM	2026-05-14 13:45:00	MINOR MAINTENANCE WORKS
KALISINDH TPS	2	600.00	5/14/26, 4:49 AM	2026-05-14 11:56:00	GENERATOR MISCELLANEOUS MAINTENANCE
OBRA TPS	12	200.00	5/14/26, 1:41 PM	2026-05-14 17:23:00	I.D. FANS PROBLEM
ANPARA C TPS	2	600.00	5/14/26, 1:54 AM		WATER WALL TUBE LEAKAGE
KUNDARKI TPS	1	45.00	5/14/26, 10:19 PM		ELECTRICAL MISCELLANEOUS PROBLEMS
KUNDARKI TPS	2	45.00	5/14/26, 10:26 PM		TURBINE MISC.
WANAKBORI TPS	1	210.00	5/14/26, 9:07 PM		AIR PREHEATERS PROBLEM
KHAPARKHEDA TPS	2	210.00	5/14/26, 7:20 PM	2026-05-14 21:52:00	FURNACE FIRE OUT /FLAME FAILURE
PARLI TPS	6	250.00	5/14/26, 5:40 PM		DRUM LEVEL HIGH/ low
RATNAGIRI CCPP	5	213.00	5/14/26, 1:21 AM	2026-05-14 15:22:00	GT- LOW SYSTEM DAMAND
RATNAGIRI CCPP	8	213.00	5/14/26, 12:48 AM	2026-05-14 16:15:00	GT- LOW SYSTEM DAMAND
TARAPUR	4	540.00	5/14/26, 12:00 AM	2026-05-16	REACTOR MAINTENANCE WORKS.
NEYVELI TPS-II	1	210.00	5/14/26, 12:00 AM		SCHEDULED ANNUAL MAINTENANCE
NEYVELI TPS-II EXP	2	250.00	5/14/26, 4:10 AM	2026-05-14 07:49:00	TURBINE VIBRATIONS HIGH
VALLUR TPP	1	500.00	5/14/26, 6:50 PM		WATER WALL TUBE LEAKAGE
AGARTALA GT	2	21.00	5/14/26, 12:00 AM	2026-05-14 14:59:59	Fuel Shortage
KATHALGURI CCPP	5	33.50	5/14/26, 12:00 AM	2026-05-14 23:59:59	Low system demand/ costly fuel
Total		4830.50			

Note: 1.Actual generation is gross generation from stations above 25 MW. It excludes generation from RES.
2.Data published in this report is for operational purpose only and not for commercial purpose.
3.Generation data/Outage data are compiled based on data submitted directly by the utilities."

Remarks:-

Report Version :-