

**CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION**

THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 14-11-2019

Sub-Report - 15

Station	Unit No	Capacity (MW)	Date of Maintanance	Expected/Sync Date of return	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
JALIPA KAPURDI TPP	2	135.00	14/11/2019 12:59		DRUM LEVEL LOW
HAZIRA CCPP EXT	1	351.00	14/11/2019 16:38		RSD/LOW SCHEDULE
SURAT LIG. TPS	1	125.00	14/11/2019 14:00	17/11/2019	WATER WALL TUBE LEAKAGE
METTUR TPS	1	210.00	14/11/2019 02:20	15/11/2019	TURBINE VIBRATIONS HIGH
TUTICORIN TPS	3	210.00	14/11/2019 20:40	16/11/2019	BOILER AUX. MISC. PROMLEMS
MUZAFFARPUR TPS	4	195.00	14/11/2019 09:14		ELECTRICAL MISCELLANEOUS PROBLEMS
Total		1226.00			