

**CENTRAL ELECTRICITY AUTHORITY  
G O & D WING  
OPERATION PERFORMANCE MONITORING DIVISION**

**RECOMMISSIONING OF THERMAL/NUCLEAR UNITS AS ON: 15-05-2019**

Sub-Report - 14

Station	Unit No	Capacity (MW)	Date of Maintanance	Sync Date	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
RAJASTHAN A.P.S.	2	200.00	23/04/2019 13:50	15/05/2019 15:00	REACTOR MAINTENANCE WORKS.
KOTA TPS	5	210.00	13/05/2019 10:57	15/05/2019 06:52	TUBE LKG. AT LOW TEMP. SUPERHEATER ZONE
KORBA STPS	5	500.00	12/05/2019 21:25	15/05/2019 06:14	WATER WALL TUBE LEAKAGE
KORBA-WEST TPS	4	210.00	14/05/2019 08:27	15/05/2019 09:06	SUPER HEATER TUBE LEAKAGE
MARWA TPS	2	500.00	12/05/2019 21:03	15/05/2019 12:47	WATER WALL TUBE LEAKAGE
SURAT LIG. TPS	2	125.00	15/05/2019 11:35	15/05/2019 20:57	BOILER MISC. PROBLEM
GADARWARA TPP	1	800.00	03/05/2019 20:14	15/05/2019 11:45	NON STABLISED UNIT
SANJAY GANDHI TPS	2	210.00	29/04/2019 13:55	15/05/2019 18:26	ECONOMISER TUBE LEAKAGE
CHANDRAPUR(MAHARASHTRA) STPS	3	210.00	15/05/2019 00:41	15/05/2019 15:50	AIR PREHEATERS PROBLEM
KUDGI STPP	3	800.00	30/04/2019 13:08	15/05/2019 18:18	RSD/LOW SCHEDULE
NEYVELI TPS-II	1	210.00	13/05/2019 11:00	15/05/2019 08:41	WATER WALL TUBE LEAKAGE
NORTH CHENNAI TPS	3	210.00	14/05/2019 04:24	15/05/2019 18:21	WATER WALL TUBE LEAKAGE
KOVIKALPAL CCPP	1	69.65	15/05/2019 01:17	15/05/2019 02:50	GRID DISTURBANCE
RAMAGUNDEM STPS	4	500.00	12/05/2019 23:50	15/05/2019 23:59	WATER WALL TUBE LEAKAGE
SAGARDIGHI TPS	1	300.00	13/05/2019 22:56	15/05/2019 12:50	Low system demand/ costly fuel
SOUTHERN REPL. TPS	2	67.50	13/05/2019 22:01	15/05/2019 11:22	RESERVE SHUT DOWN / STANDBY UNIT
LAKWA REPLACEMENT POWER PROJECT	5	9.96	15/05/2019 07:20	15/05/2019 07:35	MINOR MAINTENANCE WORKS
Total		5,132.11			