

**CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION**

THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 15-05-2019

Sub-Report - 15

Station	Unit No	Capacity (MW)	Date of Maintanance	Expected/Sync Date of return	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
RAJASTHAN A.P.S.	2	200.00	15/05/2019 23:18		REACTOR MAINTENANCE WORKS.
HARDUAGANJ TPS	7	105.00	15/05/2019 01:16		GEN. TRANSFORMER TRIPPING/ DAMAGED
HARDUAGANJ TPS	8	250.00	15/05/2019 01:16		GEN. TRANSFORMER TRIPPING/ DAMAGED
HARDUAGANJ TPS	9	250.00	15/05/2019 01:16		GEN. TRANSFORMER TRIPPING/ DAMAGED
KORBA-III	2	120.00	15/05/2019 01:20		WATER WALL TUBE LEAKAGE
KUTCH LIG. TPS	3	75.00	15/05/2019 02:00		WATER WALL TUBE LEAKAGE
SURAT LIG. TPS	2	125.00	15/05/2019 11:35	15/05/2019	BOILER MISC. PROBLEM
SANJAY GANDHI TPS	1	210.00	15/05/2019 18:35		WATER WALL TUBE LEAKAGE
SASAN UMTTP	1	660.00	15/05/2019 05:47	16/05/2019	ECONOMISER TUBE LEAKAGE
CHANDRAPUR(MAHARASHTRA) STPS	3	210.00	15/05/2019 00:41		AIR PREHEATERS PROBLEM
TROMBAY TPS	8	250.00	15/05/2019 11:03		Cooling Water System Abnormal/ Maintenance
MADRAS A.P.S.	2	220.00	15/05/2019 02:45		REACTOR MAINTENANCE WORKS.
KOVIKALPAL CCPP	1	69.65	15/05/2019 01:17		GRID DISTURBANCE
LAKWA REPLACEMENT POWER PROJECT	5	9.96	15/05/2019 07:20		MINOR MAINTENANCE WORKS
Total		2754.62			