

**CENTRAL ELECTRICITY AUTHORITY  
G O & D WING  
OPERATION PERFORMANCE MONITORING DIVISION**

**RECOMMISSIONNING OF THERMAL/NUCLEAR UNITS AS ON: 15-07-2019**

Sub-Report - 14

Station	Unit No	Capacity (MW)	Date of Maintanance	Sync Date	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
KOTA TPS	3	210.00	09/07/2019 12:04	15/07/2019 22:03	RSD/LOW SCHEDULE
KOTA TPS	4	210.00	06/07/2019 23:00	15/07/2019 20:49	RSD/LOW SCHEDULE
SURATGARH TPS	4	250.00	15/06/2019 14:15	15/07/2019 23:41	TURBINE CONTROL VALVE PROBLEM
MEJA STPP	1	660.00	14/07/2019 15:00	15/07/2019 05:30	TURBINE CONTROL VALVE PROBLEM
NAWAPARA TPP	2	300.00	14/07/2019 14:54	15/07/2019 10:03	H.P. AND L.P. bypass system
OP JINDAL TPS	3	250.00	02/07/2019 16:07	15/07/2019 14:18	CONDENSER TUBE LEAKAGE/ CLEANING
WANAKBORI TPS	2	210.00	13/07/2019 10:55	15/07/2019 15:15	RSD/LOW SCHEDULE
SATPURA TPS	7	210.00	12/07/2019 04:40	15/07/2019 19:32	WATER WALL TUBE LEAKAGE
MUZAFFARPUR TPS	1	110.00	11/07/2019 10:42	15/07/2019 22:18	TURBINE MISC. PROBLEMS
MUZAFFARPUR TPS	2	110.00	12/07/2019 03:01	15/07/2019 11:20	TURBINE MISC. PROBLEMS
TALCHER STPS	3	500.00	15/06/2019 23:16	15/07/2019 15:50	BOILER OVERHAUL/ ANNUAL MAINTENANCE
MEJIA TPS	4	210.00	06/07/2019 13:27	15/07/2019 00:12	Low system demand/ costly fuel
BANDEL TPS	2	60.00	11/07/2019 08:21	15/07/2019 18:32	COAL SHORTAGE
D.P.L. TPS	7	300.00	12/07/2019 00:00	15/07/2019 17:45	COAL SHORTAGE
SOUTHERN REPL. TPS	1	67.50	15/07/2019 01:14	15/07/2019 10:28	RESERVE SHUT DOWN / STANDBY UNIT
BONGAIGAON TPP	3	250.00	10/07/2019 08:12	15/07/2019 11:52	WATER WALL TUBE LEAKAGE
Total		3,907.50			