

**CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION**

THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 15-07-2019

Sub-Report - 15

Station	Unit No	Capacity (MW)	Date of Maintanance	Expected/Sync Date of return	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
RAJIV GANDHI TPS	2	600.00	15/07/2019 16:07		RSD/LOW SCHEDULE
SINGRAULI STPS	4	200.00	15/07/2019 05:52		WATER WALL TUBE LEAKAGE
KUNDARKI TPS	1	45.00	15/07/2019 17:15		BOILER MISC. PROBLEM
SANJAY GANDHI TPS	2	210.00	15/07/2019 23:05		BOILER OVERHAUL/ ANNUAL MAINTENANCE
NEYVELI TPS- I	3	50.00	15/07/2019 22:55		BOILER OVERHAUL/ ANNUAL MAINTENANCE
TUTICORIN TPS	1	210.00	15/07/2019 13:15		RESERVE SHUT DOWN / STANDBY UNIT
TUTICORIN TPS	5	210.00	15/07/2019 14:01	16/07/2019	RESERVE SHUT DOWN / STANDBY UNIT
FARAKKA STPS	5	500.00	15/07/2019 23:24		TURBINE MISC.
BANDEL TPS	5	210.00	15/07/2019 04:10		TURBINE VIBRATIONS HIGH
D.P.L. TPS	8	250.00	15/07/2019 17:50	24/07/2019	ECONOMISER TUBE LEAKAGE
SOUTHERN REPL. TPS	1	67.50	15/07/2019 01:14		RESERVE SHUT DOWN / STANDBY UNIT
BONGAIGAON TPP	1	250.00	15/07/2019 01:00		BOILER MISC. PROBLEM
Total		2802.50			