

CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION

THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 15-09-2025

Sub-Report - 15

Station	Unit No	Capacity (MW)	Date of Maintanance	Expected/Sync Date of return	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
AURAIYA CCPP	1	111.19	15/09/2025 22:16	15/09/2025	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	1	130.19	15/09/2025 22:24	15/09/2025	CONSERVATION OF MAIN FUEL/RSD
OBRA TPS	12	200.00	15/09/2025 08:10		FURNACE DRAFT ABNORMAL
OBRA TPS	14	660.00	15/09/2025 23:35		ELECTRICAL MISCELLANEOUS PROBLEMS
CHAKABURA TPP	2	30.00	15/09/2025 03:27		Turbine Misc
SVPL TPP	1	63.00	15/09/2025 19:35	16/09/2025	COAL FEEDING PROBLEM IN PLANT
GANDHAR CCPP	3	144.30	15/09/2025 19:15	15/09/2025	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	2	106.00	15/09/2025 22:52	15/09/2025	CONSERVATION OF MAIN FUEL/RSD
VINDHYACHAL STPS	4	210.00	15/09/2025 20:14	15/09/2025	SUPER HEATER TUBE LEAKAGE
RATNAGIRI CCPP	5	213.00	15/09/2025 22:48		GT- LOW SYSTEM DAMAND
RATNAGIRI CCPP	8	213.00	15/09/2025 23:18		GT- LOW SYSTEM DAMAND
CHANDRAPUR(MAHARASHTRA) STPS	6	500.00	15/09/2025 09:03		WATER WALL TUBE LEAKAGE
SHIRPUR TPP	1	150.00	15/09/2025 04:55		FURNACE FIRE OUT /FLAME FAILURE
BELLARY TPS	2	500.00	15/09/2025 06:54		FURNACE FIRE OUT /FLAME FAILURE
RAICHUR TPS	5	210.00	15/09/2025 05:23		GENERATOR PROTECTION RELAY OPERATION PROBLEM
BARH STPS	5	660.00	15/09/2025 02:30	15/09/2025	WATER WALL TUBE LEAKAGE
BAKRESWAR TPS	1	210.00	15/09/2025 20:32		Miscellaneous
BAKRESWAR TPS	1		15/09/2025 15:36		FURNACE FIRE OUT /FLAME FAILURE
KATHALGURI CCPP	5	33.50	15/09/2025 00:00		MISCELLANOUS
KATHALGURI CCPP	7	30.00	15/09/2025 00:00		MISCELLANEOUS PLANNED MAINTENANCE
KATHALGURI CCPP	8	30.00	15/09/2025 00:00		MISCELLANEOUS
LAKWA REPLACEMENT POWER PROJECT	1	9.96	15/09/2025 21:30		GRID DISTURBANCES MISC.
LAKWA REPLACEMENT POWER PROJECT	2	9.96	15/09/2025 00:00		GRID DISTURBANCES MISC.
AGARTALA GT	3	21.00	15/09/2025 00:00		Fuel Shortage
Total		4445.11			