

CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION

RECOMMISSIONNING OF THERMAL/NUCLEAR UNITS AS: 15-Sep-2026

Sub - Report 14

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
FARIDABAD CCPP	1	137.76	9/15/26, 7:54AM		CONSERVATION OF MAIN FUEL/RSD
FARIDABAD CCPP	2	137.76	9/15/26, 8:12AM		CONSERVATION OF MAIN FUEL/RSD
FARIDABAD CCPP	3	156.07	9/15/26, 8:06AM		CONSERVATION OF MAIN FUEL/RSD
RAMGARH CCPP	5	110.0	9/14/26, 10:21PM		FUEL SUPPLY & OTHER MISC. PROBLEMS
DHOLPUR CCPP	1	110.0	9/15/26, 7:45AM		Low system demand/ costly fuel
DHOLPUR CCPP	2	110.0	9/15/26, 7:45AM		Low system demand/ costly fuel
ANTA CCPP	2		9/15/26, 3:12PM		CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	2	88.71	9/15/26, 8:09AM		CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	3	88.71	9/15/26, 7:57AM		CONSERVATION OF MAIN FUEL/RSD
SHREE CEMENT LTD TPS	3	19.0	9/15/26, 8:10AM		RSD/LOW SCHEDULE
SHREE CEMENT LTD TPS	4	19.0	9/15/26, 8:10AM		RSD/LOW SCHEDULE
SHREE CEMENT LTD TPS	5	6.0	9/15/26, 8:05AM		RSD/LOW SCHEDULE
OBRA TPS	11	200.0	9/15/26, 6:40PM		FURNACE FIRE OUT /FLAME FAILURE
OBRA TPS	12	200.0	9/15/26, 7:03AM		FURNACE DRAFT ABNORMAL
OBRA TPS	13	200.0	9/15/26, 10:41AM		FURNACE DRAFT ABNORMAL
UNCHA HAR TPS	4	210.0	9/14/26, 8:57PM		BOILER FEED PUMP/MOTOR PROBLEM
AURAIYA CCPP	1	111.19	9/15/26, 8:15AM		CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	2	111.19	9/15/26, 7:42AM		CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	3	111.19	9/15/26, 7:47AM		CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	4	111.19	9/15/26, 8:18AM		CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	5	109.3	9/15/26, 8:10AM		CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	6	109.3	9/15/26, 8:11AM		CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	1	130.19	9/15/26, 7:46AM		CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	2	130.19	9/15/26, 7:55AM		CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	3		9/14/26, 7:09AM		CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	3	130.19	9/15/26, 7:50AM		CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	4	130.19	9/15/26, 7:56AM		CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	5	154.51	9/15/26, 7:50AM		CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	6	154.51	9/15/26, 8:50AM		CONSERVATION OF MAIN FUEL/RSD

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
UKAI TPS	4	200.0	9/14/26, 7:52AM		FURNACE FIRE OUT /FLAME FAILURE
KAWAS CCPP	1	106.0	9/15/26, 7:38AM		CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	2	106.0	9/15/26, 7:29AM		CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	3	106.0	9/15/26, 7:23AM		CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	4	106.0	9/15/26, 7:33AM		CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	5	116.1	9/15/26, 7:31AM		CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	6	116.1	9/15/26, 7:24AM		CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	1	144.3	9/15/26, 7:18AM		CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	2	144.3	9/15/26, 7:37AM		CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	3	144.3	9/15/26, 7:24AM		CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	4	224.49	9/15/26, 7:29AM		CONSERVATION OF MAIN FUEL/RSD
KORADI TPS	6	210.0	9/13/26, 10:01AM		FURNACE FIRE OUT /FLAME FAILURE
CHANDRAPUR(MAHARASHTRA) STPS	3	210.0	9/15/26, 9:40AM		ELECTRICAL MISCELLANEOUS PROBLEMS
BELA TPS	1	270.0	9/11/26, 4:57PM		E.S.P.MISCELLANEOUS
TUTICORIN TPS	3	210.0	9/14/26, 4:46AM		BOILER AUX. MISC. PROMLEMS
NORTH CHENNAI TPS STAGE 2	4	600.0	9/13/26, 9:11AM		WATER WALL TUBE LEAKAGE
NEYVELI TPS-II	3	210.0	6/29/26, 12:00AM		SCHEDULED ANNUAL MAINTENANCE
YADADRI TPS	3	800.0	9/15/26, 2:10AM		FURNACE DRAFT ABNORMAL
NABINAGAR STPP	3		9/15/26, 5:57AM		GEN. TRANSORMER PROTECTION RELAY OPERATION PROBLEM
NABINAGAR STPP	3	660.0	9/12/26, 4:34PM		WATER WALL TUBE LEAKAGE
RAGHUNATHPUR TPP	2	600.0	9/15/26, 2:12PM		TURBINE OIL SYSTEM PROBLEM
MAHADEV PRASAD STPP	2	270.0	8/15/26, 11:55PM		BOILER OVERHAUL/ ANNUAL MAINTENANCE
AGARTALA GT	1	21.0	9/15/26, 12:00AM		Fuel Shortage
AGARTALA GT	2	21.0	9/15/26, 12:00AM		Fuel Shortage
AGARTALA GT	3	21.0	9/15/26, 12:00AM		Fuel Shortage
AGARTALA GT	5	25.5	9/15/26, 12:00AM		Fuel Shortage
KATHALGURI CCPP	4	33.5	9/15/26, 12:00AM		Low system demand/ costly fuel

Total	8961.74			
-------	---------	--	--	--

Remarks:-

Report Version :-