

CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION

Thermal/Nuclear Units Went Out of Grid On: 15-Sep-2026

Sub - Report 15

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
ROPAR TPS	4	210.00	9/15/26, 12:25PM		FURNACE FIRE OUT /FLAME FAILURE
ROPAR TPS	5	210.00	9/15/26, 4:30PM		MAIN STEAM LINE PROBLEM
FARIDABAD CCPP	1	137.76	9/15/26, 7:54AM	2026-09-15 14:16:00	CONSERVATION OF MAIN FUEL/RSD
FARIDABAD CCPP	2	137.76	9/15/26, 8:12AM	2026-09-15 15:47:00	CONSERVATION OF MAIN FUEL/RSD
FARIDABAD CCPP	3	156.07	9/15/26, 8:06AM	2026-09-15 15:15:00	CONSERVATION OF MAIN FUEL/RSD
JALIPA KAPURDI TPP	1	135.00	9/15/26, 3:43AM		BOILER MISC. PROBLEM
RAMGARH CCPP	5	110.00	9/15/26, 10:21PM		FUEL SUPPLY & OTHER MISC. PROBLEMS
DHOLPUR CCPP	1	110.00	9/15/26, 7:45AM	2026-09-15 18:02:00	Low system demand/ costly fuel
DHOLPUR CCPP	2	110.00	9/15/26, 7:45AM	2026-09-15 17:38:00	Low system demand/ costly fuel
ANTA CCPP	2	88.71	9/15/26, 3:12PM	2026-09-15 17:10:00	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	2		9/15/26, 8:09AM	2026-09-15 13:31:00	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	3	88.71	9/15/26, 7:57AM	2026-09-15 15:00:00	CONSERVATION OF MAIN FUEL/RSD
SHREE CEMENT LTD TPS	3	19.00	9/15/26, 8:10AM	2026-09-15 15:29:00	RSD/LOW SCHEDULE
SHREE CEMENT LTD TPS	4	19.00	9/15/26, 8:10AM	2026-09-15 16:01:00	RSD/LOW SCHEDULE
SHREE CEMENT LTD TPS	5	6.00	9/15/26, 8:05AM	2026-09-15 15:33:00	RSD/LOW SCHEDULE
OBRA TPS	11	200.00	9/15/26, 6:40PM	2026-09-15 23:27:00	FURNACE FIRE OUT /FLAME FAILURE
OBRA TPS	12	200.00	9/15/26, 7:03AM	2026-09-15 13:08:00	FURNACE DRAFT ABNORMAL
OBRA TPS	13	200.00	9/15/26, 10:41AM	2026-09-15 16:32:00	FURNACE DRAFT ABNORMAL
HARDUAGANJ TPS	7	105.00	9/15/26, 7:33PM		BOILER FEED PUMP/MOTOR PROBLEM
AURAIYA CCPP	1	111.19	9/15/26, 8:15AM	2026-09-15 15:50:00	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	2	111.19	9/15/26, 7:42AM	2026-09-15 13:28:00	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	3	111.19	9/15/26, 7:47AM	2026-09-15 15:44:00	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	4	111.19	9/15/26, 8:18AM	2026-09-15 13:38:00	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	5	109.30	9/15/26, 8:10AM	2026-09-15 15:48:00	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	6	109.30	9/15/26, 8:11AM	2026-09-15 15:59:00	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	1	130.19	9/15/26, 7:46AM	2026-09-15 15:53:00	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	2	130.19	9/15/26, 7:55AM	2026-09-15 13:35:00	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	3	130.19	9/15/26, 7:50AM	2026-09-15 13:44:00	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	4	130.19	9/15/26, 7:56AM	2026-09-15 15:38:00	CONSERVATION OF MAIN FUEL/RSD

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
DADRI CCPP	5	154.51	9/15/26, 7:50AM	2026-09-15 15:30:00	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	6		9/15/26, 7:50AM	2026-09-15	WATER WALL TUBE LEAKAGE
DADRI CCPP	6	154.51	9/15/26, 8:50AM	2026-09-15 15:15:00	CONSERVATION OF MAIN FUEL/RSD
SANJAY GANDHI TPS	1	210.00	9/15/26, 2:00AM		CAPITAL MAINTENANCE
AKRIMOTA LIG TPS	2	125.00	9/15/26, 3:59AM		P.A. FANS PROBLEM
SURAT LIG. TPS	2	125.00	9/15/26, 11:46PM		BOILER MISC. PROBLEM
ADANI POWER LIMITED MUNDRA TPP - III	8	660.00	9/15/26, 5:37PM		MILLING SYSTEM /RC FEEDER PROBLEM
KAWAS CCPP	1	106.00	9/15/26, 7:38AM	2026-09-15 14:15:00	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	2	106.00	9/15/26, 7:29AM	2026-09-15 16:16:00	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	3	106.00	9/15/26, 7:23AM	2026-09-15 13:25:00	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	4	106.00	9/15/26, 7:33AM	2026-09-15 16:09:00	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	5	116.10	9/15/26, 7:31AM	2026-09-15 15:38:00	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	6	116.10	9/15/26, 7:24AM	2026-09-15 15:33:00	CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	1	144.30	9/15/26, 7:18AM	2026-09-15 16:14:00	CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	2	144.30	9/15/26, 7:37AM	2026-09-15 14:14:00	CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	3	144.30	9/15/26, 7:24AM	2026-09-15 15:14:00	CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	4	224.49	9/15/26, 7:29AM	2026-09-15 15:31:00	CONSERVATION OF MAIN FUEL/RSD
CHANDRAPUR(MAHARASHTRA) STPS	3	210.00	9/15/26, 9:40AM	2026-09-15 16:16:00	ELECTRICAL MISCELLANEOUS PROBLEMS
CHANDRAPUR(MAHARASHTRA) STPS	4	210.00	9/15/26, 9:27AM		ELECTRICAL MISCELLANEOUS PROBLEMS
ADANI POWER LIMITED TIRODA TPP	1	660.00	9/15/26, 8:59PM		PIPES and VALVES BOILER SIDE
BELLARY TPS	3	700.00	9/15/26, 6:06AM		WATER WALL TUBE LEAKAGE
TUTICORIN TPS	3	210.00	9/15/26, 3:52PM		BOILER AUX. MISC. PROMLEMS
RAMAGUNDEM STPS	6	500.00	9/15/26, 3:05AM	2026-09-15	REHEATER TUBE LEAKAGE
YADADRI TPS	3	800.00	9/15/26, 2:10AM	2026-09-15 19:30:00	FURNACE DRAFT ABNORMAL
YADADRI TPS	4	800.00	9/15/26, 5:48AM		GENERATOR PROTECTION RELAY OPERATION PROBLEM
NABINAGAR STPP	3	660.00	9/15/26, 5:57AM	2026-09-15 09:57:00	GEN. TRANSORMER PROTECTION RELAY OPERATION PROBLEM
RAGHUNATHPUR TPP	2	600.00	9/15/26, 2:12PM	2026-09-15 19:39:00	TURBINE OIL SYSTEM PROBLEM
KOLAGHAT TPS	4	210.00	9/15/26, 12:16AM		GEN. COOLING SYSTEM FAILURE
FARAKKA STPS	5	500.00	9/15/26, 4:11PM	2026-09-15	FURNACE CLINKER FORMATION
DERANG TPP	2	600.00	9/15/26, 9:30PM		AIR PREHEATERS PROBLEM
AGARTALA GT	1	21.00	9/15/26, 12:00AM	2026-09-15 23:59:59	Fuel Shortage

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
AGARTALA GT	2	21.00	9/15/26, 12:00AM	2026-09-15 23:59:59	Fuel Shortage
AGARTALA GT	3	21.00	9/15/26, 12:00AM	2026-09-15 23:59:59	Fuel Shortage
AGARTALA GT	5	25.50	9/15/26, 12:00AM	2026-09-15 23:59:59	Fuel Shortage
BONGAIGAON TPP	1	250.00	9/15/26, 10:00AM	2026-09-15	WATER WALL TUBE LEAKAGE
KATHALGURI CCPP	4	33.50	9/15/26, 12:00AM	2026-09-15 23:59:59	Low system demand/ costly fuel
Total		13201.74			

Remarks:-

Report Version :-