

**CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION**

RECOMMISSIONING OF THERMAL/NUCLEAR UNITS AS ON 15-10-2018

Sub-Report-14

Station	Unit No.	Capacity (MW)	Date Of Maintenance	Expected Date Of Return	Reasons/Present Status
			DD/MM/YYYY HH24:MM	DD/MM/YYYY HH24:MM	
1	2	3	4	5	6
KALISINDH TPS	1	600.00	11/10/2018 13:20	15/10/2018 12:11	WATER WALL TUBE LEAKAGE
TAMNAR TPP	2	600.00	11/10/2018 20:45	15/10/2018 05:25	BOILER AUX. MISC. PROMLEMS
UTRAN CCPP	5	240.00	12/10/2018 22:38	15/10/2018 19:22	RESERVE SHUT DOWN / STANDBY UNIT
UTRAN CCPP	6	134.00	12/10/2018 22:35	15/10/2018 21:02	RESERVE SHUT DOWN / STANDBY UNIT
SEIONI TPP	1	600.00	07/10/2018 18:40	15/10/2018 05:35	BOILER MISC. PROBLEM
RATNAGIRI CCPP	5	213.00	10/10/2018 00:22	15/10/2018 19:48	Fuel Shortage
KORADI TPS	6	210.00	13/10/2018 23:56	15/10/2018 03:15	GENERATOR PROTECTION RELAY OPERATION PROBLEM
YERMARUS TPP	2	800.00	08/10/2018 19:45	15/10/2018 00:23	ASH HANDLING SYSTEM PROBLEM
Total		3,397.00			