

**CENTRAL ELECTRICITY AUTHORITY  
G O & D WING  
OPERATION PERFORMANCE MONITORING DIVISION**

THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON 15-10-2018

Sub-Report-15

Station	Unit No.	Capacity (MW)	Date Of Maintenance	Expected Date Of Return	Reasons/Present Status
			DD/MM/YYYY HH24:MM	DD/MM/YYYY HH24:MM	
1	2	3	4	5	6
BADARPUR TPS	4	210.00	15/10/2018 18:05		POLLUTION PROBLEM
BADARPUR TPS	5	210.00	15/10/2018 20:03		POLLUTION PROBLEM
KALISINDH TPS	1	600.00	15/10/2018 13:49		D.M. WATER PROBLEM
MAQSOODPUR TPS	2	45.00	15/10/2018 12:02	18/10/2018	COAL SHORTAGE
OP JINDAL TPS	1	250.00	15/10/2018 05:00		RESERVE SHUT DOWN / STANDBY UNIT
SURAT LIG. TPS	3	125.00	15/10/2018 15:27		GT- GENERATOR PROTECTION SYSTEM
RATNAGIRI CCPP	8	213.00	15/10/2018 22:00		Fuel Shortage
RATNAGIRI CCPP	9	237.54	15/10/2018 21:58		Fuel Shortage
KORADI TPS	6	210.00	15/10/2018 11:32		DRUM LEVEL HIGH/ low
KORADI TPS	6	210.00	15/10/2018 23:40		DRUM LEVEL LOW
TIRORA TPS	3	660.00	15/10/2018 20:29		AIR PREHEATERS PROBLEM
DAMODARAM SANJEEVAIAH TPS	1	800.00	15/10/2018 23:11	20/10/2018	COAL SHORTAGE
NORTH CHENNAI TPS	5	600.00	15/10/2018 00:43		Exhaust Gas Duct Abnormal/ Maintenance
VALANTARVY CCPP	1	38.00	15/10/2018 10:14	15/10/2018	GRID DISTURBANCE
VALANTARVY CCPP	2	14.80	15/10/2018 10:14	15/10/2018	GRID DISTURBANCE
<b>Total</b>		<b>4,423.34</b>			