

**CENTRAL ELECTRICITY AUTHORITY  
G O & D WING  
OPERATION PERFORMANCE MONITORING DIVISION**

**RECOMMISSIONING OF THERMAL/NUCLEAR UNITS AS ON: 15-10-2020**

Sub-Report - 14

| Station                         | Unit No | Capacity (MW) | Date of Maintanance | Sync Date          | remarks                             |
|---------------------------------|---------|---------------|---------------------|--------------------|-------------------------------------|
|                                 |         |               | DD/MM/YYYY HH:24MM  | DD/MM/YYYY HH:24MM |                                     |
| 1                               | 2       | 3             | 4                   | 5                  | 6                                   |
| MAHATMA GANDHI TPS              | 1       | 660.00        | 12/10/2020 09:45    | 15/10/2020 05:58   | COAL FEEDING PROBLEM IN PLANT       |
| KOTA TPS                        | 3       | 210.00        | 04/10/2020 14:24    | 15/10/2020 04:45   | Low system demand/ costly fuel      |
| LARA TPP                        | 1       | 800.00        | 04/10/2020 23:48    | 15/10/2020 01:10   | C&I PROBLEM                         |
| KORBA-WEST TPS                  | 3       | 210.00        | 14/10/2020 12:16    | 15/10/2020 04:35   | WATER WALL TUBE LEAKAGE             |
| HAZIRA CCPP                     | 1       | 52.00         | 14/10/2020 22:08    | 15/10/2020 10:44   | RSD/LOW SCHEDULE                    |
| HAZIRA CCPP                     | 2       | 52.00         | 14/10/2020 21:51    | 15/10/2020 13:17   | RSD/LOW SCHEDULE                    |
| HAZIRA CCPP                     | 3       | 52.10         | 14/10/2020 22:01    | 15/10/2020 12:27   | RSD/LOW SCHEDULE                    |
| SANJAY GANDHI TPS               | 4       | 210.00        | 13/10/2020 11:20    | 15/10/2020 12:15   | WATER WALL TUBE LEAKAGE             |
| SATPURA TPS                     | 7       | 210.00        | 12/08/2020 10:15    | 15/10/2020 00:58   | RSD/LOW SCHEDULE                    |
| NASIK TPS                       | 4       | 210.00        | 25/03/2020 19:47    | 15/10/2020 10:20   | RESERVE SHUT DOWN / STANDBY UNIT    |
| KOVIKALPAL CCPP                 | 1       | 69.65         | 10/10/2020 09:00    | 15/10/2020 09:30   | BOILER OVERHAUL/ ANNUAL MAINTENANCE |
| LAKWA REPLACEMENT POWER PROJECT | 2       | 9.96          | 14/10/2020 12:30    | 15/10/2020 00:52   | Fuel Shortage                       |
| LAKWA REPLACEMENT POWER PROJECT | 6       | 9.96          | 14/10/2020 00:00    | 15/10/2020 14:42   | Fuel Shortage                       |
| NAMRUP CCPP                     | 3       | 21.00         | 14/10/2020 07:35    | 15/10/2020 17:27   | GT- LUB OIL SYSTEM PROB.            |
| Total                           |         | 2,776.68      |                     |                    |                                     |