

**CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION**

THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 15-10-2020

Sub-Report - 15

Station	Unit No	Capacity (MW)	Date of Maintanance	Expected/Sync Date of return	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
YAMUNA NAGAR TPS	2	300.00	15/10/2020 07:18		RSD/LOW SCHEDULE
LARA TPP	2	800.00	15/10/2020 15:28		I.D. FANS PROBLEM
MAUDA TPS	2	500.00	15/10/2020 12:20	15/10/2020	CONSERVATION OF MAIN FUEL/RSD
MAUDA TPS	3	660.00	15/10/2020 10:41	15/10/2020	CONSERVATION OF MAIN FUEL/RSD
SOLAPUR	1	660.00	15/10/2020 09:49	15/10/2020	CONSERVATION OF MAIN FUEL/RSD
KAHALGAON TPS	2	210.00	15/10/2020 14:30	15/10/2020	GENERATOR PROTECTION
MAHADEV PRASAD STPP	2	270.00	15/10/2020 07:00		TURBINE MISC. PROBLEM
LAKWA REPLACEMENT POWER PROJECT	2	9.96	15/10/2020 10:34		Fuel Shortage
LAKWA REPLACEMENT POWER PROJECT	6	9.96	15/10/2020 17:00		Fuel Shortage
Total		3419.93			