

**CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION**

THERMAL/NUCLEAR UNITS OUT OF GRID EARLIER FOR MORE THAN ONE YEAR as on: 15-Oct-2025

Sub - Report 13

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
I.P.CCPP	2	30.0	1/25/19, 10:00 PM	31-03-2025	GT- LOW SYSTEM DAMAND
I.P.CCPP	3	30.0	1/25/19, 10:30 PM	31-03-2025	RESERVE SHUT DOWN / STANDBY UNIT
I.P.CCPP	4	30.0	1/25/19, 10:30 PM	31-03-2025	RESERVE SHUT DOWN / STANDBY UNIT
I.P.CCPP	8	30.0	1/25/19, 10:30 PM		RESERVE SHUT DOWN
PRAGATI CCPP	1		9/22/23, 3:05 PM		GRID DISTURBANCE
PRAGATI CCPP	1		9/4/20, 9:02 PM		GT-MISCELLANEOUS PROBLEMS
PRAGATI CCPP	1		8/1/24, 12:00 AM	07-08-2024	LOW SYSTEM DEMAND
PRAGATI CCPP	1		9/25/23, 12:00 PM		GT-STATOR/ROTOR EARTH FAULT
PRAGATI CCPP	1		9/22/23, 3:45 PM		GT-STATOR/ROTOR EARTH FAULT
PRAGATI CCPP	1	104.6	8/7/24, 12:30 PM	07-08-2024	GT-MANDATORY INSPECTION/OTHERS
PRAGATI CCPP	1		9/23/23, 4:00 PM		LOW SYSTEM DEMAND
PRAGATI CCPP	2		7/20/24, 4:26 PM	21-07-2024	LOW SYSTEM DEMAND
PRAGATI CCPP	2	104.6	9/12/23, 12:00 AM	14-09-2023	LOW SYSTEM DEMAND
PRAGATI CCPP	2		9/14/23, 2:09 PM	15-09-2023	GT - GOVERNING SYSTEM PROBLEM
PRAGATI CCPP	2		2/25/21, 6:24 PM	31-03-2021	GT- LOW SYSTEM DAMAND
PRAGATI CCPP	2		7/21/24, 4:45 PM	21-07-2024	GT-MISCELLANEOUS PROBLEMS
PRAGATI CCPP	2		9/5/22, 3:17 AM	05-09-2022	C&I PROBLEM
PRAGATI CCPP	2		3/25/21, 8:00 AM	07-04-2021	GT-MANDATORY INSPECTION/OTHERS
PRAGATI CCPP	3		10/24/23, 2:00 AM	23-01-2024	LOW SYSTEM DEMAND
PRAGATI CCPP	3	121.2	9/23/22, 5:00 PM		LOW SYSTEM DEMAND
PRAGATI CCPP	3		1/23/24, 1:15 PM	24-01-2024	MISCELLANOUS
PRAGATI CCPP	3		10/11/24, 6:01 PM	13-01-2025	Low system demand/ costly fuel
PRAGATI CCGT-III	4		6/21/18, 4:01 PM	21-06-2018	ACCIDENT/STRIKE/OTHERS
PRAGATI CCGT-III	4	250.0	10/9/23, 12:25 AM		Test
PRAGATI CCGT-III	4		10/10/23, 7:48 AM		TESTING OF FIRE FIGHTING SYS.
PRAGATI CCGT-III	4		6/21/18, 4:10 PM	10-10-2023	MISCELLANOUS
RITHALA CCPP	1	0.0	3/19/13, 5:32 PM	05-10-2018	GT-MISCELLANEOUS PROBLEMS
RITHALA CCPP	2	0.0	6/7/13, 10:42 PM	13-06-2018	GT-NO SCHEDULE FROM
RITHALA CCPP	3	0.0	6/7/13, 10:38 PM	31-05-2018	GT-NO SCHEDULE FROM

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
INDIRA GANDHI STPP	1		8/28/21, 12:00 AM		Fuel Shortage
INDIRA GANDHI STPP	1	500.0	10/22/22, 11:10 PM		RESERVE SHUT DOWN
INDIRA GANDHI STPP	2	500.0	11/7/20, 9:35 PM		RESERVE SHUT DOWN / STANDBY UNIT
INDIRA GANDHI STPP	2		8/12/20, 5:39 PM		RSD/LOW SCHEDULE
INDIRA GANDHI STPP	3		3/25/23, 5:07 AM		BOILER AUX. MISC. PROMLEMS
INDIRA GANDHI STPP	3	500.0	10/13/21, 8:47 PM		TUBE LKG. AT LOW TEMP.
FARIDABAD CCPP	1	137.76	11/12/18, 2:59 PM		GT- LOW SYSTEM DAMAND
FARIDABAD CCPP	1		2/2/19, 12:00 AM		BOILER OVERHAUL/ ANNUAL
FARIDABAD CCPP	2	137.76	6/24/24, 9:29 PM	30-08-2024	NO/REDUCED IRRIGATION DEMAND
FARIDABAD CCPP	3	156.07	7/29/24, 12:00 PM	01-08-2024	NO/REDUCED IRRIGATION DEMAND
FARIDABAD CCPP	3		1/31/19, 11:55 PM		BOILER OVERHAUL/ ANNUAL
FARIDABAD CCPP	3		6/28/24, 1:16 AM	30-07-2024	CONSERVATION OF MAIN FUEL/RSD
FARIDABAD CCPP	3		8/1/24, 12:00 PM	02-08-2024	CONSERVATION OF MAIN FUEL/RSD
PAMPORE GPS (Liq.)	1	0.0	2/1/12, 12:01 AM		GT- UNECONOMIC OPERATION
PAMPORE GPS (Liq.)	2	0.0	2/1/12, 12:01 AM		GT- UNECONOMIC OPERATION
PAMPORE GPS (Liq.)	3	0.0	2/1/12, 12:01 AM		GT- UNECONOMIC OPERATION
PAMPORE GPS (Liq.)	4	0.0	2/1/12, 12:01 AM		GT- UNECONOMIC OPERATION
PAMPORE GPS (Liq.)	5	0.0	2/1/12, 12:01 AM		GT- UNECONOMIC OPERATION
PAMPORE GPS (Liq.)	6	0.0	2/1/12, 12:01 AM		GT- UNECONOMIC OPERATION
PAMPORE GPS (Liq.)	7	0.0	2/1/12, 12:01 AM		GT- UNECONOMIC OPERATION
ROPAR TPS	3		2/29/24, 12:20 PM	02-03-2024	BOILER MISC. PROBLEM
ROPAR TPS	3		1/10/23, 7:00 PM		RSD/LOW SCHEDULE
ROPAR TPS	3		10/1/21, 9:40 AM		STATOR EARTH FAULT
ROPAR TPS	3		11/10/23, 10:55 PM		LOW SYSTEM DEMAND
ROPAR TPS	3		8/29/21, 10:55 AM		RSD/LOW SCHEDULE
ROPAR TPS	3		7/7/21, 11:35 PM		VARIOUS STEAM LEAKAGES
ROPAR TPS	3		7/8/20, 8:05 PM		UNIT AUX. TRANSFORMER PROBLEM
ROPAR TPS	3		8/19/20, 11:40 AM		P.A. FANS PROBLEM
ROPAR TPS	3		2/25/22, 2:27 PM		REHEATER TUBE LEAKAGE
ROPAR TPS	3		7/28/23, 7:10 PM		FURNACE FIRE OUT /FLAME FAILURE
ROPAR TPS	3		10/7/21, 2:30 PM		COAL SHORTAGE

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
ROPAR TPS	3		7/8/23, 1:05 PM		RESERVE SHUT DOWN
ROPAR TPS	3		5/12/22, 1:00 PM		ASH HANDLING SYSTEM PROBLEM
ROPAR TPS	3		8/27/21, 8:10 PM		REHEATER TUBE LEAKAGE
ROPAR TPS	3		7/28/22, 4:45 PM		P.A. FANS PROBLEM
ROPAR TPS	3	210.0	6/13/22, 12:18 PM		LINE BREAKER FAULT
ROPAR TPS	4		5/19/23, 6:33 AM		AIR PREHEATERS PROBLEM
ROPAR TPS	4		5/19/23, 9:00 PM		LOW SYSTEM DEMAND
ROPAR TPS	4		10/8/21, 3:20 PM		AIR PREHEATERS PROBLEM
ROPAR TPS	4		10/24/23, 7:07 AM		BOILER FEED PUMP/MOTOR PROBLEM
ROPAR TPS	4		5/20/23, 6:35 AM	21-05-2023	STATOR EARTH FAULT
ROPAR TPS	4		9/27/19, 7:55 AM		RSD/LOW SCHEDULE
ROPAR TPS	4		2/1/23, 6:05 PM		RSD/LOW SCHEDULE
ROPAR TPS	4		1/27/23, 10:44 PM		MILLING SYSTEM /RC FEEDER
ROPAR TPS	4		9/28/24, 6:40 AM		DC SUPPLY PROBLEM
ROPAR TPS	4		10/9/22, 1:50 PM		GENERATOR EARTH FAULT
ROPAR TPS	4		9/15/23, 12:07 PM		BOILER MISC. PROBLEM
ROPAR TPS	4		5/16/23, 7:30 AM		STATOR EARTH FAULT
ROPAR TPS	4		7/20/20, 8:30 AM		RSD/LOW SCHEDULE
ROPAR TPS	4		3/25/23, 9:30 AM	28-03-2023	LOW SYSTEM DEMAND
ROPAR TPS	4	210.0	10/17/23, 5:33 PM		WATER WALL TUBE LEAKAGE
ROPAR TPS	4		5/18/23, 8:00 AM		LOW SYSTEM DEMAND
ROPAR TPS	4		2/26/20, 12:00 AM		SCHEDULED ANNUAL MAINTENANCE
ROPAR TPS	4		7/8/23, 11:42 AM		RESERVE SHUT DOWN
ROPAR TPS	5		5/24/23, 8:27 AM		FURNACE FIRE OUT /FLAME FAILURE
ROPAR TPS	5		10/3/22, 3:24 AM		WATER WALL TUBE LEAKAGE
ROPAR TPS	5		7/29/20, 11:15 PM		RSD/LOW SCHEDULE
ROPAR TPS	5		9/8/22, 3:45 PM		WATER WALL TUBE LEAKAGE
ROPAR TPS	5		6/15/22, 1:53 AM		REHEATER TUBE LEAKAGE
ROPAR TPS	5		9/23/20, 7:55 AM		REHEATER TUBE LEAKAGE
ROPAR TPS	5		7/23/23, 5:15 AM		AIR PREHEATERS PROBLEM
ROPAR TPS	5		10/16/21, 12:50 AM		COAL SHORTAGE

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
ROPAR TPS	5		4/1/21, 12:00 AM		CAPITAL MAINTENANCE
ROPAR TPS	5		9/12/22, 7:42 AM		MILLING SYSTEM /RC FEEDER
ROPAR TPS	5		3/10/22, 12:00 AM		SCHEDULED ANNUAL MAINTENANCE
ROPAR TPS	5		11/11/20, 9:20 PM		RSD/LOW SCHEDULE
ROPAR TPS	5		12/16/21, 12:00 AM		RSD/LOW SCHEDULE
ROPAR TPS	5	210.0	8/10/20, 9:30 AM		TURBINE BEARING PROBLEM
ROPAR TPS	6		9/28/24, 2:00 PM		REHEATER TUBE LEAKAGE
ROPAR TPS	6	210.0	8/3/22, 5:01 AM		AIR PREHEATERS PROBLEM
ROPAR TPS	6		6/13/22, 1:08 AM		P.A. FANS PROBLEM
ROPAR TPS	6		3/2/22, 11:45 PM		REHEATER TUBE LEAKAGE
ROPAR TPS	6		11/4/20, 3:30 PM		WATER WALL TUBE LEAKAGE
ROPAR TPS	6		10/10/19, 12:00 AM		SCHEDULED ANNUAL MAINTENANCE
ROPAR TPS	6		9/3/21, 11:20 AM		RSD/LOW SCHEDULE
ROPAR TPS	6		8/19/22, 6:10 PM		WATER WALL TUBE LEAKAGE
ROPAR TPS	6		3/5/22, 11:30 AM		RSD/LOW SCHEDULE
ROPAR TPS	6		5/22/22, 10:07 PM		AIR PREHEATERS PROBLEM
ROPAR TPS	6		2/20/22, 11:45 PM		BOILER MISC. PROBLEM
ROPAR TPS	6		3/14/22, 11:00 AM		AIR PREHEATERS PROBLEM
ROPAR TPS	6		7/21/22, 1:12 PM		GENERATOR EARTH FAULT
TALWANDI SABO TPP	1		5/20/21, 11:43 AM		C&I PROBLEM
TALWANDI SABO TPP	1	660.0	7/4/21, 1:16 AM		BOILER MISC. PROBLEM
TALWANDI SABO TPP	1		12/3/20, 9:30 PM		ELECTRICAL MISCELLANEOUS
TALWANDI SABO TPP	2	660.0	5/8/20, 7:30 AM		TURBINE CONTROL VALVE PROBLEM
TALWANDI SABO TPP	3		3/2/21, 2:59 PM		TURBINE VIBRATIONS HIGH
TALWANDI SABO TPP	3	660.0	2/27/21, 7:43 PM		BOILER MISC. PROBLEM
DAE (RAJASTHAN)	1	0.0	10/9/04, 10:58 PM		GENERATOR EARTH FAULT
RAJASTHAN A.P.S.	2	200.0	4/12/22, 4:10 AM		MISCELLANOUS
RAJASTHAN A.P.S.	5	220.0	4/12/24, 4:25 PM	27-04-2024	REACTOR MAINTENANCE WORKS.
SURATGARH TPS	2	250.0	7/29/23, 9:18 AM		RSD/LOW SCHEDULE
SURATGARH TPS	3	250.0	4/22/23, 6:19 AM		ECONOMISER TUBE LEAKAGE
SURATGARH TPS	6	250.0	5/22/23, 1:34 AM		MISC. SHORT DURATION

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
SURATGARH TPS	6		10/11/24, 1:00 AM		MILLING SYSTEM /RC FEEDER
SURATGARH STPS	7	660.0	9/15/23, 6:00 PM	17-09-2023	BOILER MISC. PROBLEM
SURATGARH STPS	8	660.0	11/27/23, 1:45 AM		BOILER MISC. PROBLEM
GIRAL TPS	1	125.0	7/11/14, 8:20 AM	03-06-2018	UNIT LIKELY TO BE SCRAPPED.
GIRAL TPS	2	125.0	1/27/16, 3:27 PM	12-07-2018	UNIT LIKELY TO BE SCRAPPED.
RAMGARH CCPP	4	37.5	7/27/22, 11:48 PM		MISCELLANEOUS
RAMGARH CCPP	6	50.0	9/25/23, 10:00 AM		FUEL SUPPLY & OTHER MISC.
DHOLPUR CCPP	3	110.0	7/31/24, 10:29 PM		RSD/LOW SCHEDULE
ANTA CCPP	1		9/21/24, 9:03 PM	22-09-2024	NO/REDUCED IRRIGATION DEMAND
ANTA CCPP	1	88.71	9/22/24, 6:00 PM	09-10-2024	NO/REDUCED IRRIGATION DEMAND
ANTA CCPP	2	88.71	6/25/22, 11:15 PM		RSD/LOW SCHEDULE
ANTA CCPP	2		5/13/24, 8:15 PM	16-05-2024	VARIOUS STEAM LEAKAGES
ANTA CCPP	2		5/10/24, 7:02 PM	13-05-2024	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	3	88.71	8/26/24, 6:30 PM	27-08-2024	NO/REDUCED IRRIGATION DEMAND
ANTA CCPP	3		6/25/24, 12:58 AM	25-06-2024	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	3		6/26/24, 1:00 PM	30-06-2024	GT-BLEED VALVE MALFUNCTIONING
ANTA CCPP	3		8/25/24, 6:30 PM	26-08-2024	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	3		8/15/24, 4:30 AM	16-08-2024	NO/REDUCED IRRIGATION DEMAND
ANTA CCPP	3		8/24/24, 3:50 PM	26-08-2024	NO/REDUCED IRRIGATION DEMAND
ANTA CCPP	3		8/5/24, 10:44 PM	08-08-2024	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	3		4/28/24, 12:30 AM	28-04-2024	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	4	153.2	11/25/19, 9:24 AM		RSD/LOW SCHEDULE
OBRA TPS	10	200.0	1/29/23, 9:00 PM		TURBINE MISC. PROBLEMS
PARICHHA TPS	3	210.0	7/30/21, 6:00 PM		WATER WALL TUBE LEAKAGE
LALITPUR TPS	1		11/14/21, 11:59 PM		ANNUAL MAINTENANCE
LALITPUR TPS	1	660.0	11/4/21, 8:40 PM	14-11-2021	RESERVE SHUT DOWN / STANDBY UNIT
LALITPUR TPS	2	660.0	10/16/21, 8:00 PM		BOILER AUX. MISC. PROMLEMS
SINGRAULI STPS	4	200.0	1/14/22, 8:55 AM	15-01-2022	WATER WALL TUBE LEAKAGE
MEJA STPP	2	660.0	1/25/23, 8:21 AM	26-01-2023	ELECTRICAL MISCELLANEOUS
DADRI (NCTPP)	1	210.0	3/3/24, 12:05 AM	30-03-2024	MISCELLANEOUS
TANDA TPS	1	110.0	9/27/24, 11:00 AM	30-09-2024	NO/REDUCED IRRIGATION DEMAND

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
TANDA TPS	2	110.0	9/27/24, 11:17 AM	30-09-2024	RSD/LOW SCHEDULE
TANDA TPS	3	110.0	9/27/24, 11:28 AM	30-09-2024	RSD/LOW SCHEDULE
TANDA TPS	4	110.0	9/12/24, 11:16 AM	14-09-2024	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	1	111.19	8/9/24, 10:52 PM	12-08-2024	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	2	111.19	5/11/24, 11:48 AM	13-05-2024	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	4	111.19	6/6/24, 1:03 AM	07-06-2024	NO/REDUCED IRRIGATION DEMAND
AURAIYA CCPP	5	109.3	12/16/23, 12:00 PM	17-02-2024	NO/REDUCED IRRIGATION DEMAND
AURAIYA CCPP	5		6/28/24, 12:30 AM	12-08-2024	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	6	109.3	6/28/24, 12:39 AM	28-07-2024	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	6		10/16/23, 11:32 PM	17-02-2024	NO/REDUCED IRRIGATION DEMAND
DADRI CCPP	1	130.19	2/23/24, 9:39 AM	23-02-2024	BOILER AUX. MISC. PROMLEMS
DADRI CCPP	3	130.19	2/14/24, 9:29 AM	19-02-2024	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	4	130.19	6/19/24, 1:49 AM	19-06-2024	NO/REDUCED IRRIGATION DEMAND
DADRI CCPP	4		8/25/24, 12:00 AM	26-08-2024	NO/REDUCED IRRIGATION DEMAND
DADRI CCPP	5		7/21/24, 2:00 PM	22-07-2024	NO/REDUCED IRRIGATION DEMAND
DADRI CCPP	5		7/23/24, 10:06 AM	26-07-2024	GT-1ST STAGE PR PROBLEM
DADRI CCPP	5		7/30/24, 10:06 AM	31-07-2024	NO/REDUCED IRRIGATION DEMAND
DADRI CCPP	5		8/11/24, 2:00 PM	12-08-2024	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	5		8/8/24, 10:06 AM	11-08-2024	NO/REDUCED IRRIGATION DEMAND
DADRI CCPP	5		7/22/24, 10:06 AM	23-07-2024	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	5		7/26/24, 2:00 PM	26-07-2024	NO/REDUCED IRRIGATION DEMAND
DADRI CCPP	5		7/15/24, 10:00 AM	16-07-2024	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	5		7/16/24, 10:06 AM	17-07-2024	VIBRATIONS
DADRI CCPP	5		8/12/24, 10:00 AM	13-08-2024	NO/REDUCED IRRIGATION DEMAND
DADRI CCPP	5		8/7/24, 10:06 AM	08-08-2024	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	5		7/7/24, 10:06 AM	10-07-2024	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	5		7/2/24, 2:30 PM	03-07-2024	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	5		7/17/24, 10:06 AM	18-07-2024	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	5		8/3/24, 2:00 PM	04-08-2024	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	5		8/4/24, 2:00 PM	05-08-2024	NO/REDUCED IRRIGATION DEMAND
DADRI CCPP	5		8/6/24, 10:00 AM	07-08-2024	NO/REDUCED IRRIGATION DEMAND

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
DADRI CCPP	5		7/29/24, 10:00 AM	30-07-2024	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	5		7/6/24, 10:05 AM	07-07-2024	NO/REDUCED IRRIGATION DEMAND
DADRI CCPP	5		7/3/24, 2:00 PM	14-07-2024	NO/REDUCED IRRIGATION DEMAND
DADRI CCPP	5		7/13/24, 10:00 AM	14-07-2024	VIBRATIONS
DADRI CCPP	5		7/28/24, 10:00 AM	29-07-2024	NO/REDUCED IRRIGATION DEMAND
DADRI CCPP	5		8/15/24, 10:05 AM	16-08-2024	NO/REDUCED IRRIGATION DEMAND
DADRI CCPP	5		8/5/24, 2:00 PM	06-08-2024	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	5		7/27/24, 2:00 PM	28-07-2024	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	5		7/31/24, 10:06 AM	03-08-2024	GT HIGH VIBRATIONS
DADRI CCPP	5		7/10/24, 2:00 PM	11-07-2024	NO/REDUCED IRRIGATION DEMAND
DADRI CCPP	5		8/13/24, 2:00 PM	14-08-2024	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	5		7/12/24, 10:00 AM	12-07-2024	NO/REDUCED IRRIGATION DEMAND
DADRI CCPP	5		7/20/24, 10:00 AM	21-07-2024	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	5		8/16/24, 10:06 AM	19-08-2024	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	5		7/19/24, 12:00 AM	19-07-2024	NO/REDUCED IRRIGATION DEMAND
DADRI CCPP	5		7/11/24, 10:00 AM	12-07-2024	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	5	154.51	8/19/24, 2:00 PM	20-08-2024	NO/REDUCED IRRIGATION DEMAND
MAQSOODPUR TPS	1		3/29/23, 1:00 PM		REACTOR MAINTENANCE WORKS.
MAQSOODPUR TPS	1	45.0	1/2/20, 9:20 PM		COAL SHORTAGE
MAQSOODPUR TPS	1		10/5/22, 12:16 PM		RSD/LOW SCHEDULE
MAQSOODPUR TPS	1		2/22/19, 12:00 AM		RESCHEDULED ANNUAL MAINTENANCE
MAQSOODPUR TPS	1		10/8/19, 11:01 PM		MAIN STEAM LINE PROBLEM
MAQSOODPUR TPS	1		2/5/21, 4:18 PM		TURBINE CONTROL VALVE PROBLEM
MAQSOODPUR TPS	1		6/23/22, 11:58 PM		COAL SHORTAGE
MAQSOODPUR TPS	1		3/20/23, 12:30 PM		RSD/LOW SCHEDULE
MAQSOODPUR TPS	1		10/3/21, 12:00 AM		COAL SHORTAGE
MAQSOODPUR TPS	1		11/13/23, 1:00 AM		RSD/LOW SCHEDULE
MAQSOODPUR TPS	2		1/2/20, 9:20 PM		COAL SHORTAGE
MAQSOODPUR TPS	2		10/8/19, 11:01 PM		MAIN STEAM LINE PROBLEM
MAQSOODPUR TPS	2	45.0	2/22/19, 12:00 AM		RESCHEDULED ANNUAL MAINTENANCE
MAQSOODPUR TPS	2		3/29/23, 1:00 PM		REACTOR MAINTENANCE WORKS.

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
MAQSOODPUR TPS	2		1/27/22, 9:14 PM		RSD/LOW SCHEDULE
MAQSOODPUR TPS	2		3/20/23, 12:30 PM		RSD/LOW SCHEDULE
MAQSOODPUR TPS	2		2/8/21, 1:16 PM		RSD/LOW SCHEDULE
KHAMBARKHERA TPS	1		3/30/23, 12:00 AM		REACTOR MAINTENANCE WORKS.
KHAMBARKHERA TPS	1	45.0	3/2/24, 1:10 PM		RSD/LOW SCHEDULE
KHAMBARKHERA TPS	1		10/10/21, 7:30 AM		COAL SHORTAGE
KHAMBARKHERA TPS	1		3/12/23, 2:00 PM		RSD/LOW SCHEDULE
KHAMBARKHERA TPS	1		1/27/22, 9:01 PM		RSD/LOW SCHEDULE
KHAMBARKHERA TPS	2	45.0	10/10/21, 7:04 AM		COAL SHORTAGE
KHAMBARKHERA TPS	2		1/10/24, 11:03 AM		ANNUAL MAINTENANCE
KHAMBARKHERA TPS	2		6/26/22, 4:58 PM		COAL SHORTAGE
KHAMBARKHERA TPS	2		3/30/23, 12:00 AM		REACTOR MAINTENANCE WORKS.
KHAMBARKHERA TPS	2		3/12/23, 1:30 PM		RSD/LOW SCHEDULE
BARKHERA TPS	1	45.0	10/12/21, 9:58 AM		COAL SHORTAGE
BARKHERA TPS	2		1/27/22, 9:15 PM		RSD/LOW SCHEDULE
BARKHERA TPS	2		3/31/23, 12:00 PM		RSD/LOW SCHEDULE
BARKHERA TPS	2		3/20/23, 12:28 PM		RSD/LOW SCHEDULE
BARKHERA TPS	2	45.0	3/24/23, 12:00 AM		ANNUAL MAINTENANCE
BARKHERA TPS	2		1/26/23, 8:40 PM		RSD/LOW SCHEDULE
BARKHERA TPS	2		10/12/21, 9:58 AM		COAL SHORTAGE
KUNDARKI TPS	1	45.0	9/2/22, 9:55 AM		COAL SHORTAGE
KUNDARKI TPS	1		3/20/23, 12:31 PM		RSD/LOW SCHEDULE
KUNDARKI TPS	1		3/28/23, 12:45 PM		REACTOR MAINTENANCE WORKS.
KUNDARKI TPS	1		1/27/22, 9:12 PM		RSD/LOW SCHEDULE
KUNDARKI TPS	1		10/14/23, 12:00 AM		COAL SHORTAGE
KUNDARKI TPS	2		9/23/21, 7:00 PM		COAL SHORTAGE
KUNDARKI TPS	2	45.0	3/20/23, 12:31 PM		RSD/LOW SCHEDULE
KUNDARKI TPS	2		1/27/22, 9:12 PM		RSD/LOW SCHEDULE
KUNDARKI TPS	2		3/28/23, 1:30 AM		REACTOR MAINTENANCE WORKS.
UTRAULA TPS	1		3/20/23, 12:30 PM		RSD/LOW SCHEDULE
UTRAULA TPS	1		8/29/22, 9:16 PM		COAL SHORTAGE

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
UTRAULA TPS	1		1/27/22, 9:10 PM		RSD/LOW SCHEDULE
UTRAULA TPS	1		3/20/23, 1:15 PM		ANNUAL MAINTENANCE
UTRAULA TPS	1	45.0	7/8/23, 11:00 AM		RSD/LOW SCHEDULE
UTRAULA TPS	1		11/15/23, 10:27 PM		RSD/LOW SCHEDULE
UTRAULA TPS	2		1/27/22, 8:46 PM		RSD/LOW SCHEDULE
UTRAULA TPS	2	45.0	3/20/23, 12:20 PM		RSD/LOW SCHEDULE
UTRAULA TPS	2		12/10/23, 6:20 PM		RSD/LOW SCHEDULE
UTRAULA TPS	2		3/20/23, 1:15 PM		ANNUAL MAINTENANCE
UTRAULA TPS	2		11/15/23, 10:42 PM		RESERVE SHUT DOWN
UTRAULA TPS	2		12/10/23, 8:00 AM		INSPECTION /MTCE
UKAI TPS	4	200.0	1/27/23, 7:41 PM	31-01-2023	WATER WALL TUBE LEAKAGE
GANDHI NAGAR TPS	3		10/1/24, 3:45 AM		ELECTRICAL FAULT
GANDHI NAGAR TPS	3	210.0	6/29/24, 8:25 AM		COAL FEEDING PROBLEM IN PLANT
UTRAN CCPP	5		10/10/24, 7:13 PM	16-10-2024	RESERVE SHUT DOWN / STANDBY UNIT
UTRAN CCPP	5	240.0	11/3/18, 12:17 AM	05-11-2018	RESERVE SHUT DOWN / STANDBY UNIT
UTRAN CCPP	5		9/5/24, 12:00 AM	05-09-2024	RESERVE SHUT DOWN/ STANDBY.
UTRAN CCPP	6	134.0	10/10/24, 7:10 PM		RESERVE SHUT DOWN / STANDBY UNIT
HAZIRA CCPP	1		4/7/22, 6:06 AM		Low system demand/ costly fuel
HAZIRA CCPP	1		3/23/22, 8:15 PM		Fuel Shortage
HAZIRA CCPP	1		10/1/19, 9:27 PM		GT- LOW SYSTEM DAMAND
HAZIRA CCPP	1		6/1/22, 12:00 AM		NO Power purchase agreement
HAZIRA CCPP	1	0.0	9/8/21, 12:00 AM		Low system demand/ costly fuel
HAZIRA CCPP	2		11/9/20, 2:31 PM	14-11-2020	GT HIGH VIBRATIONS
HAZIRA CCPP	2		3/27/21, 12:53 AM		RSD/LOW SCHEDULE
HAZIRA CCPP	2		4/7/22, 6:07 AM		Low system demand/ costly fuel
HAZIRA CCPP	2		6/1/22, 12:00 AM		NO Power purchase agreement
HAZIRA CCPP	2	0.0	9/7/21, 7:00 PM		LOW SYSTEM DEMAND
HAZIRA CCPP	2		3/23/22, 8:15 PM		Fuel Shortage
HAZIRA CCPP	3	0.0	6/1/22, 12:00 AM		NO Power purchase agreement
HAZIRA CCPP	3		3/23/22, 8:15 PM		Fuel Shortage
HAZIRA CCPP	3		4/7/22, 6:08 AM		Low system demand/ costly fuel

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
HAZIRA CCPP	3		8/31/21, 12:00 AM		Low system demand/ costly fuel
HAZIRA CCPP EXT	1		2/14/22, 12:00 AM		MISCELLANEOUS PLANNED
HAZIRA CCPP EXT	1	351.0	12/23/22, 7:37 PM		GENEATOR PROTECTION MISC/BACK
HAZIRA CCPP EXT	1		4/7/22, 6:09 AM		Low system demand/ costly fuel
HAZIRA CCPP EXT	1		3/23/22, 8:15 PM		Fuel Shortage
HAZIRA CCPP EXT	1		2/23/22, 9:00 PM		Low system demand/ costly fuel
HAZIRA CCPP EXT	1		2/17/23, 9:00 PM	21-03-2024	TURBINE VIBRATIONS HIGH
HAZIRA CCPP EXT	1		10/26/21, 7:15 PM		Low system demand/ costly fuel
HAZIRA CCPP EXT	1		5/2/22, 12:00 AM		BOILER INSPECTION/ RE-
HAZIRA CCPP EXT	1		5/2/21, 12:00 AM		BOILER OVERHAUL/ ANNUAL
DHUVARAN CCPP	1		5/5/22, 12:00 AM	01-06-2022	Other Commercial Reason
DHUVARAN CCPP	1		9/25/18, 12:00 AM		BEARING
DHUVARAN CCPP	1	67.85	9/5/24, 5:17 PM		NO Power purchase agreement
DHUVARAN CCPP	2		9/25/18, 12:00 AM		RSD/LOW SCHEDULE
DHUVARAN CCPP	2	38.77	5/5/22, 12:00 AM	01-06-2022	NO Power purchase agreement
DHUVARAN CCPP	4	40.0	6/17/23, 12:00 AM		BOILER AUX. MISC. PROMLEMS
DHUVARAN CCPP	5	376.1	5/5/22, 12:00 AM	01-06-2022	EXTENDED ANNUAL MAINTENANCE
DHUVARAN CCPP	5		9/24/24, 11:00 PM		RESERVE SHUT DOWN
DHUVARAN CCPP	5		3/30/23, 12:00 AM		RESERVE SHUT DOWN/ STANDBY.
WANAKBORI TPS	1		9/12/21, 10:00 PM		RESERVE SHUT DOWN
WANAKBORI TPS	1	210.0	12/26/20, 6:23 PM		MAIN STEAM LINE PROBLEM
WANAKBORI TPS	2		11/6/20, 11:58 AM		TURBINE OIL SYSTEM PROBLEM
WANAKBORI TPS	2	210.0	11/6/20, 11:59 PM		TURBINE MISC.
WANAKBORI TPS	3	210.0	7/4/24, 4:23 PM	06-07-2024	ASH HANDLING SYSTEM PROBLEM
WANAKBORI TPS	5		11/25/20, 3:27 PM		FUEL SUPPLY & OTHER MISC.
WANAKBORI TPS	5	210.0	1/7/21, 12:36 PM		TURBINE BEARING PROBLEM
WANAKBORI TPS	6	210.0	2/20/21, 8:15 AM		RESERVE SHUT DOWN / STANDBY UNIT
WANAKBORI TPS	7		12/30/20, 12:45 PM		BOILER MISC. PROBLEM
WANAKBORI TPS	7	210.0	7/20/21, 1:41 PM		RESERVE SHUT DOWN
WANAKBORI TPS	8	800.0	5/27/20, 3:05 PM		MAL-FUNCTION OF RELAY
SIKKA REP. TPS	3		6/26/20, 3:50 PM	06-07-2020	ELECTRICAL MISCELLANEOUS

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
SIKKA REP. TPS	3	250.0	7/6/20, 8:00 AM	20-07-2020	RSD/LOW SCHEDULE
SIKKA REP. TPS	4	250.0	1/23/23, 12:00 AM	31-01-2023	TUBE LKG. AT LOW TEMP.
SIKKA REP. TPS	4		2/3/21, 8:18 AM	06-02-2021	SUPER HEATER TUBE LEAKAGE
PIPAVAV CCPP	2	351.0	4/19/24, 1:10 AM		RSD/LOW SCHEDULE
KUTCH LIG. TPS	4	75.0	7/5/23, 7:05 AM		COOLING TOWER PROBLEM
AKRIMOTA LIG TPS	1	125.0	6/8/24, 7:30 PM		CAPITAL MAINTENANCE
SUGEN CCPP	1		5/26/22, 7:00 PM	30-05-2022	MAIN STEAM LINE PROBLEM
SUGEN CCPP	1		1/11/21, 12:00 AM	19-01-2021	RSD/LOW SCHEDULE
SUGEN CCPP	1	382.5	11/26/22, 11:53 PM		RSD/LOW SCHEDULE
SUGEN CCPP	1		1/7/22, 7:45 PM		RSD/LOW SCHEDULE
SUGEN CCPP	1		5/25/22, 1:50 AM	31-05-2022	RSD/LOW SCHEDULE
SUGEN CCPP	1		2/5/20, 6:01 PM	16-02-2020	RESERVE SHUT DOWN / STANDBY UNIT
SUGEN CCPP	1		1/18/21, 6:00 AM	24-01-2021	GT-MANDATORY INSPECTION/OTHERS
SUGEN CCPP	2		1/22/21, 11:38 PM	08-02-2021	RSD/LOW SCHEDULE
SUGEN CCPP	2		1/17/20, 7:30 PM	26-01-2020	RESERVE SHUT DOWN / STANDBY UNIT
SUGEN CCPP	2		1/31/19, 3:03 PM		RESERVE SHUT DOWN / STANDBY UNIT
SUGEN CCPP	2	382.5	11/2/21, 12:00 AM		RSD/LOW SCHEDULE
SUGEN CCPP	2		1/26/20, 12:00 AM	29-01-2020	GT-MANDATORY INSPECTION/OTHERS
SUGEN CCPP	3		8/2/19, 12:00 AM		RESERVE SHUT DOWN / STANDBY UNIT
SUGEN CCPP	3		2/19/22, 7:30 PM	22-02-2022	MAIN STEAM LINE PROBLEM
SUGEN CCPP	3	382.5	1/4/21, 6:00 AM	10-01-2021	GT-MANDATORY INSPECTION/OTHERS
SUGEN CCPP	3		3/3/23, 12:00 AM		RSD/LOW SCHEDULE
SUGEN CCPP	3		11/20/22, 12:00 AM	26-11-2022	RESERVE SHUT DOWN / STANDBY UNIT
SUGEN CCPP	3		3/10/23, 8:30 PM	13-03-2023	GENERATOR BEARING PROBLEM
SUGEN CCPP	3		1/5/22, 3:47 PM		RSD/LOW SCHEDULE
SUGEN CCPP	3		1/5/20, 12:00 AM	09-01-2020	GT-MANDATORY INSPECTION/OTHERS
SUGEN CCPP	3		12/16/20, 7:38 PM	05-01-2021	RESERVE SHUT DOWN / STANDBY UNIT
SUGEN CCPP	3		12/28/19, 12:00 AM	05-01-2020	Low system demand/ costly fuel
SUGEN CCPP	3		2/17/22, 11:30 AM	19-02-2022	MAIN STEAM LINE PROBLEM
SUGEN CCPP	3		8/11/19, 9:00 AM	11-08-2019	GT- GAS FLAME OFF/ DISTURBED
SUGEN CCPP	3		2/18/22, 6:15 PM	26-02-2022	RESERVE SHUT DOWN / STANDBY UNIT

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
UNOSUGEN CCPP	1	382.5	12/31/22, 9:38 PM		RSD/LOW SCHEDULE
UNOSUGEN CCPP	1		10/24/23, 12:58 AM	14-11-2023	RSD/LOW SCHEDULE
UNOSUGEN CCPP	1		11/19/20, 12:00 AM	21-11-2020	GT-MANDATORY INSPECTION/OTHERS
UNOSUGEN CCPP	1		11/16/23, 12:00 AM	21-11-2023	ANNUAL MAINTENANCE
UNOSUGEN CCPP	1		10/30/21, 11:58 PM	01-11-2021	RSD/LOW SCHEDULE
DGEN MEGA CCPP	1		6/20/23, 12:00 AM		GT-NO SCHEDULE FROM
DGEN MEGA CCPP	1	400.0	7/17/23, 11:00 AM		GT-MISCELLANEOUS PROBLEMS
DGEN MEGA CCPP	1		10/20/23, 12:00 AM		GT-NO SCHEDULE FROM
DGEN MEGA CCPP	2	400.0	10/15/23, 1:19 AM		GT-NO SCHEDULE FROM
DGEN MEGA CCPP	2		8/12/20, 12:26 AM	16-08-2020	RESERVE SHUT DOWN
DGEN MEGA CCPP	2		6/11/23, 12:00 AM		GT-NO SCHEDULE FROM
DGEN MEGA CCPP	2		7/13/23, 9:54 AM		SWITH YARD RELATED PROBLEMS
DGEN MEGA CCPP	2		11/5/21, 12:00 AM		GT-NO SCHEDULE FROM
DGEN MEGA CCPP	3	400.0	4/21/23, 1:11 AM		GT-NO SCHEDULE FROM
ESSAR CCPP	1	110.0	2/1/15, 12:03 PM	31-03-2023	NO Power purchase agreement
ESSAR CCPP	2	110.0	8/17/15, 12:00 AM	31-03-2023	NO Power purchase agreement
ESSAR CCPP	3	185.0	8/17/15, 12:00 AM	31-03-2023	NO Power purchase agreement
ESSAR CCPP	4	110.0	8/17/15, 12:00 AM	31-03-2023	NO Power purchase agreement
SABARMATI (D-F STATIONS)	1		3/29/21, 2:45 PM		TURBINE CONTROL VALVE PROBLEM
SABARMATI (D-F STATIONS)	1		1/18/21, 10:57 PM	19-01-2021	RESERVE SHUT DOWN / STANDBY UNIT
SABARMATI (D-F STATIONS)	1	120.0	11/20/20, 11:58 PM		RSD/LOW SCHEDULE
SABARMATI (D-F STATIONS)	2	121.0	7/13/24, 8:21 PM		GENERATOR
GIPCL. GT IMP	1	0.0	1/14/22, 12:00 AM	28-02-2022	FUEL SUPPLY & OTHER MISC.
GIPCL. GT IMP	2	0.0	1/14/22, 12:00 AM	30-06-2022	FUEL SUPPLY & OTHER MISC.
GIPCL. GT IMP	3	0.0	1/14/22, 12:19 PM	30-06-2022	FUEL SUPPLY & OTHER MISC.
GIPCL. GT IMP	3		1/14/22, 12:00 AM	28-02-2022	FUEL SUPPLY & OTHER MISC.
GIPCL. GT IMP	4	0.0	1/14/22, 12:00 AM	30-06-2022	FUEL SUPPLY & OTHER MISC.
BARODA CCPP	5	0.0	7/23/16, 10:40 PM	31-05-2023	FUEL SUPPLY & OTHER MISC.
BARODA CCPP	6	0.0	6/21/16, 6:56 PM	28-02-2023	FUEL SUPPLY & OTHER MISC.
ADANI POWER LIMITED	1	330.0	7/16/22, 12:00 AM		OVERHAULING WORKS
ADANI POWER LIMITED	1		8/26/21, 7:24 AM		TURBINE MISC. PROBLEM

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
ADANI POWER LIMITED	1		5/12/22, 2:59 PM		RSD/LOW SCHEDULE
ADANI POWER LIMITED	2	330.0	8/26/21, 11:04 AM		AIR PREHEATERS PROBLEM
ADANI POWER LIMITED	3		5/13/22, 9:29 AM		RSD/LOW SCHEDULE
ADANI POWER LIMITED	3	330.0	6/15/22, 12:00 AM		OVERHAULING WORKS
ADANI POWER LIMITED	7	660.0	5/6/21, 6:01 AM		AIR PREHEATERS PROBLEM
ADANI POWER LIMITED	7		7/21/22, 6:56 PM		CONDENSER TUBE LEAKAGE/
ADANI POWER LIMITED	8		7/19/21, 12:00 AM		OVERHAULING WORKS
ADANI POWER LIMITED	8	660.0	7/4/21, 12:57 AM		TURBINE MISC. PROBLEM
MUNDRA UMTTP	1	800.0	10/14/22, 4:34 PM		RESERVE SHUT DOWN
MUNDRA UMTTP	4	800.0	11/21/21, 9:42 AM		ELECTRICAL MISCELLANEOUS
KAWAS CCPP	1		7/3/24, 12:00 PM	04-07-2024	NO/REDUCED IRRIGATION DEMAND
KAWAS CCPP	1	106.0	6/8/24, 5:15 PM	09-06-2024	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	1		6/25/24, 12:27 AM	03-07-2024	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	1		8/21/24, 11:58 PM	29-08-2024	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	4		2/15/24, 8:27 AM	16-02-2024	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	4		8/17/22, 9:54 PM	17-08-2022	Fuel Shortage
KAWAS CCPP	4	106.0	10/8/24, 11:42 PM	09-10-2024	NO/REDUCED IRRIGATION DEMAND
KAWAS CCPP	4		2/16/24, 6:00 AM	16-02-2024	BOILER AUX. MISC. PROMLEMS
KAWAS CCPP	5		8/26/24, 12:00 PM	27-08-2024	NO/REDUCED IRRIGATION DEMAND
KAWAS CCPP	5		4/17/24, 12:44 AM	17-04-2024	NO/REDUCED IRRIGATION DEMAND
KAWAS CCPP	5		2/8/24, 10:45 AM	25-02-2024	BOILER INSPECTION/ RE-
KAWAS CCPP	5		8/24/24, 3:43 PM	25-08-2024	INSPECTION /MTCE
KAWAS CCPP	5		6/27/24, 8:26 AM	03-07-2024	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	5	116.1	6/8/24, 11:53 PM	09-06-2024	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	6		7/29/24, 8:30 PM	31-07-2024	NO/REDUCED IRRIGATION DEMAND
KAWAS CCPP	6		2/16/24, 8:00 AM	21-02-2024	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	6		2/21/24, 4:00 PM	24-02-2024	NO/REDUCED IRRIGATION DEMAND
KAWAS CCPP	6		2/16/24, 6:00 AM	16-02-2024	NO/REDUCED IRRIGATION DEMAND
KAWAS CCPP	6		2/21/24, 6:48 AM	21-02-2024	NO/REDUCED IRRIGATION DEMAND
KAWAS CCPP	6		8/2/24, 12:00 PM	09-08-2024	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	6		8/9/24, 12:00 PM	10-08-2024	NO/REDUCED IRRIGATION DEMAND

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
KAWAS CCPP	6		7/31/24, 11:00 AM	01-08-2024	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	6		10/1/24, 10:59 PM	02-12-2024	NO/REDUCED IRRIGATION DEMAND
KAWAS CCPP	6		2/21/24, 10:09 AM	21-02-2024	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	6		11/5/23, 12:00 AM	16-02-2024	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	6		8/1/24, 12:00 PM	02-08-2024	NO/REDUCED IRRIGATION DEMAND
KAWAS CCPP	6		3/15/23, 12:00 AM		MISCELLANEOUS
KAWAS CCPP	6		6/27/24, 8:33 AM	17-07-2024	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	6		7/17/24, 5:00 PM	24-07-2024	BOILER AUX. MISC. PROMLEMS
KAWAS CCPP	6	116.1	9/23/24, 5:46 PM	24-09-2024	NO/REDUCED IRRIGATION DEMAND
KAKRAPARA	2	220.0	11/11/20, 12:00 AM	11-11-2020	REACTOR MAINTENANCE WORKS.
KORBA-WEST TPS	1	210.0	11/30/23, 5:30 PM		REHEATER TUBE LEAKAGE
KORBA-WEST TPS	1		10/19/20, 7:29 PM	22-10-2020	REHEATER TUBE LEAKAGE
NIWARI TPP	1		2/16/23, 12:24 AM		AIR PREHEATERS PROBLEM
NIWARI TPP	1	45.0	6/30/22, 1:57 PM		RESERVE SHUT DOWN
SEIONI TPP	1	600.0	10/1/24, 11:01 PM	04-10-2024	BOILER MISC. PROBLEM
KORBA STPS	1	200.0	9/4/24, 5:06 PM	06-09-2024	WATER WALL TUBE LEAKAGE
OP JINDAL TPS	1	250.0	10/10/21, 10:28 PM		AIR PREHEATERS PROBLEM
OP JINDAL TPS	1		1/23/22, 12:00 AM		LOW SYSTEM DEMAND
OP JINDAL TPS	1		12/28/21, 12:00 AM		BOILER INSPECTION/ RE-
OP JINDAL TPS	1		5/17/21, 3:02 PM		AIR PREHEATERS PROBLEM
OP JINDAL TPS	1		1/13/20, 8:06 AM		AIR PREHEATERS PROBLEM
OP JINDAL TPS	1		5/24/22, 7:21 PM		AIR PREHEATERS PROBLEM
OP JINDAL TPS	2		2/23/20, 9:05 PM		ASH HANDLING SYSTEM PROBLEM
OP JINDAL TPS	2		6/6/22, 10:20 PM		MAIN STEAM LINE PROBLEM
OP JINDAL TPS	2		4/26/22, 4:50 PM		AIR PREHEATERS PROBLEM
OP JINDAL TPS	2		5/25/21, 3:27 PM		AIR PREHEATERS PROBLEM
OP JINDAL TPS	2	250.0	7/23/21, 11:22 PM		ASH HANDLING SYSTEM PROBLEM
OP JINDAL TPS	3		10/20/21, 12:00 AM		Fuel Shortage
OP JINDAL TPS	3		11/1/21, 12:00 AM		LOW SYSTEM DEMAND
OP JINDAL TPS	3	250.0	1/7/22, 11:48 PM		CONDENSER TUBE LEAKAGE/
OP JINDAL TPS	3		10/17/21, 3:00 AM		AIR PREHEATERS PROBLEM

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
OP JINDAL TPS	4		10/1/20, 9:32 AM		CONDENSER TUBE LEAKAGE/
OP JINDAL TPS	4	250.0	1/3/22, 12:41 PM		BOILER INSPECTION/ RE-
OP JINDAL TPS	4		10/27/21, 12:00 AM		Fuel Shortage
OP JINDAL TPS	4		7/19/20, 12:00 AM		TURBINE MISC. PROBLEM
OP JINDAL TPS	4		11/11/22, 1:08 AM		ABNORMAL BOILER OPERATIONAL
OP JINDAL TPS	4		4/28/22, 6:10 AM		CONDENSER TUBE LEAKAGE/
OP JINDAL TPS	4		12/1/21, 7:07 PM		AIR PREHEATERS PROBLEM
RATIJA TPS	2		11/10/23, 12:04 AM		MISCELLANEOUS PLANNED
RATIJA TPS	2	50.0	11/6/23, 12:33 AM		BOILER INSPECTION/ RE-
SWASTIK KORBA TPP	1	0.0	4/1/15, 12:20 AM	10-10-2018	No Fuel Supply Agreement
KATGHORA TPP	1	0.0	10/15/12, 12:28 AM	30-12-2018	No Fuel Supply Agreement
SALORA TPP	1	0.0	10/19/14, 4:30 AM	13-09-2018	No Fuel Supply Agreement
TAMNAR TPP	1		11/8/21, 9:29 PM		AIR PREHEATERS PROBLEM
TAMNAR TPP	1		5/2/21, 1:30 AM		MAIN STEAM LINE PROBLEM
TAMNAR TPP	1	600.0	7/11/21, 12:04 AM		CONDENSER TUBE LEAKAGE/
TAMNAR TPP	2		9/16/21, 7:00 AM		TURBINE VIBRATION
TAMNAR TPP	2		6/19/21, 12:00 AM		COAL FEEDING PROBLEM IN PLANT
TAMNAR TPP	2		4/23/21, 5:44 AM		CONDENSER TUBE LEAKAGE/
TAMNAR TPP	2	600.0	4/11/20, 3:00 AM		AIR PREHEATERS PROBLEM
TAMNAR TPP	2		9/23/21, 12:00 AM		Fuel Shortage
TAMNAR TPP	2		9/24/21, 12:00 AM		TURBINE VIBRATION HIGH
TAMNAR TPP	2		9/2/21, 1:04 AM		TURBINE VIBRATION
TAMNAR TPP	2		9/25/23, 7:34 PM		FURNACE DRAFT ABNORMAL
TAMNAR TPP	3		12/18/21, 6:55 PM		AIR PREHEATERS PROBLEM
TAMNAR TPP	3		6/18/22, 12:35 AM		AIR PREHEATERS PROBLEM
TAMNAR TPP	3		10/23/21, 9:12 PM		AIR PREHEATERS PROBLEM
TAMNAR TPP	3		9/26/21, 12:00 AM		CONDENSER TUBE LEAKAGE/
TAMNAR TPP	3		11/24/21, 12:00 AM		MAIN STEAM LINE PROBLEM
TAMNAR TPP	3	600.0	9/11/22, 12:35 AM		BOILER AUX. MISC. PROMLEMS
TAMNAR TPP	3		11/8/20, 2:48 AM		CONDENSER TUBE LEAKAGE/
TAMNAR TPP	3		5/15/22, 6:01 AM		GENEATOR TRANSFORMER OIL

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
TAMNAR TPP	3		5/7/21, 3:34 PM		AIR PREHEATERS PROBLEM
TAMNAR TPP	3		7/21/20, 10:53 AM		ELECTRICAL MISCELLANEOUS
TAMNAR TPP	3		9/8/20, 4:00 AM		CONDENSER TUBE LEAKAGE/
TAMNAR TPP	3		4/17/22, 5:00 AM		AIR PREHEATERS PROBLEM
TAMNAR TPP	4		12/30/20, 12:16 PM		ASH HANDLING SYSTEM PROBLEM
TAMNAR TPP	4		12/12/21, 12:00 AM		AIR PREHEATERS PROBLEM
TAMNAR TPP	4		8/5/21, 12:00 AM		ANNUAL MAINTENANCE
TAMNAR TPP	4		9/9/20, 1:57 AM		AIR PREHEATERS PROBLEM
TAMNAR TPP	4	600.0	10/14/22, 9:57 PM		TURBINE MISC. PROBLEM
TAMNAR TPP	4		8/29/23, 3:11 AM		ANNUAL MAINTENANCE
BINJKOTE TPP	1		5/13/20, 3:48 PM		SUPER HEATER TUBE LEAKAGE
BINJKOTE TPP	1	300.0	11/7/19, 12:00 AM		RSD/LOW SCHEDULE
BINJKOTE TPP	1		11/6/19, 9:19 PM		BOILER MISC. PROBLEM
BINJKOTE TPP	2	300.0	10/18/19, 8:32 PM	23-10-2019	ECONOMISER TUBE LEAKAGE
BINJKOTE TPP	2		10/22/19, 11:59 PM		COAL SHORTAGE
BINJKOTE TPP	2		1/25/20, 12:01 AM		COOLING TOWER PROBLEM
NAWAPARA TPP	1		4/18/21, 7:39 AM		BOILER AUX. MISC. PROMLEMS
NAWAPARA TPP	1		9/2/21, 2:58 AM		FURNACE FIRE OUT /FLAME FAILURE
NAWAPARA TPP	1	300.0	9/12/20, 3:22 PM		WET/ POOR QUALITY COAL
NAWAPARA TPP	2	300.0	2/6/21, 12:00 AM		TRANSMISSION CONSTRAINTS
NAWAPARA TPP	2		12/23/20, 12:00 AM		COAL SHORTAGE
NAWAPARA TPP	2		10/1/22, 8:48 AM		FURNACE FIRE OUT /FLAME FAILURE
NAWAPARA TPP	2		12/5/20, 5:49 PM		BOILER INSPECTION/ RE-
UCHPINDA TPP	3	360.0	7/26/19, 1:50 PM		BOILER MISC. PROBLEM
NASIK TPS	3	210.0	8/26/21, 7:44 PM		COAL SHORTAGE
NASIK TPS	5	210.0	8/25/24, 1:23 PM		RESERVE SHUT DOWN
PARAS TPS	4	250.0	1/4/23, 7:08 AM		DRUM LEVEL HIGH/ low
BHUSAWAL TPS	3	210.0	6/8/21, 12:34 AM	08-08-2021	RSD/LOW SCHEDULE
URAN CCPP	7		4/25/23, 10:44 PM		INSTRUMENTATION PROBLEM
URAN CCPP	7	108.0	2/25/20, 12:51 PM		TURBINE MISC. PROBLEM
TROMBAY CCPP	1	120.0	11/5/22, 12:05 AM	13-11-2022	Fuel Shortage

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
TROMBAY CCPP	2	60.0	11/4/22, 4:22 AM	13-11-2022	Fuel Shortage
RATNAGIRI CCPP	1	205.0	6/20/22, 12:01 PM		GT SHUT DOWN DUE TO FUEL
RATNAGIRI CCPP	2	205.0	7/8/14, 1:30 PM	02-04-2017	GT SHUT DOWN DUE TO FUEL
RATNAGIRI CCPP	3	230.0	6/6/23, 12:00 AM		GT SHUT DOWN DUE TO FUEL
MIHAN TPS	1	61.51	1/10/13, 3:50 PM	01-07-2018	No Fuel Supply Agreement
MIHAN TPS	2	61.5	11/5/13, 11:53 AM	29-05-2018	No Fuel Supply Agreement
MIHAN TPS	3	61.5	6/10/13, 6:00 PM	07-05-2018	No Fuel Supply Agreement
MIHAN TPS	4	61.5	8/20/13, 10:00 AM	05-05-2018	No Fuel Supply Agreement
AMRAVATI TPS	1		9/8/22, 11:58 AM		FURNACE CLINKER FORMATION
AMRAVATI TPS	1		3/7/22, 2:39 AM		ELECTRICAL MISCELLANEOUS
AMRAVATI TPS	1	270.0	4/20/21, 1:00 AM		ASH HANDLING SYSTEM PROBLEM
AMRAVATI TPS	2	270.0	5/16/23, 11:00 PM		ASH HANDLING SYSTEM PROBLEM
AMRAVATI TPS	3		12/25/22, 5:45 PM		ASH HANDLING SYSTEM PROBLEM
AMRAVATI TPS	3	270.0	5/24/22, 2:22 AM		FURNACE FIRE OUT /FLAME FAILURE
AMRAVATI TPS	4		5/31/22, 1:15 AM		ASH HANDLING SYSTEM PROBLEM
AMRAVATI TPS	4	270.0	11/13/21, 7:15 AM		ASH HANDLING SYSTEM PROBLEM
AMRAVATI TPS	5	270.0	3/3/22, 12:00 PM	06-03-2022	ASH HANDLING SYSTEM PROBLEM
AMRAVATI TPS	5		9/23/21, 12:44 AM	30-09-2021	ASH HANDLING SYSTEM PROBLEM
AMRAVATI TPS	5		10/6/22, 9:33 PM		BOILER MISC. PROBLEM
NASIK (P) TPS	1	0.0	3/4/14, 6:10 PM	14-05-2018	No Fuel Supply Agreement
NASIK (P) TPS	2	0.0	2/16/17, 12:46 AM		NO Power purchase agreement
NASIK (P) TPS	3	0.0	4/14/17, 1:45 AM		NO Power purchase agreement
NASIK (P) TPS	4	0.0	5/20/17, 12:25 AM		NO Power purchase agreement
NASIK (P) TPS	5	0.0	5/30/17, 3:24 PM		NO Power purchase agreement
GEPL TPP Ph-I	1	60.0	6/29/13, 12:00 AM	03-05-2018	No Fuel Supply Agreement
GEPL TPP Ph-I	2	60.0	6/20/13, 8:27 PM	24-11-2018	No Fuel Supply Agreement
MANGAON CCPP	1	0.0	2/7/17, 5:30 PM	12-05-2018	GT-NO SCHEDULE FROM
TARAPUR	1	160.0	3/6/24, 12:00 AM		RENOVATION/MODERNISATION WORKS
TARAPUR	2	160.0	7/13/20, 4:38 AM	24-04-2024	RENOVATION/MODERNISATION WORKS
TARAPUR	4	540.0	3/2/24, 12:00 AM	03-03-2024	MISCELLANEOUS
GOA CCPP (Liq.)	1	0.0	5/1/14, 12:00 AM		GT-NO SCHEDULE FROM

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
Dr. N.TATA RAO TPS	2	210.0	8/5/20, 4:42 AM		P.A. FANS PROBLEM
Dr. N.TATA RAO TPS	4		3/12/23, 9:55 PM		BOILER AUX. MISC. PROMLEMS
Dr. N.TATA RAO TPS	4	210.0	9/25/20, 3:13 PM		I.D. FANS PROBLEM
Dr. N.TATA RAO TPS	5		8/7/20, 4:32 AM		TUBE LKG. AT LOW TEMP.
Dr. N.TATA RAO TPS	5	210.0	3/8/23, 12:10 AM		ECONOMISER TUBE LEAKAGE
Dr. N.TATA RAO TPS	5		8/6/20, 4:33 AM		WATER WALL TUBE LEAKAGE
Dr. N.TATA RAO TPS	6	210.0	9/13/20, 3:22 PM		RESERVE SHUT DOWN / STANDBY UNIT
DAMODARAM SANJEEVAIAH	3	800.0	4/30/23, 4:16 PM	03-05-2023	WATER WALL TUBE LEAKAGE
RAMAGUNDEM-B TPS	1		6/9/20, 12:01 AM		BOILER OVERHAUL/ ANNUAL
RAMAGUNDEM-B TPS	1		6/4/24, 8:24 PM		COAL FEEDING PROBLEM IN PLANT
RAMAGUNDEM-B TPS	1	62.5	4/17/20, 5:10 PM		RSD/LOW SCHEDULE
RAMAGUNDEM-B TPS	1		4/21/20, 9:15 PM		RSD/LOW SCHEDULE
KAKATIYA TPS	2		4/12/20, 7:35 AM		WATER WALL TUBE LEAKAGE
KAKATIYA TPS	2	600.0	6/2/20, 6:40 PM		FURNACE FIRE OUT /FLAME FAILURE
RAYALASEEMA TPS	1		10/22/23, 8:31 PM		FURNACE FIRE OUT /FLAME FAILURE
RAYALASEEMA TPS	1	210.0	7/18/24, 8:28 PM		GENEATOR PROTECTION MISC/BACK
RAYALASEEMA TPS	2	210.0	2/23/23, 1:23 AM		SUPER HEATER TUBE LEAKAGE
RAYALASEEMA TPS	2		9/7/24, 10:21 PM		WATER WALL TUBE LEAKAGE
RAYALASEEMA TPS	3		8/4/22, 12:52 AM		TURBINE MISC. PROBLEM
RAYALASEEMA TPS	3		11/15/22, 9:47 PM		ECONOMISER TUBE LEAKAGE
RAYALASEEMA TPS	3	210.0	8/4/22, 9:00 PM		COAL SHORTAGE
RAYALASEEMA TPS	4	210.0	10/31/22, 10:13 AM		COAL SHORTAGE
THAMMINAPATNAM TPS	1		9/13/24, 12:00 AM	14-09-2024	TURBINE VIBRATION
THAMMINAPATNAM TPS	1		9/21/24, 1:18 AM	31-12-2024	TURBINE INSPECTION MISC
THAMMINAPATNAM TPS	1	150.0	9/11/24, 1:01 PM	13-09-2024	TURBINE VIBRATION HIGH
VIZAG TPP	1	520.0	4/18/22, 10:34 PM		BOILER AUX. MISC. PROMLEMS
VIZAG TPP	1		5/29/22, 11:24 PM		BOILER AUX. MISC. PROMLEMS
VIZAG TPP	1		9/15/24, 3:57 AM		BOILER AUX. MISC. PROMLEMS
VIZAG TPP	1		9/20/24, 5:00 PM		COOLING WATER SYSTEM
VIZAG TPP	2		4/27/20, 4:00 AM		COAL SHORTAGE
VIZAG TPP	2	520.0	4/25/20, 4:11 AM		Cooling Water System Abnormal/

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
VIZAG TPP	2		7/16/20, 4:00 AM		COAL SHORTAGE
VIZAG TPP	2		10/11/24, 1:33 AM		SWITCH YARD/TRIPPING OF
VIZAG TPP	2		6/26/24, 8:16 AM		COOLING WATER SYSTEM
VIJJESWARAM CCPP	1		8/9/19, 10:47 PM		GT SHUT DOWN DUE TO FUEL
VIJJESWARAM CCPP	1		1/4/20, 10:27 AM	15-04-2020	Fuel Shortage
VIJJESWARAM CCPP	1		2/3/20, 12:00 AM	05-02-2020	SCHEDULED ANNUAL MAINTENANCE
VIJJESWARAM CCPP	1		10/3/22, 12:00 AM		Fuel Shortage
VIJJESWARAM CCPP	1	0.0	7/5/20, 12:00 AM	31-07-2020	SCHEDULED ANNUAL MAINTENANCE
VIJJESWARAM CCPP	2		10/3/22, 12:00 AM		Fuel Shortage
VIJJESWARAM CCPP	2	0.0	2/24/20, 12:00 AM	24-03-2020	SCHEDULED ANNUAL MAINTENANCE
VIJJESWARAM CCPP	3	0.0	10/3/22, 12:00 AM		Fuel Shortage
VIJJESWARAM CCPP	4	0.0	9/22/22, 12:00 AM		Fuel Shortage
VIJJESWARAM CCPP	5	0.0	9/22/22, 12:00 AM		Fuel Shortage
JEGURUPADU CCPP PH I	1	52.8	5/10/24, 7:12 PM	30-06-2024	Fuel Shortage
JEGURUPADU CCPP PH I	2	52.8	4/17/23, 12:00 AM	30-06-2023	Fuel Shortage
JEGURUPADU CCPP PH I	3		3/26/20, 4:25 PM		Fuel Shortage
JEGURUPADU CCPP PH I	3		3/6/21, 12:29 AM	11-03-2021	BOILER INSPECTION/ RE-
JEGURUPADU CCPP PH I	3	52.8	3/7/20, 1:45 PM		GT-GEN./FIELD BREAKER PROBLEM
JEGURUPADU CCPP PH I	3		12/1/21, 2:40 PM	15-12-2021	Fuel Shortage
JEGURUPADU CCPP PH I	3		3/6/20, 3:31 PM		Fuel Shortage
JEGURUPADU CCPP PH I	3		5/20/24, 12:00 AM	30-06-2024	Fuel Shortage
JEGURUPADU CCPP PH I	4	77.0	5/20/24, 12:00 AM	30-06-2024	Fuel Shortage
JEGURUPADU CCPP PH II	1	0.0	12/15/15, 11:18 PM		GT SHUT DOWN DUE TO FUEL
JEGURUPADU CCPP PH II	2	0.0	12/15/15, 11:02 PM		GT SHUT DOWN DUE TO FUEL
GODAVARI CCPP	1		3/13/19, 10:23 AM	13-03-2019	Fuel Shortage
GODAVARI CCPP	1	0.0	8/6/21, 5:45 PM	10-08-2021	GT SHUT DOWN DUE TO FUEL
GODAVARI CCPP	1		8/6/21, 9:00 AM		Fuel Shortage
GODAVARI CCPP	2	0.0	10/22/21, 5:26 AM		Fuel Shortage
GODAVARI CCPP	3		12/28/19, 1:58 PM	02-01-2020	Fuel Shortage
GODAVARI CCPP	3	0.0	2/18/19, 12:00 AM	22-02-2019	SCHEDULED ANNUAL MAINTENANCE
GODAVARI CCPP	4	0.0	10/22/21, 5:03 AM		Fuel Shortage

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
KONDAPALLI CCPP	1	0.0	10/2/21, 12:00 AM		Fuel Shortage
KONDAPALLI CCPP	1		7/13/20, 12:00 AM		NO Power purchase agreement
KONDAPALLI CCPP	2		10/30/21, 4:32 PM	05-11-2021	GT/WHRB/ST PLANNED OVERHAUL
KONDAPALLI CCPP	2		9/18/21, 12:00 AM	19-09-2021	Fuel Shortage
KONDAPALLI CCPP	2	0.0	4/10/19, 12:00 AM	22-05-2019	Fuel Shortage
KONDAPALLI CCPP	3		9/18/21, 12:00 AM	18-09-2021	Fuel Shortage
KONDAPALLI CCPP	3	0.0	10/30/21, 4:30 PM	05-11-2021	MISCELLANEOUS
KONDAPALLI ST-3 CCPP	1	0.0	9/16/16, 5:40 AM		GT SHUT DOWN DUE TO FUEL
KONDAPALLI ST-3 CCPP	2	0.0	11/2/16, 12:01 AM		GT SHUT DOWN DUE TO FUEL
PEDDAPURAM CCPP	1	0.0	1/4/15, 12:00 AM		GT-NO SCHEDULE FROM
PEDDAPURAM CCPP	2	0.0	1/4/15, 12:00 AM		GT-NO SCHEDULE FROM
GAUTAMI CCPP	1	0.0	2/2/13, 12:17 PM		GT SHUT DOWN DUE TO FUEL
GAUTAMI CCPP	2	0.0	4/30/15, 11:26 PM		GT SHUT DOWN DUE TO FUEL
GAUTAMI CCPP	3	0.0	4/30/15, 11:17 PM		GT SHUT DOWN DUE TO FUEL
KONASEEMA CCPP	1	0.0	4/18/16, 12:00 AM	10-08-2017	GT SHUT DOWN DUE TO FUEL
KONASEEMA CCPP	2	0.0	4/18/16, 12:00 AM	04-04-2017	GT SHUT DOWN DUE TO FUEL
KONASEEMA CCPP	3	0.0	4/18/16, 12:00 AM	31-10-2018	GT SHUT DOWN DUE TO FUEL
VEMAGIRI CCPP	2	137.0	10/1/16, 1:25 AM		GT SHUT DOWN DUE TO FUEL
GREL CCPP (Rajahmundry)	1	240.0	9/1/16, 12:25 AM		GT SHUT DOWN DUE TO FUEL
GREL CCPP (Rajahmundry)	2	144.0	9/1/16, 12:25 AM		GT SHUT DOWN DUE TO FUEL
GREL CCPP (Rajahmundry)	3	240.0	10/1/16, 2:10 AM		GT SHUT DOWN DUE TO FUEL
GREL CCPP (Rajahmundry)	4	144.0	10/1/16, 2:10 AM		GT SHUT DOWN DUE TO FUEL
RAICHUR TPS	1		8/14/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	1		7/15/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	1		6/20/22, 8:20 PM	24-06-2022	ASH HANDLING SYSTEM PROBLEM
RAICHUR TPS	1		6/24/22, 6:30 PM		RSD/LOW SCHEDULE
RAICHUR TPS	1		6/29/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	1		7/24/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	1		8/24/22, 11:59 PM		OLD UNIT NOT IN OPERATION DUE TO
RAICHUR TPS	1		9/16/22, 11:59 PM		COAL FEEDING PROBLEM IN PLANT
RAICHUR TPS	1		6/30/22, 11:59 PM		RSD/LOW SCHEDULE

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
RAICHUR TPS	1		7/26/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	1		8/26/22, 11:59 PM		OLD UNIT NOT IN OPERATION DUE TO
RAICHUR TPS	1		7/23/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	1		9/4/22, 11:59 PM		Fuel System Abnormal/ Maintenance
RAICHUR TPS	1		11/2/22, 11:59 PM		Fuel System Abnormal/ Maintenance
RAICHUR TPS	1		7/16/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	1		8/10/22, 8:45 AM		RESERVE SHUT DOWN
RAICHUR TPS	1		8/10/22, 11:59 PM		Fuel System Abnormal/ Maintenance
RAICHUR TPS	1		8/19/22, 11:59 PM		Fuel System Abnormal/ Maintenance
RAICHUR TPS	1		9/9/22, 11:59 PM		COAL FEEDING SYSTEM FAILURE.
RAICHUR TPS	1		8/13/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	1		10/8/22, 11:59 PM		COAL FEEDING SYSTEM FAILURE.
RAICHUR TPS	1		7/11/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	1		8/10/22, 9:00 AM		MAJOR BREAK DOWN
RAICHUR TPS	1		11/22/22, 11:59 PM		COAL FEEDING SYSTEM NOT READY
RAICHUR TPS	1		8/1/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	1		7/6/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	1		9/30/22, 11:59 PM		COAL FEEDING SYSTEM NOT READY
RAICHUR TPS	1		7/2/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	1		9/25/22, 11:59 PM		COAL FEEDING PROBLEM IN PLANT
RAICHUR TPS	1		7/14/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	1		8/21/22, 11:59 PM		OLD UNIT NOT IN OPERATION DUE TO
RAICHUR TPS	1		8/29/22, 11:59 PM		COAL FEEDING SYSTEM FAILURE.
RAICHUR TPS	1		7/10/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	1		8/23/22, 11:59 PM		MAJOR BREAK DOWN
RAICHUR TPS	1		10/28/22, 11:59 PM		COAL FEEDING SYSTEM FAILURE.
RAICHUR TPS	1		7/25/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	1		9/27/22, 11:59 PM		COAL FEEDING PROBLEM IN PLANT
RAICHUR TPS	1		9/29/22, 11:59 PM		COAL FEEDING PROBLEM IN PLANT
RAICHUR TPS	1		8/8/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	1		8/20/22, 11:59 PM		MAJOR BREAK DOWN

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
RAICHUR TPS	1		8/31/22, 11:58 PM		COAL FEEDING SYSTEM FAILURE.
RAICHUR TPS	1		11/24/22, 11:59 PM		COAL FEEDING SYSTEM NOT READY
RAICHUR TPS	1		8/3/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	1		10/26/22, 11:59 PM		COAL FEEDING SYSTEM FAILURE.
RAICHUR TPS	1		9/5/22, 11:59 PM		MAJOR BREAK DOWN
RAICHUR TPS	1		10/11/22, 11:59 PM		COAL FEEDING PROBLEM IN PLANT
RAICHUR TPS	1		8/30/22, 11:59 PM		COAL FEEDING PROBLEM IN PLANT
RAICHUR TPS	1		8/17/22, 11:59 PM		Fuel System Abnormal/ Maintenance
RAICHUR TPS	1		1/20/24, 12:00 AM		COLLAPSE OF R.C. BUNKER
RAICHUR TPS	1		10/10/22, 11:59 PM		COAL FEEDING SYSTEM FAILURE.
RAICHUR TPS	1		7/31/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	1		7/22/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	1		10/24/22, 11:59 PM		COAL FEEDING SYSTEM FAILURE.
RAICHUR TPS	1		8/18/22, 11:59 PM		MAJOR BREAK DOWN
RAICHUR TPS	1		8/22/22, 11:59 PM		VARIOUS MAINTENANCE WORKS
RAICHUR TPS	1		10/25/22, 11:59 PM		COAL FEEDING SYSTEM NOT READY
RAICHUR TPS	1		10/5/22, 11:59 PM		COAL FEEDING SYSTEM NOT READY
RAICHUR TPS	1		8/25/22, 11:59 PM		VARIOUS MAINTENANCE WORKS
RAICHUR TPS	1		11/17/22, 11:59 PM		COAL FEEDING SYSTEM FAILURE.
RAICHUR TPS	1		11/19/22, 11:59 PM		COAL FEEDING PROBLEM IN PLANT
RAICHUR TPS	1		8/6/22, 11:59 PM		RSD/LOW SCHEDULE
RAICHUR TPS	1		10/21/22, 11:59 PM		COAL FEEDING PROBLEM IN PLANT
RAICHUR TPS	1		7/7/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	1		11/23/22, 11:59 PM		COAL FEEDING SYSTEM FAILURE.
RAICHUR TPS	1		9/10/22, 11:59 PM		COAL FEEDING PROBLEM IN PLANT
RAICHUR TPS	1		10/2/22, 11:59 PM		COAL FEEDING SYSTEM FAILURE.
RAICHUR TPS	1		10/29/22, 11:59 PM		COAL FEEDING SYSTEM NOT READY
RAICHUR TPS	1		6/28/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	1		10/14/22, 11:59 PM		COAL FEEDING SYSTEM FAILURE.
RAICHUR TPS	1		8/2/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	1		9/1/22, 11:59 PM		COAL FEEDING PROBLEM IN PLANT

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
RAICHUR TPS	1		11/20/22, 11:59 PM		COAL FEEDING SYSTEM FAILURE.
RAICHUR TPS	1		7/17/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	1		10/13/22, 11:59 PM		COAL FEEDING PROBLEM IN PLANT
RAICHUR TPS	1		8/16/22, 11:59 PM		MAJOR BREAK DOWN
RAICHUR TPS	1		10/27/22, 11:59 PM		COAL FEEDING PROBLEM IN PLANT
RAICHUR TPS	1		9/18/22, 11:59 PM		COAL FEEDING PROBLEM IN PLANT
RAICHUR TPS	1		9/28/22, 11:59 PM		COAL FEEDING SYSTEM FAILURE.
RAICHUR TPS	1		9/24/22, 11:59 PM		COAL FEEDING SYSTEM FAILURE.
RAICHUR TPS	1		8/11/22, 11:59 PM		MAJOR BREAK DOWN
RAICHUR TPS	1		3/15/24, 12:00 AM		COAL FEEDING SYSTEM FAILURE.
RAICHUR TPS	1		8/4/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	1		7/9/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	1		9/26/22, 11:59 PM		COAL FEEDING SYSTEM FAILURE.
RAICHUR TPS	1		9/8/22, 11:59 PM		COAL FEEDING PROBLEM IN PLANT
RAICHUR TPS	1		7/27/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	1		8/7/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	1		10/9/22, 11:59 PM		COLLAPSE OF R.C. BUNKER
RAICHUR TPS	1		10/12/22, 12:00 AM		COAL FEEDING SYSTEM FAILURE.
RAICHUR TPS	1		7/30/22, 7:11 AM		RESERVE SHUT DOWN
RAICHUR TPS	1		9/2/22, 11:59 PM		COAL FEEDING SYSTEM FAILURE.
RAICHUR TPS	1		9/11/22, 11:59 PM		COAL FEEDING SYSTEM FAILURE.
RAICHUR TPS	1		7/29/22, 11:59 PM	30-07-2022	RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	1		8/9/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	1		8/12/22, 11:59 PM		Fuel System Abnormal/ Maintenance
RAICHUR TPS	1		7/8/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	1		9/17/22, 11:59 PM		COAL FEEDING SYSTEM FAILURE.
RAICHUR TPS	1		7/3/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	1		9/3/22, 11:59 PM		COAL FEEDING SYSTEM NOT READY
RAICHUR TPS	1	210.0	7/1/22, 12:00 AM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	2		9/5/22, 11:59 PM		FUEL SUPPLY & OTHER MISC.
RAICHUR TPS	2		7/14/22, 11:59 PM		RESERVE SHUT DOWN

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
RAICHUR TPS	2		8/18/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	2		10/10/22, 11:58 PM		COAL FEEDING SYSTEM FAILURE.
RAICHUR TPS	2		7/26/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	2		11/22/22, 11:59 PM		COAL FEEDING SYSTEM FAILURE.
RAICHUR TPS	2		8/22/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	2		11/20/22, 11:59 PM		COAL FEEDING SYSTEM NOT READY
RAICHUR TPS	2		8/29/22, 11:59 PM		RSD/LOW SCHEDULE
RAICHUR TPS	2		8/20/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	2		11/4/22, 11:59 PM		COAL FEEDING PROBLEM IN PLANT
RAICHUR TPS	2		6/30/22, 11:59 PM		RSD/LOW SCHEDULE
RAICHUR TPS	2		7/3/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	2		4/5/20, 10:44 AM		TUBE LKG. AT LOW TEMP.
RAICHUR TPS	2		7/10/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	2		9/24/22, 11:59 PM		COAL FEEDING SYSTEM FAILURE.
RAICHUR TPS	2		11/23/22, 11:59 PM		COAL FEEDING SYSTEM NOT READY
RAICHUR TPS	2		11/6/22, 11:59 PM		Fuel System Abnormal/ Maintenance
RAICHUR TPS	2		11/10/22, 11:59 PM		COAL FEEDING SYSTEM NOT READY
RAICHUR TPS	2		9/25/22, 11:59 PM		COAL FEEDING PROBLEM IN PLANT
RAICHUR TPS	2		8/12/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	2		6/29/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	2		5/30/23, 12:01 AM		GENERATOR MISCLLANEOUS
RAICHUR TPS	2		8/26/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	2		8/24/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	2		10/13/22, 11:59 PM		COAL FEEDING PROBLEM IN PLANT
RAICHUR TPS	2		7/17/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	2		7/15/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	2		7/6/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	2		10/28/22, 11:59 PM		COAL FEEDING SYSTEM FAILURE.
RAICHUR TPS	2		7/8/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	2		7/11/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	2		8/19/22, 11:59 PM		RESERVE SHUT DOWN

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
RAICHUR TPS	2		8/31/22, 11:59 PM		COAL FEEDING SYSTEM FAILURE.
RAICHUR TPS	2		10/21/22, 11:59 PM		COAL FEEDING PROBLEM IN PLANT
RAICHUR TPS	2		8/6/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	2		8/21/22, 11:59 PM		RSD/LOW SCHEDULE
RAICHUR TPS	2		7/25/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	2		9/2/22, 11:59 PM		COAL FEEDING SYSTEM FAILURE.
RAICHUR TPS	2		9/26/22, 11:59 PM		COAL FEEDING SYSTEM FAILURE.
RAICHUR TPS	2		9/28/22, 11:59 PM		COAL FEEDING SYSTEM FAILURE.
RAICHUR TPS	2		11/2/22, 11:59 PM		COAL FEEDING SYSTEM FAILURE.
RAICHUR TPS	2		11/10/22, 12:00 AM	10-11-2022	FUEL SUPPLY & OTHER MISC.
RAICHUR TPS	2		8/23/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	2		10/15/22, 11:59 PM		COAL FEEDING SYSTEM NOT READY
RAICHUR TPS	2		9/18/22, 11:59 PM		COAL FEEDING PROBLEM IN PLANT
RAICHUR TPS	2		9/3/22, 11:59 PM		COAL FEEDING SYSTEM NOT READY
RAICHUR TPS	2		8/13/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	2		9/29/22, 11:59 PM		COAL FEEDING PROBLEM IN PLANT
RAICHUR TPS	2		8/9/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	2		10/8/22, 11:59 PM		COAL FEEDING PROBLEM IN PLANT
RAICHUR TPS	2		7/2/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	2		6/24/22, 9:37 AM	25-06-2022	RSD/LOW SCHEDULE
RAICHUR TPS	2		7/24/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	2		8/14/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	2		10/24/22, 11:59 PM		COAL FEEDING SYSTEM FAILURE.
RAICHUR TPS	2		8/17/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	2		7/1/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	2		10/29/22, 11:59 PM		COAL FEEDING SYSTEM NOT READY
RAICHUR TPS	2		11/24/22, 11:59 PM		COAL FEEDING SYSTEM FAILURE.
RAICHUR TPS	2		8/31/24, 12:00 AM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	2		9/30/22, 11:59 PM		COAL FEEDING SYSTEM NOT READY
RAICHUR TPS	2		10/14/22, 11:59 PM		COAL FEEDING SYSTEM FAILURE.
RAICHUR TPS	2		10/11/22, 11:59 PM		COAL FEEDING PROBLEM IN PLANT

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
RAICHUR TPS	2		7/7/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	2		9/1/22, 11:59 PM		COAL FEEDING PROBLEM IN PLANT
RAICHUR TPS	2		10/9/22, 11:59 PM		COAL FEEDING SYSTEM NOT READY
RAICHUR TPS	2		8/25/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	2		9/8/22, 11:59 PM		COAL FEEDING PROBLEM IN PLANT
RAICHUR TPS	2		7/22/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	2	210.0	8/10/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	2		3/15/24, 12:00 AM		BOILER AUX. MISC. PROMLEMS
RAICHUR TPS	2		8/11/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	2		8/7/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	2		10/25/22, 11:59 PM		COAL FEEDING SYSTEM NOT READY
RAICHUR TPS	2		11/5/22, 11:59 PM		COAL FEEDING SYSTEM NOT READY
RAICHUR TPS	2		9/17/22, 11:59 PM		COAL FEEDING SYSTEM FAILURE.
RAICHUR TPS	2		8/8/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	2		8/30/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	2		9/4/22, 11:59 PM		Fuel System Abnormal/ Maintenance
RAICHUR TPS	2		9/9/22, 11:59 PM		COAL FEEDING SYSTEM FAILURE.
RAICHUR TPS	2		10/27/22, 11:59 PM		COAL FEEDING PROBLEM IN PLANT
RAICHUR TPS	2		10/17/22, 11:59 PM		COAL FEEDING PROBLEM IN PLANT
RAICHUR TPS	2		11/7/22, 11:59 PM		COAL FEEDING SYSTEM FAILURE.
RAICHUR TPS	2		9/27/22, 11:59 PM		COAL FEEDING PROBLEM IN PLANT
RAICHUR TPS	2		10/12/22, 11:59 PM		COAL FEEDING SYSTEM FAILURE.
RAICHUR TPS	2		7/16/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	2		3/14/24, 7:06 AM	17-03-2024	WATER WALL TUBE LEAKAGE
RAICHUR TPS	2		9/10/22, 11:59 PM		COAL FEEDING PROBLEM IN PLANT
RAICHUR TPS	2		11/17/22, 11:59 PM		COAL FEEDING SYSTEM FAILURE.
RAICHUR TPS	2		11/8/22, 11:59 PM		COAL FEEDING SYSTEM NOT READY
RAICHUR TPS	2		10/18/22, 11:59 PM		COAL FEEDING SYSTEM NOT READY
RAICHUR TPS	2		7/23/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	2		11/19/22, 11:59 PM		COAL FEEDING PROBLEM IN PLANT
RAICHUR TPS	2		10/5/22, 11:59 PM		COAL FEEDING SYSTEM NOT READY

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
RAICHUR TPS	2		6/28/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	2		10/2/22, 11:59 PM		COAL FEEDING SYSTEM FAILURE.
RAICHUR TPS	2		8/16/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	2		7/9/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	2		9/16/22, 11:59 PM		COAL FEEDING PROBLEM IN PLANT
RAICHUR TPS	2		9/11/22, 11:59 PM		COAL FEEDING SYSTEM FAILURE.
RAICHUR TPS	2		8/25/24, 3:02 PM		RSD/LOW SCHEDULE
RAICHUR TPS	2		10/26/22, 11:59 PM		COAL FEEDING SYSTEM FAILURE.
RAICHUR TPS	3		8/6/22, 11:59 PM		RSD/LOW SCHEDULE
RAICHUR TPS	3		8/16/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	3		8/10/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	3		9/17/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	3	210.0	6/29/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	3		8/25/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	3		8/31/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	3		6/30/22, 11:59 PM		RSD/LOW SCHEDULE
RAICHUR TPS	3		8/19/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	3		7/16/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	3		7/8/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	3		9/16/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	3		8/17/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	3		8/30/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	3		7/24/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	3		7/11/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	3		7/3/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	3		8/20/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	3		9/9/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	3		8/13/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	3		9/11/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	3		7/6/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	3		8/22/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
RAICHUR TPS	3		6/25/22, 10:30 AM		RSD/LOW SCHEDULE
RAICHUR TPS	3		9/8/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	3		8/14/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	3		9/1/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	3		8/26/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	3		7/17/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	3		7/15/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	3		7/10/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	3		6/28/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	3		9/4/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	3		7/25/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	3		9/10/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	3		8/29/22, 11:59 PM		RSD/LOW SCHEDULE
RAICHUR TPS	3		8/11/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	3		8/5/22, 11:38 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	3		7/23/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	3		7/7/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	3		7/14/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	3		8/23/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	3		8/12/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	3		7/22/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	3		9/3/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	3		8/18/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	3		8/9/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	3		8/8/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	3		7/1/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	3		8/21/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	3		8/24/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	3		9/2/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	3		7/2/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	3		9/5/22, 11:59 PM		RESERVE SHUT DOWN

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
RAICHUR TPS	3		7/9/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	3		8/7/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	4		8/25/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	4	210.0	8/7/22, 11:49 AM		RESERVE SHUT DOWN
RAICHUR TPS	4		7/17/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	4		7/24/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	4		9/5/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	4		1/6/23, 9:06 PM	14-01-2023	BOILER MISC. PROBLEM
RAICHUR TPS	4		8/8/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	4		8/22/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	4		8/11/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	4		7/22/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	4		8/30/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	4		9/1/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	4		8/31/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	4		8/18/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	4		7/2/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	4		9/11/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	4		8/23/22, 11:58 PM		RESERVE SHUT DOWN
RAICHUR TPS	4		9/9/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	4		9/8/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	4		7/7/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	4		8/12/23, 11:42 PM		WATER WALL TUBE LEAKAGE
RAICHUR TPS	4		8/14/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	4		8/21/22, 11:59 PM		RSD/LOW SCHEDULE
RAICHUR TPS	4		8/16/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	4		8/13/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	4		8/20/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	4		8/29/22, 11:59 PM		RSD/LOW SCHEDULE
RAICHUR TPS	4		7/10/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	4		8/26/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
RAICHUR TPS	4		7/11/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	4		7/2/22, 9:07 AM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	4		9/2/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	4		7/3/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	4		7/14/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	4		8/19/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	4		9/10/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	4		9/3/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	4		8/17/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	4		8/10/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	4		7/25/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	4		7/15/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	4		7/23/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	4		7/6/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	4		7/9/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	4		9/4/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	4		9/17/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	4		7/16/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	4		8/24/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	4		9/16/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	4		8/12/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	4		7/8/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	4		8/9/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	5		10/2/22, 11:59 PM		COAL FEEDING PROBLEM IN PLANT
RAICHUR TPS	5	210.0	8/22/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	5		7/7/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	5		7/22/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	5		8/19/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	5		7/23/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	5		7/26/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	5		7/25/22, 11:59 PM		RESERVE SHUT DOWN

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
RAICHUR TPS	5		8/11/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	5		10/5/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	5		7/11/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	5		8/23/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	5		9/29/22, 11:05 AM		FURNACE FIRE OUT /FLAME FAILURE
RAICHUR TPS	5		7/14/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	5		7/16/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	5		8/7/22, 3:30 PM		RESERVE SHUT DOWN
RAICHUR TPS	5		8/16/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	5		9/30/22, 11:59 PM		COAL FEEDING SYSTEM FAILURE.
RAICHUR TPS	5		8/21/22, 11:59 PM		RSD/LOW SCHEDULE
RAICHUR TPS	5		8/20/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	5		8/17/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	5		7/24/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	5		9/29/22, 11:59 PM		COAL FEEDING PROBLEM IN PLANT
RAICHUR TPS	5		7/8/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	5		8/13/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	5		7/17/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	5		7/15/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	5		8/24/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	5		7/9/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	5		8/8/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	5		8/9/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	5		8/14/22, 11:59 PM		RSD/LOW SCHEDULE
RAICHUR TPS	5		7/10/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	5		10/3/22, 1:00 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	5		8/10/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	5		7/7/22, 8:34 PM		RESERVE SHUT DOWN
RAICHUR TPS	5		6/24/22, 11:59 AM	26-06-2022	RSD/LOW SCHEDULE
RAICHUR TPS	5		8/12/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	5		8/25/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
RAICHUR TPS	5		8/18/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	6		8/23/22, 11:58 PM		RESERVE SHUT DOWN
RAICHUR TPS	6		8/16/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	6		7/14/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	6		7/17/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	6		9/9/22, 12:15 AM		RESERVE SHUT DOWN
RAICHUR TPS	6		7/10/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	6		8/8/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	6		9/10/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	6		8/13/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	6		7/9/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	6		9/9/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	6		7/11/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	6		7/23/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	6		7/8/22, 6:22 PM		RESERVE SHUT DOWN
RAICHUR TPS	6		8/17/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	6		7/15/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	6		7/8/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	6		8/14/22, 11:59 PM		RSD/LOW SCHEDULE
RAICHUR TPS	6		8/25/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	6		8/11/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	6		7/16/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	6		8/12/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	6		7/25/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	6		9/16/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	6		8/24/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	6		7/22/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	6		8/20/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	6		8/6/22, 11:24 AM		RESERVE SHUT DOWN
RAICHUR TPS	6		8/9/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	6		8/22/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
RAICHUR TPS	6		9/11/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	6		8/19/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	6		8/18/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	6		7/24/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	6		8/10/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	6		8/21/22, 11:59 PM		RSD/LOW SCHEDULE
RAICHUR TPS	6	210.0	8/2/22, 9:07 PM		Fuel System Abnormal/ Maintenance
RAICHUR TPS	7		7/22/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	7	210.0	7/25/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	7		8/21/22, 11:59 PM		RSD/LOW SCHEDULE
RAICHUR TPS	7		9/10/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	7		7/26/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	7		10/21/23, 5:27 PM	25-10-2023	WATER WALL TUBE LEAKAGE
RAICHUR TPS	7		8/7/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	7		8/22/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	7		8/24/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	7		8/13/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	7		8/4/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	7		9/16/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	7		7/7/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	7		6/29/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	7		8/18/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	7		8/25/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	7		7/9/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	7		7/15/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	7		8/11/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	7		8/3/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	7		8/1/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	7		7/29/22, 11:59 PM	30-07-2022	RSD/LOW SCHEDULE
RAICHUR TPS	7		8/19/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	7		7/1/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
RAICHUR TPS	7		6/30/22, 11:59 PM		RSD/LOW SCHEDULE
RAICHUR TPS	7		7/17/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	7		9/9/22, 12:27 AM		RESERVE SHUT DOWN
RAICHUR TPS	7		8/9/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	7		8/6/22, 11:59 PM		RSD/LOW SCHEDULE
RAICHUR TPS	7		7/11/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	7		7/31/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	7		7/14/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	7		7/30/22, 7:07 AM		RESERVE SHUT DOWN
RAICHUR TPS	7		7/6/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	7		7/10/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	7		7/27/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	7		9/11/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	7		7/2/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	7		8/14/22, 11:59 PM		ROTOR/ ROTOR EARTH FAULT
RAICHUR TPS	7		8/23/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	7		6/24/22, 12:07 PM	26-06-2022	RSD/LOW SCHEDULE
RAICHUR TPS	7		8/12/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	7		8/10/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	7		9/9/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	7		8/20/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	7		7/24/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	7		8/2/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	7		8/8/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	7		8/5/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	7		7/3/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	7		9/17/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	7		8/17/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	7		7/8/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	7		8/16/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	7		7/16/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
RAICHUR TPS	7		7/23/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	7		6/28/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	8		9/17/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	8		8/14/22, 11:59 PM		RSD/LOW SCHEDULE
RAICHUR TPS	8		10/2/22, 11:59 PM		COAL FEEDING PROBLEM IN PLANT
RAICHUR TPS	8		8/22/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	8		9/29/22, 11:59 PM		COAL FEEDING PROBLEM IN PLANT
RAICHUR TPS	8		7/25/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	8		8/24/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	8		8/11/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	8		7/14/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	8		8/6/22, 11:59 PM		RSD/LOW SCHEDULE
RAICHUR TPS	8		8/12/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	8		7/2/22, 10:29 AM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	8		7/10/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	8		7/7/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	8		8/18/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	8		8/25/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	8		9/28/22, 11:59 PM		COAL FEEDING SYSTEM NOT READY
RAICHUR TPS	8		9/27/22, 11:59 PM		COAL FEEDING PROBLEM IN PLANT
RAICHUR TPS	8		7/22/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	8		7/3/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	8		8/7/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	8		9/11/22, 1:12 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	8		7/6/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	8		9/16/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	8		8/16/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	8		8/20/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	8		8/8/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	8		8/17/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	8		7/24/22, 11:59 PM		LOW SYSTEM DEMAND

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
RAICHUR TPS	8		8/19/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	8		10/17/22, 10:00 AM		WATER WALL TUBE LEAKAGE
RAICHUR TPS	8		7/17/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	8		8/21/22, 11:59 PM		RSD/LOW SCHEDULE
RAICHUR TPS	8		8/23/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	8		6/24/22, 10:26 AM	26-06-2022	RSD/LOW SCHEDULE
RAICHUR TPS	8		8/13/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	8		7/9/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	8		7/11/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	8		5/6/23, 12:00 AM		BOILER AUX. MISC. PROMLEMS
RAICHUR TPS	8		10/3/22, 12:30 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	8		7/16/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	8		9/11/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	8		8/10/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	8		9/30/22, 11:59 PM		COAL FEEDING SYSTEM FAILURE.
RAICHUR TPS	8		7/15/22, 11:59 PM		LOW SYSTEM DEMAND
RAICHUR TPS	8		8/9/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	8		7/26/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	8	250.0	8/26/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	8		9/24/22, 12:19 PM		FURNACE FIRE OUT /FLAME FAILURE
RAICHUR TPS	8		7/23/22, 11:59 PM		RESERVE SHUT DOWN
RAICHUR TPS	8		7/2/22, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	8		7/8/22, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	8		8/5/22, 11:58 PM		RESERVE SHUT DOWN / STANDBY UNIT
BELLARY TPS	1		10/17/22, 4:29 AM		ASH HANDLING SYSTEM PROBLEM
BELLARY TPS	1		9/9/20, 12:00 AM	21-09-2020	BOILER OVERHAUL/ ANNUAL
BELLARY TPS	1	500.0	6/2/20, 1:44 PM		RSD/LOW SCHEDULE
BELLARY TPS	2		6/2/20, 4:31 PM		RSD/LOW SCHEDULE
BELLARY TPS	2		10/1/23, 11:31 PM		WATER WALL TUBE LEAKAGE
BELLARY TPS	2		12/26/20, 9:28 AM		RESERVE SHUT DOWN / STANDBY UNIT
BELLARY TPS	2	500.0	10/1/20, 12:00 AM	12-10-2020	SCHEDULED ANNUAL MAINTENANCE

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
BELLARY TPS	3	700.0	9/26/22, 8:50 PM		GENERATING UNIT SHUT DOWN
BELLARY TPS	3		9/9/22, 7:53 AM		WET / POOR QUALITY COAL
BELLARY TPS	3		5/19/22, 11:35 AM		REHEATER TUBE LEAKAGE
BELLARY TPS	3		1/20/24, 12:03 PM	24-01-2024	WATER WALL TUBE LEAKAGE
BELLARY TPS	3		9/29/23, 6:28 PM		TURBINE MISC. PROBLEMS
BELLARY TPS	3		9/19/22, 3:18 AM		SUPER HEATER TUBE LEAKAGE
BELLARY TPS	3		5/15/21, 8:45 AM		GENERATOR EARTH FAULT
YERMARUS TPP	1		3/4/23, 8:00 PM	09-03-2023	WATER WALL TUBE LEAKAGE
YERMARUS TPP	1	800.0	8/25/24, 8:17 AM		RESERVE SHUT DOWN / STANDBY UNIT
YERMARUS TPP	2	800.0	9/10/22, 1:51 PM		RESERVE SHUT DOWN
YERMARUS TPP	2		12/17/22, 7:14 AM	17-12-2022	FURNACE CLINKER FORMATION
ADANI POWER LIMITED UDUPI	1		8/27/21, 10:31 PM		COAL SHORTAGE
ADANI POWER LIMITED UDUPI	1		4/6/22, 12:08 AM		RSD/LOW SCHEDULE
ADANI POWER LIMITED UDUPI	1		12/6/22, 10:30 PM		RSD/LOW SCHEDULE
ADANI POWER LIMITED UDUPI	1	600.0	6/2/23, 8:30 AM		MISCELLANOUS
ADANI POWER LIMITED UDUPI	1		4/10/22, 11:55 AM		COAL SHORTAGE
ADANI POWER LIMITED UDUPI	1		7/6/23, 12:53 AM		COAL FEEDING PROBLEM IN PLANT
ADANI POWER LIMITED UDUPI	1		2/4/23, 10:42 AM	07-02-2023	MAIN STEAM LINE PROBLEM
ADANI POWER LIMITED UDUPI	1		12/21/22, 12:00 AM		OVERHAULING WORKS
ADANI POWER LIMITED UDUPI	1		7/5/23, 12:33 AM		RSD/LOW SCHEDULE
ADANI POWER LIMITED UDUPI	2		7/6/23, 12:53 AM		COAL FEEDING PROBLEM IN PLANT
ADANI POWER LIMITED UDUPI	2		4/10/22, 11:55 AM		COAL SHORTAGE
ADANI POWER LIMITED UDUPI	2		8/27/21, 9:49 PM		COAL SHORTAGE
ADANI POWER LIMITED UDUPI	2	600.0	3/16/23, 1:00 AM	23-03-2023	AIR PREHEATERS PROBLEM
COCHIN CCPP (Liq.)	1	0.0	10/15/15, 9:36 PM	07-10-2018	GT-NO SCHEDULE FROM
COCHIN CCPP (Liq.)	2	0.0	5/6/15, 7:58 PM	18-10-2018	GT-NO SCHEDULE FROM
COCHIN CCPP (Liq.)	3	0.0	5/6/15, 8:16 PM	27-10-2018	GT-NO SCHEDULE FROM
COCHIN CCPP (Liq.)	4	0.0	11/23/14, 11:05 PM	06-06-2017	GT-NO SCHEDULE FROM
R. GANDHI CCPP (Liq.)	1	115.2	3/12/22, 11:59 PM		RSD/LOW SCHEDULE
R. GANDHI CCPP (Liq.)	2	115.2	1/31/22, 8:01 PM		RSD/LOW SCHEDULE
R. GANDHI CCPP (Liq.)	3	129.18	5/1/21, 12:00 AM		RSD/LOW SCHEDULE

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
TUTICORIN TPS	1		10/20/23, 8:50 AM		BOILER AUX. MISC. PROMLEMS
TUTICORIN TPS	1		9/11/24, 8:30 AM		BOILER AUX. MISC. PROMLEMS
TUTICORIN TPS	1		3/18/23, 10:19 AM		BOILER AUX. MISC. PROMLEMS
TUTICORIN TPS	1		1/21/22, 12:14 PM		CONDENSER LOW VACCUM
TUTICORIN TPS	1		12/16/23, 7:20 PM	08-01-2024	BOILER MISC. PROBLEM
TUTICORIN TPS	1		9/14/22, 9:20 PM	15-09-2022	BOILER AUX. MISC. PROMLEMS
TUTICORIN TPS	1		3/10/23, 10:28 PM		BOILER AUX. MISC. PROMLEMS
TUTICORIN TPS	1		1/5/23, 9:12 AM		BOILER AUX. MISC. PROMLEMS
TUTICORIN TPS	1	210.0	11/20/23, 1:46 AM		MAL-FUNCTION OF RELAY
TUTICORIN TPS	1		4/12/24, 3:34 AM		BOILER AUX. MISC. PROMLEMS
TUTICORIN TPS	1		11/7/22, 4:20 AM		I.D. FANS PROBLEM
TUTICORIN TPS	1		5/7/22, 3:32 PM		BOILER MISC. PROBLEM
TUTICORIN TPS	1		9/4/22, 6:58 PM		BOILER AUX. MISC. PROMLEMS
TUTICORIN TPS	1		9/5/24, 9:13 PM		BOILER MISC. PROBLEM
TUTICORIN TPS	1		9/26/22, 12:05 AM	01-10-2022	BOILER INSPECTION/ RE-
TUTICORIN TPS	1		1/24/22, 5:28 PM	20-02-2022	SEAL OIL SYSTEM PROBLEM
TUTICORIN TPS	1		9/30/23, 6:22 PM		BOILER AUX. MISC. PROMLEMS
TUTICORIN TPS	1		9/25/22, 11:25 PM		RSD/LOW SCHEDULE
TUTICORIN TPS	1		11/17/22, 9:36 AM		BOILER AUX. MISC. PROMLEMS
TUTICORIN TPS	2		2/3/22, 10:22 PM	05-02-2022	F.D. FANS PROBLEM
TUTICORIN TPS	2		5/6/22, 9:19 PM		BOILER MISC. PROBLEM
TUTICORIN TPS	2		12/17/23, 8:09 PM	05-01-2024	RSD/LOW SCHEDULE
TUTICORIN TPS	2		8/30/22, 1:32 PM		BOILER AUX. MISC. PROMLEMS
TUTICORIN TPS	2		11/12/22, 6:33 AM		RESERVE SHUT DOWN
TUTICORIN TPS	2		4/21/22, 2:18 PM		BOILER MISC. PROBLEM
TUTICORIN TPS	2		10/1/22, 3:10 AM		RESERVE SHUT DOWN
TUTICORIN TPS	2		7/4/22, 4:30 PM		BOILER AUX. MISC. PROMLEMS
TUTICORIN TPS	2		5/14/23, 12:42 AM	14-05-2023	GENERATOR EARTH FAULT
TUTICORIN TPS	2		4/29/22, 10:37 PM		VARIOUS STEAM LEAKAGES
TUTICORIN TPS	2		2/25/22, 9:33 AM		TURBINE CONTROL VALVE PROBLEM
TUTICORIN TPS	2		5/3/22, 10:45 PM		TURBINE CONTROL VALVE PROBLEM

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
TUTICORIN TPS	2		11/23/22, 3:23 PM		CONDENSER TUBE LEAKAGE/
TUTICORIN TPS	2	210.0	4/16/24, 12:13 AM		AIR PREHEATERS PROBLEM
TUTICORIN TPS	2		10/24/21, 8:19 AM		BOILER MISC. PROBLEM
TUTICORIN TPS	2		10/13/22, 12:01 PM		ASH HANDLING SYSTEM PROBLEM
TUTICORIN TPS	2		11/23/22, 12:20 PM		RESERVE SHUT DOWN / STANDBY UNIT
TUTICORIN TPS	2		4/4/23, 1:08 AM	05-04-2023	BOILER AUX. MISC. PROMLEMS
TUTICORIN TPS	2		11/19/22, 12:07 PM	22-11-2022	TURBINE CONTROL VALVE PROBLEM
TUTICORIN TPS	2		12/8/23, 1:20 PM	09-12-2023	I.D. FANS PROBLEM
TUTICORIN TPS	2		6/18/23, 12:58 AM		I.D. FANS PROBLEM
TUTICORIN TPS	2		1/24/21, 7:18 AM	28-01-2021	FUEL OIL PROBLEM
TUTICORIN TPS	2		11/17/21, 7:13 PM		BOILER MISC. PROBLEM
TUTICORIN TPS	2		12/16/21, 4:17 AM		BOILER MISC. PROBLEM
TUTICORIN TPS	2		5/19/24, 12:37 AM		FURNACE DRAFT ABNORMAL
TUTICORIN TPS	2		11/6/22, 7:22 AM		WET / POOR QUALITY COAL
TUTICORIN TPS	2		11/12/22, 9:00 AM		GEN. COOLING SYSTEM MISC. /
TUTICORIN TPS	2		11/12/21, 1:18 PM		BOILER MISC. PROBLEM
TUTICORIN TPS	2		10/15/22, 9:18 PM		BOILER AUX. MISC. PROMLEMS
TUTICORIN TPS	2		4/16/24, 6:00 AM		RESERVE SHUT DOWN
TUTICORIN TPS	2		7/30/22, 12:09 PM		BOILER AUX. MISC. PROMLEMS
TUTICORIN TPS	2		1/15/23, 9:30 AM		HRH LINE LEAKAGE
TUTICORIN TPS	2		8/14/22, 9:50 AM		BOILER AUX. MISC. PROMLEMS
TUTICORIN TPS	3		6/20/22, 4:53 AM		BOILER AUX. MISC. PROMLEMS
TUTICORIN TPS	3	210.0	11/11/22, 10:47 AM		GEN. COOLING SYSTEM FAILURE
TUTICORIN TPS	3		12/27/22, 9:18 PM		BOILER MISC. PROBLEM
TUTICORIN TPS	3		7/3/22, 12:51 PM		RSD/LOW SCHEDULE
TUTICORIN TPS	3		12/12/21, 8:15 AM		FURNACE DRAFT ABNORMAL
TUTICORIN TPS	3		5/29/23, 3:29 PM	31-05-2023	TURBINE CONTROL VALVE PROBLEM
TUTICORIN TPS	3		4/19/24, 7:32 AM		BOILER AUX. MISC. PROMLEMS
TUTICORIN TPS	3		10/26/21, 2:07 PM		BOILER MISC. PROBLEM
TUTICORIN TPS	3		4/13/22, 10:32 PM		WATER WALL TUBE LEAKAGE
TUTICORIN TPS	3		11/4/22, 10:08 AM		WET / POOR QUALITY COAL

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
TUTICORIN TPS	3		3/12/23, 11:07 AM		RESERVE SHUT DOWN
TUTICORIN TPS	3		11/12/21, 7:53 PM		HRH LINE LEAKAGE
TUTICORIN TPS	3		6/26/24, 6:14 PM		BOILER AUX. MISC. PROMLEMS
TUTICORIN TPS	3		8/25/24, 12:05 PM		ANNUAL MAINTENANCE
TUTICORIN TPS	3		11/15/22, 10:08 AM		WET / POOR QUALITY COAL
TUTICORIN TPS	3		9/10/23, 6:39 PM		PRESSURE RELIEF VALVE PROBLEM
TUTICORIN TPS	3		9/30/23, 9:53 AM		RESERVE SHUT DOWN
TUTICORIN TPS	3		9/16/22, 7:25 PM		GENERATOR EARTH FAULT
TUTICORIN TPS	3		8/18/22, 8:55 AM		BOILER AUX. MISC. PROMLEMS
TUTICORIN TPS	3		9/24/23, 10:05 AM		MILLING SYSTEM /RC FEEDER
TUTICORIN TPS	3		11/21/22, 2:42 PM		WET / POOR QUALITY COAL
TUTICORIN TPS	3		4/8/21, 3:43 AM		GRID DISTURBANCE
TUTICORIN TPS	3		5/30/22, 7:13 PM	01-06-2022	WATER WALL TUBE LEAKAGE
TUTICORIN TPS	3		11/14/21, 4:12 AM		BOILER MISC. PROBLEM
TUTICORIN TPS	3		1/22/22, 3:37 AM		BOILER AUX. MISC. PROMLEMS
TUTICORIN TPS	3		5/18/22, 7:29 PM		BOILER MISC. PROBLEM
TUTICORIN TPS	3		6/17/22, 5:00 PM	18-06-2022	WATER WALL TUBE LEAKAGE
TUTICORIN TPS	4		1/16/23, 2:34 PM		BOILER AUX. MISC. PROMLEMS
TUTICORIN TPS	4		8/27/22, 3:21 PM		BOILER AUX. MISC. PROMLEMS
TUTICORIN TPS	4		5/11/23, 7:27 PM		CONDENSER TUBE LEAKAGE/
TUTICORIN TPS	4		11/8/22, 9:19 AM		BOILER AUX. MISC. PROMLEMS
TUTICORIN TPS	4		12/28/22, 9:22 PM		TURBINE MISC. PROBLEM
TUTICORIN TPS	4	210.0	1/6/22, 7:06 PM		BOILER AUX. MISC. PROMLEMS
TUTICORIN TPS	4		6/30/22, 8:30 AM		RESERVE SHUT DOWN
TUTICORIN TPS	4		5/20/24, 10:48 AM		RESERVE SHUT DOWN
TUTICORIN TPS	4		11/13/21, 12:06 PM		BOILER MISC. PROBLEM
TUTICORIN TPS	4		11/9/21, 11:42 AM		BOILER MISC. PROBLEM
TUTICORIN TPS	4		7/11/22, 1:52 PM		TURBINE MISC. PROBLEM
TUTICORIN TPS	4		9/1/22, 7:14 PM		BOILER AUX. MISC. PROMLEMS
TUTICORIN TPS	4		5/22/24, 11:30 AM	26-05-2024	BOILER AUX. MISC. PROMLEMS
TUTICORIN TPS	4		7/9/22, 10:43 PM		RESERVE SHUT DOWN

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
TUTICORIN TPS	4		12/20/22, 10:15 PM	21-12-2022	Fuel Shortage
TUTICORIN TPS	5		12/4/23, 9:18 AM		HYDROGEN PRESSURE PROBLEM
TUTICORIN TPS	5		7/6/23, 3:34 AM		BOILER AUX. MISC. PROMLEMS
TUTICORIN TPS	5		6/5/22, 12:12 AM		BOILER MISC. PROBLEM
TUTICORIN TPS	5		8/16/22, 12:02 PM		BOILER AUX. MISC. PROMLEMS
TUTICORIN TPS	5		3/1/23, 11:30 AM	02-03-2023	BOILER AUX. MISC. PROMLEMS
TUTICORIN TPS	5	210.0	10/22/22, 11:17 PM	27-10-2022	BOILER INSPECTION/ RE-
TUTICORIN TPS	5		5/5/24, 8:07 AM		RESERVE SHUT DOWN
TUTICORIN TPS	5		12/5/21, 12:30 AM	07-12-2021	BOILER AUX. MISC. PROMLEMS
TUTICORIN TPS	5		12/26/22, 8:46 PM		MAIN STEAM LINE PROBLEM
TUTICORIN TPS	5		11/6/22, 7:36 AM		WET / POOR QUALITY COAL
TUTICORIN TPS	5		8/30/22, 12:40 PM		BOILER AUX. MISC. PROMLEMS
TUTICORIN TPS	5		5/29/22, 8:10 AM	01-06-2022	TURBINE MISC. PROBLEM
TUTICORIN TPS	5		12/6/22, 11:37 AM		BOILER AUX. MISC. PROMLEMS
TUTICORIN TPS	5		1/13/22, 6:16 AM		CONDENSER TUBE LEAKAGE/
TUTICORIN TPS	5		5/27/24, 7:49 AM	28-05-2024	HYDROGEN PRESSURE PROBLEM
TUTICORIN TPS	5		6/8/24, 7:53 AM		RESERVE SHUT DOWN
TUTICORIN TPS	5		10/14/22, 6:18 PM		BOILER AUX. MISC. PROMLEMS
TUTICORIN TPS	5		7/2/23, 1:16 AM		TURBINE CONTROL VALVE PROBLEM
TUTICORIN TPS	5		5/6/22, 12:00 AM		BOILER MISC. PROBLEM
TUTICORIN TPS	5		11/10/22, 12:18 AM		BOILER MISC. PROBLEM
TUTICORIN TPS	5		11/12/22, 11:29 PM		MAIN STEAM LINE PROBLEM
METTUR TPS - II	1	600.0	5/16/24, 11:56 AM		WATER WALL TUBE LEAKAGE
METTUR TPS - II	1		4/15/21, 6:11 AM		RESERVE SHUT DOWN
METTUR TPS - II	1		8/1/20, 10:56 AM	15-08-2020	Low system demand/ costly fuel
BASIN BRIDGE GT (Liq.)	1	30.0	4/26/17, 10:25 PM		GT-MISCELLANEOUS PROBLEMS
BASIN BRIDGE GT (Liq.)	2	30.0	4/26/17, 10:25 PM		GT/WHRB/ST PLANNED OVERHAUL
BASIN BRIDGE GT (Liq.)	3	30.0	4/26/17, 10:20 PM		GT/WHRB/ST PLANNED OVERHAUL
VALUTHUR CCPP	1	60.0	11/27/19, 3:00 PM		TRANSMISSION CONSTRAINTS/
VALUTHUR CCPP	3	59.8	1/18/23, 1:46 PM	19-01-2023	MISCELLANEOUS PLANNED
KOVIKALPAL CCPP	1	69.65	7/31/23, 11:50 PM		FUEL SUPPLY & OTHER MISC.

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
KOVIKALPAL CCPP	2	38.23	7/30/23, 8:00 AM		WATER NON AVAILABILITY
P.NALLUR CCPP	1	330.5	5/1/22, 12:00 AM		GT-NO SCHEDULE FROM
VALANTARVY CCPP	1	0.0	7/1/21, 12:00 PM	01-01-2022	UPRATING
VALANTARVY CCPP	2	0.0	7/1/21, 12:00 AM	01-01-2022	UPRATING
KARUPPUR CCPP	1		10/30/22, 12:05 AM		Fuel Shortage
KARUPPUR CCPP	1		3/17/21, 12:00 AM	18-03-2021	EXTENDED ANNUAL MAINTENANCE
KARUPPUR CCPP	1	0.0	11/4/21, 12:02 AM	10-11-2021	GT-PROTECTION /INTERLOCK /RELAY
KARUPPUR CCPP	2	0.0	3/27/21, 12:00 AM	18-04-2021	ANNUAL MAINTENANCE
KARUPPUR CCPP	2		11/4/21, 12:00 AM	10-11-2021	GT-PROTECTION /INTERLOCK /RELAY
KARUPPUR CCPP	2		10/30/22, 12:02 AM		Fuel Shortage
KARUPPUR CCPP	2		4/18/21, 10:00 AM	19-04-2021	EXTENDED ANNUAL MAINTENANCE
TUTICORIN (P) TPP	1	150.0	4/3/16, 12:31 AM	14-10-2018	No Fuel Supply Agreement
TUTICORIN (P) TPP	2	150.0	4/16/16, 1:42 AM	06-10-2018	No Fuel Supply Agreement
NEYVELI TPS-II	1	210.0	7/1/23, 8:45 PM		MISCELLANEOUS
NEYVELI TPS-II	2	210.0	7/26/24, 11:50 PM		ANNUAL MAINTENANCE
NEYVELI TPS-II	4	210.0	11/15/20, 12:28 PM	15-11-2020	TURBINE MISC. PROBLEMS
NEYVELI TPS-II	6	210.0	6/10/23, 8:59 PM		I.D. FANS PROBLEM
NEYVELI TPS-II EXP	1	250.0	9/4/24, 7:04 PM		FUEL SUPPLY & OTHER MISC.
VALLUR TPP	1		4/9/20, 3:26 PM		GEN. TRANSFORMER TRIPPING/
VALLUR TPP	1		11/25/20, 11:50 AM		FLOODS
VALLUR TPP	1	500.0	9/3/20, 7:00 PM		PIPES and VALVES BOILER SIDE
VALLUR TPP	1		8/29/20, 10:01 PM		RESERVE SHUT DOWN / STANDBY UNIT
VALLUR TPP	1		2/6/21, 11:14 AM		WATER WALL TUBE LEAKAGE
VALLUR TPP	2		12/22/20, 9:05 AM		WATER WALL TUBE LEAKAGE
VALLUR TPP	2	500.0	11/25/20, 4:40 PM		FLOODS
VALLUR TPP	2		7/22/20, 8:30 PM	21-08-2020	RSD/LOW SCHEDULE
VALLUR TPP	2		9/8/20, 5:00 AM		RESERVE SHUT DOWN / STANDBY UNIT
VALLUR TPP	2		9/19/20, 3:00 PM		BOILER INSPECTION/ RE-
VALLUR TPP	2		7/11/20, 12:18 AM		RESERVE SHUT DOWN / STANDBY UNIT
VALLUR TPP	2		11/2/22, 12:22 AM		WET / POOR QUALITY COAL
VALLUR TPP	2		9/3/20, 7:00 PM		PIPES and VALVES BOILER SIDE

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
VALLUR TPP	2		9/2/20, 7:29 AM		RESERVE SHUT DOWN / STANDBY UNIT
VALLUR TPP	3		9/3/20, 5:31 PM		PIPES and VALVES BOILER SIDE
VALLUR TPP	3		8/4/20, 11:30 AM		BOILER INSPECTION/ RE-
VALLUR TPP	3	500.0	7/29/20, 11:10 AM		RESERVE SHUT DOWN / STANDBY UNIT
VALLUR TPP	3		3/5/21, 3:39 PM		LABOUR PROBLEM
VALLUR TPP	3		11/25/20, 7:36 PM		FLOODS
MADRAS A.P.S.	1	220.0	1/30/18, 4:30 PM		REACTOR MAINTENANCE WORKS.
ITPCL TPP	1	600.0	5/10/21, 2:34 AM		RSD/LOW SCHEDULE
ITPCL TPP	1		6/1/20, 1:23 AM		RESERVE SHUT DOWN / STANDBY UNIT
ITPCL TPP	1		5/17/22, 2:29 PM		WATER WALL TUBE LEAKAGE
ITPCL TPP	2		7/5/23, 12:00 AM		OVERHAULING WORKS
ITPCL TPP	2	600.0	7/16/20, 12:56 AM		SCHEDULED ANNUAL MAINTENANCE
ITPCL TPP	2		1/29/22, 11:50 PM		FUND PROBLEM
ITPCL TPP	2		7/17/21, 12:39 AM	13-08-2021	SCHEDULED ANNUAL MAINTENANCE
ITPCL TPP	2		7/1/23, 2:35 AM		RSD/LOW SCHEDULE
ITPCL TPP	2		11/12/23, 12:23 AM	14-11-2023	RESERVE SHUT DOWN
TCP Limited	1	63.5	7/16/21, 5:21 AM		MISCELLANEOUS PLANNED
BARAUNI TPS	6		6/15/23, 3:37 PM	17-06-2023	WATER WALL TUBE LEAKAGE
BARAUNI TPS	6	0.0	7/22/23, 12:05 PM		UNIT LIKELY TO BE SCRAPPED.
BARAUNI TPS	7	0.0	7/19/23, 3:30 PM		UNIT LIKELY TO BE SCRAPPED.
BARAUNI TPS	8		3/13/24, 12:55 PM		MISCELLANOUS
BARAUNI TPS	8	250.0	5/22/21, 9:45 PM	24-05-2021	WATER WALL TUBE LEAKAGE
MUZAFFARPUR TPS	4		6/25/22, 2:00 AM		MAIN INLET VALVE PROBLEM
MUZAFFARPUR TPS	4	195.0	6/23/22, 9:35 AM		SUPER HEATER TUBE LEAKAGE
BARH STPS	5	660.0	5/25/21, 5:16 AM	27-05-2021	WATER WALL TUBE LEAKAGE
NABINAGAR TPP	1	250.0	9/15/24, 4:56 AM	17-09-2024	GENERATOR STATOR DAMAGED
NABINAGAR TPP	2	250.0	2/23/20, 12:00 AM	24-02-2020	BOILER AUX. MISC. PROMLEMS
NABINAGAR TPP	3	250.0	1/21/23, 3:13 PM		ABNORMAL SOUND
KAHALGAON TPS	3	210.0	3/28/24, 4:13 AM	29-03-2024	C&I PROBLEM
MEJIA TPS	1		9/5/20, 5:00 PM		WATER WALL TUBE LEAKAGE
MEJIA TPS	1		8/20/20, 9:40 AM		WATER WALL TUBE LEAKAGE

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
MEJIA TPS	1	210.0	9/26/20, 12:00 AM		Low system demand/ costly fuel
MEJIA TPS	1		10/31/19, 5:54 PM		WATER WALL TUBE LEAKAGE
MEJIA TPS	2		9/22/19, 3:41 PM		COAL SHORTAGE
MEJIA TPS	2		7/3/22, 8:15 AM		FURNACE FIRE OUT /FLAME FAILURE
MEJIA TPS	2		8/18/19, 4:45 PM		WATER WALL TUBE LEAKAGE
MEJIA TPS	2		10/23/22, 12:59 PM		FURNACE FIRE OUT /FLAME FAILURE
MEJIA TPS	2	210.0	8/22/19, 11:15 PM		Coal Transportation Problems
MEJIA TPS	2		8/14/19, 6:58 PM		WATER WALL TUBE LEAKAGE
MEJIA TPS	3		10/22/22, 1:12 AM	23-10-2022	WATER WALL TUBE LEAKAGE
MEJIA TPS	3	210.0	8/11/22, 7:02 PM		FURNACE FIRE OUT /FLAME FAILURE
MEJIA TPS	3		8/15/22, 7:27 PM		EHT/CT/PT/FAULT /BROBLEM
MEJIA TPS	4	210.0	9/6/19, 10:58 PM		BOILER INSPECTION/ RE-
MEJIA TPS	5	250.0	12/14/19, 11:47 PM		BOILER INSPECTION/ RE-
MEJIA TPS	6		6/17/22, 3:30 PM		RESERVE SHUT DOWN
MEJIA TPS	6	250.0	9/13/19, 12:31 AM		WATER WALL TUBE LEAKAGE
MEJIA TPS	7		9/17/19, 4:30 PM		ECONOMISER TUBE LEAKAGE
MEJIA TPS	7	500.0	9/9/19, 12:00 AM		ECONOMISER TUBE LEAKAGE
MEJIA TPS	7		9/15/19, 11:59 PM		COAL SHORTAGE
MEJIA TPS	8		7/27/20, 5:19 PM		TURBINE OIL SYSTEM PROBLEM
MEJIA TPS	8	500.0	10/26/22, 9:55 PM		BOILER AUX. MISC. PROMLEMS
DURGAPUR STEEL TPS	1	500.0	4/6/20, 3:06 PM		Low system demand/ costly fuel
IB VALLEY TPS	3	660.0	9/23/23, 12:42 AM		BOILER OVERHAUL/ ANNUAL
JSW Energy Utkal Limited	1	350.0	2/29/16, 12:13 AM		TRANSMISSION CONSTRAINTS
KASBA GT (Liq.)	1	0.0	6/26/02, 12:00 AM		UNECONOMICAL OPERATION
KASBA GT (Liq.)	2	0.0	6/25/02, 12:00 AM		UNECONOMICAL OPERATION
HALDIA GT (Liq.)	1	0.0	6/17/02, 12:00 AM		UNECONOMICAL OPERATION
HALDIA GT (Liq.)	2	0.0	9/21/88, 12:00 AM		UNECONOMICAL OPERATION
D.P.L. TPS	7	300.0	9/14/23, 6:00 PM	13-10-2023	COAL SHORTAGE
D.P.L. TPS	7		9/29/23, 1:11 PM		BOILER INSPECTION/ RE-
D.P.L. TPS	7		8/9/20, 10:00 AM	19-08-2020	I.D. FANS PROBLEM
TITAGARH TPS	1	0.0	10/10/16, 4:57 AM	11-10-2018	RESERVE SHUT DOWN / STANDBY UNIT

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
TITAGARH TPS	2	0.0	10/9/16, 4:57 AM	10-10-2018	RESERVE SHUT DOWN / STANDBY UNIT
TITAGARH TPS	3	0.0	10/10/16, 4:18 AM	11-10-2018	RESERVE SHUT DOWN / STANDBY UNIT
TITAGARH TPS	4	0.0	10/9/16, 5:36 AM	10-10-2018	RESERVE SHUT DOWN / STANDBY UNIT
FARAKKA STPS	5	500.0	7/1/24, 1:02 AM	18-08-2024	CONSERVATION OF MAIN FUEL/RSD
NAMRUP CCPP	2		10/7/22, 9:52 PM		SEAL OIL SYSTEM PROBLEM
NAMRUP CCPP	2		7/7/22, 7:15 AM		Fuel Shortage
NAMRUP CCPP	2		11/30/22, 3:35 PM		REVERSE POWER RELAY OPERATION
NAMRUP CCPP	2		5/27/22, 12:30 PM		LOW SYSTEM DEMAND
NAMRUP CCPP	2		2/4/22, 1:38 PM		Fuel Shortage
NAMRUP CCPP	2		12/3/21, 11:08 AM		GRID SYSTEM PROBLEMS
NAMRUP CCPP	2		9/2/23, 3:05 PM		EXCT. FAIL/LOSS OF EXCITATION
NAMRUP CCPP	2		12/18/21, 12:00 AM		OIL LEAKAGE PROBLEM
NAMRUP CCPP	2		1/28/22, 8:25 PM		INSTRUMENTATION PROBLEM
NAMRUP CCPP	2		5/25/22, 8:20 PM		LUBRICATING OIL PUMP/SYSTEM MISC
NAMRUP CCPP	2		1/28/22, 12:00 AM		FUEL SUPPLY & OTHER MISC.
NAMRUP CCPP	2		5/6/20, 8:15 PM		Electrical Scheduled Maitenance
NAMRUP CCPP	2		8/23/22, 4:46 AM		VIBRATIONS
NAMRUP CCPP	2		2/4/22, 9:28 AM		GRID MISCELLANEOUS
NAMRUP CCPP	2		3/22/22, 12:00 AM	22-03-2022	Instrument air system Failure
NAMRUP CCPP	2		8/23/22, 4:42 AM		GRID DISTURBANCE
NAMRUP CCPP	2	17.0	7/17/24, 11:15 AM		GENEATOR PROTECTION MISC/BACK
NAMRUP CCPP	3		8/16/24, 9:46 AM		MISCELLANEOUS PLANNED
NAMRUP CCPP	3		6/4/23, 10:48 PM		TURBINE BEARING COOLING SYS/OIL
NAMRUP CCPP	3		8/3/22, 8:37 AM		FUEL SUPPLY & OTHER MISC.
NAMRUP CCPP	3		2/5/24, 9:16 AM		GRID MISCELLANEOUS
NAMRUP CCPP	3		7/13/21, 1:55 PM	30-07-2021	ELECTRICAL MISCELLANEOUS
NAMRUP CCPP	3		5/8/22, 9:17 AM		C&I PROBLEM
NAMRUP CCPP	3		1/28/22, 8:25 PM		ELECTRICAL MISCELLANEOUS
NAMRUP CCPP	3		10/3/22, 4:13 PM		GRID DISTURBANCE
NAMRUP CCPP	3		6/2/22, 1:05 PM		GRID DISTURBENCE
NAMRUP CCPP	3		1/22/22, 10:40 PM		Fuel Shortage

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
NAMRUP CCPP	3		1/8/22, 11:15 PM		GRID MISCELLANEOUS
NAMRUP CCPP	3	15.0	2/13/22, 11:40 PM		Fuel Shortage
NAMRUP CCPP	3		8/16/24, 5:00 PM		WATER SHORTAGE DUE TO INTERNAL
NAMRUP CCPP	3		2/14/22, 9:30 AM		FUEL SUPPLY & OTHER MISC.
NAMRUP CCPP	3		11/24/21, 10:43 AM	26-11-2021	GRID MISCELLANEOUS
NAMRUP CCPP	6	9.0	8/16/24, 9:30 AM		MISCELLANEOUS PLANNED
NAMRUP CCPP	6		8/23/22, 4:42 AM		GRID DISTURBANCE
NAMRUP CCPP	6		12/9/21, 5:05 AM		CONDENSER LOW VACCUM
NAMRUP CCPP	6		10/23/22, 10:43 AM		Fuel Shortage
NAMRUP CCPP	6		4/17/22, 7:45 PM		AIR COMRESSORS FAILURE AND
NAMRUP CCPP	8	36.15	9/21/21, 12:00 AM	21-09-2021	GT HIGH VIBRATIONS
LAKWA GT	5		9/2/19, 12:00 AM	17-09-2019	FUEL SUPPLY & OTHER MISC.
LAKWA GT	5		7/24/19, 12:00 AM	28-07-2019	MISC. SHORT DURATION
LAKWA GT	5		8/28/19, 12:00 AM	17-09-2019	Fuel Shortage
LAKWA GT	5		5/10/19, 12:00 AM	12-05-2019	GT-MISCELLANEOUS PROBLEMS
LAKWA GT	5		12/7/23, 12:00 AM		SWITCH YARD/TRIPPING OF
LAKWA GT	5		12/25/19, 12:00 AM	14-01-2020	MISCELLANEOUS PLANNED
LAKWA GT	5	20.0	9/18/19, 12:00 AM	30-09-2019	Fuel Shortage
LAKWA GT	5		3/23/19, 12:00 AM	25-03-2019	FUEL SUPPLY & OTHER MISC.
LAKWA GT	5		9/18/19, 9:01 AM	24-09-2019	MISC. SHORT DURATION
LAKWA GT	6		1/8/20, 12:00 AM	14-01-2020	MISC. SHORT DURATION
LAKWA GT	6	20.0	2/3/24, 12:00 AM	04-02-2024	MISCELLANEOUS
LAKWA GT	7		10/18/23, 12:00 AM		BUS PROTECTION TRIP
LAKWA GT	7		4/8/24, 5:08 PM	20-04-2024	VIBRATIONS
LAKWA GT	7	20.0	2/4/23, 9:47 PM	05-02-2023	Fuel Shortage
LAKWA GT	7		4/19/21, 12:00 AM		GEN. TRANSORMER PROTECTION
LAKWA GT	7		1/6/20, 12:00 AM	08-01-2020	MINOR MAINTENANCE WORKS
LAKWA REPLACEMENT POWER	1	9.965	5/21/24, 1:00 AM		GRID DISTURBANCE
LAKWA REPLACEMENT POWER	1		5/20/24, 9:40 PM		Fuel Shortage
LAKWA REPLACEMENT POWER	3	9.965	6/7/24, 10:14 AM		GRID DISTURBANCE
LAKWA REPLACEMENT POWER	3		12/11/21, 11:38 PM	12-12-2021	GRID MISCELLANEOUS

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
LAKWA REPLACEMENT POWER	4		5/28/24, 9:00 PM		Fuel Shortage
LAKWA REPLACEMENT POWER	4	9.965	7/16/24, 10:26 AM		GRID DISTURBANCES MISC.
LAKWA REPLACEMENT POWER	5		6/6/24, 9:38 AM		GRID DISTURBANCE
LAKWA REPLACEMENT POWER	5		3/7/20, 9:13 PM		FUEL SUPPLY & OTHER MISC.
LAKWA REPLACEMENT POWER	5	9.965	6/6/24, 8:53 AM		Fuel Shortage
LAKWA REPLACEMENT POWER	6		7/16/24, 5:10 PM		GRID DISTURBANCES MISC.
LAKWA REPLACEMENT POWER	6		7/16/24, 7:00 PM		Fuel Shortage
LAKWA REPLACEMENT POWER	6		7/16/24, 1:25 PM		MISCELLANEOUS
LAKWA REPLACEMENT POWER	6		7/17/24, 2:00 AM		GRID DISTURBANCES MISC.
LAKWA REPLACEMENT POWER	6	9.965	2/8/23, 4:44 PM	10-02-2023	MISCELLANEOUS
LAKWA REPLACEMENT POWER	6		9/14/21, 1:29 PM		FUEL OIL PROBLEM
LAKWA REPLACEMENT POWER	6		2/8/23, 11:12 AM		Fuel Shortage
LAKWA REPLACEMENT POWER	7		6/28/24, 10:30 PM		GRID DISTURBANCES MISC.
LAKWA REPLACEMENT POWER	7		5/14/24, 2:55 PM		MISCELLANOUS
LAKWA REPLACEMENT POWER	7		6/15/24, 10:53 AM		GRID DISTURBANCES MISC.
LAKWA REPLACEMENT POWER	7	9.965	6/15/24, 7:00 PM		MISCELLANEOUS
LAKWA REPLACEMENT POWER	7		2/20/19, 12:00 AM		FUEL SUPPLY & OTHER MISC.
KATHALGURI CCPP	1		1/12/23, 10:00 AM		MISCELLANEOUS
KATHALGURI CCPP	1	33.5	1/11/23, 3:50 PM		Fuel Shortage
KATHALGURI CCPP	2	33.5	1/4/23, 4:36 PM		MISCELLANEOUS PLANNED
KATHALGURI CCPP	3	33.5	5/27/23, 12:48 PM		MISCELLANEOUS
KATHALGURI CCPP	3		1/9/23, 11:43 AM		MISCELLANEOUS
ROKHIA GT	7	21.0	12/24/19, 12:00 AM	24-12-2019	GT-EXHAUST HIGH TEMPERATURE
MONARCHAK CCPP	1	65.4	1/5/24, 11:00 AM		MISCELLANEOUS
MONARCHAK CCPP	1		4/6/23, 12:35 PM		MISCELLANEOUS
MONARCHAK CCPP	1		10/17/23, 11:16 PM		MISCELLANEOUS
MONARCHAK CCPP	2	35.6	10/17/23, 11:13 PM	18-10-2023	MISCELLANEOUS

Total	62,732.60			
-------	-----------	--	--	--

Remarks:-

Report Version :-