

CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION

RECOMMISSIONNING OF THERMAL/NUCLEAR UNITS AS: 15-Oct-2025

Sub - Report 14

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
INDIRA GANDHI STPP	3	500.0	10/15/25, 4:26 PM		MAL-FUNCTION OF RELAY
KOTA TPS	6	195.0	10/12/25, 10:08 AM		RESERVE SHUT DOWN / STANDBY UNIT
SURATGARH TPS	3	250.0	11/28/24, 1:48 PM		FUEL SUPPLY & OTHER MISC. PROBLEMS
JALIPA KAPURDI TPP	1	135.0	10/15/25, 11:12 AM		BOILER MISC. PROBLEM
JALIPA KAPURDI TPP	5	135.0	10/11/25, 6:06 PM		BOILER MISC. PROBLEM
ADANI POWER LIMITED KAWAI TPP	2	660.0	10/5/25, 1:10 AM		TURBINE OIL SYSTEM PROBLEM
CHHABRA-I PH-1 TPP	2	250.0	10/14/25, 11:14 AM		ABNORMAL SOUND
OBRA TPS	9	200.0	10/15/25, 5:22 PM		CONDENSER LOW VACCUM
OBRA TPS	9		10/15/25, 2:21 PM		CONDENSER LOW VACCUM
UNCHAHAR TPS	2	210.0	9/12/25, 12:53 AM		OVERHAULING WORKS
AURAIYA CCPP	1	111.19	10/14/25, 7:44 PM		CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	2	111.19	10/14/25, 7:43 PM		CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	1	130.19	10/14/25, 7:56 PM		CONSERVATION OF MAIN FUEL/RSD
BALCO TPS	2	300.0	10/15/25, 3:54 PM		TURBINE MISC.
UCHPINDA TPP	4	360.0	10/15/25, 8:53 AM		UNIT AUX. TRANSFORMER PROBLEM
GANDHAR CCPP	2	144.3	10/14/25, 8:00 PM		CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	3	144.3	10/14/25, 8:08 PM		CONSERVATION OF MAIN FUEL/RSD
NASIK TPS	3	210.0	10/8/25, 9:15 AM		WATER WALL TUBE LEAKAGE
PARLI TPS	6	250.0	10/1/25, 1:35 AM		RSD/LOW SCHEDULE
CHANDRAPUR(MAHARASHTRA) STPS	3	210.0	10/13/25, 9:22 AM		WATER WALL TUBE LEAKAGE
NORTH CHENNAI TPS	1	210.0	10/14/25, 9:00 PM		MISC. FIRE HAZARDS / CABLE GALLERY
OPG Power Generation Private Limited	2	77.0	10/14/25, 11:59 PM		RSD/LOW SCHEDULE
NABINAGAR STPP	3	660.0	10/15/25, 3:42 AM		ECONOMISER TUBE LEAKAGE
KAHALGAON TPS	2	210.0	10/12/25, 11:24 PM		CONDENSER LOW VACCUM
FARAKKA STPS	4	500.0	10/14/25, 8:18 AM		P.A. FANS PROBLEM
TENUGHAT TPS	1	210.0	10/14/25, 9:28 PM		STATOR/ STATOR EARTH FAULT
IB VALLEY TPS	3	660.0	10/11/25, 11:28 AM		CONDENSER TUBE LEAKAGE/ CLEANING
AGARTALA GT	2	21.0	10/15/25, 12:00 AM		Fuel Shortage
LAKWA REPLACEMENT POWER PROJECT	3	9.965	10/15/25, 6:00 PM		MISC. SHORT DURATION MAINTENANCE

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
KATHALGURI CCPP	5	33.5	10/15/25, 8:23 PM		MINOR MAINTENANCE WORKS
KATHALGURI CCPP	6	33.5	10/15/25, 12:00 AM		MISCELLANEOUS PLANNED MAINTENANCE
KATHALGURI CCPP	7	30.0	10/15/25, 12:00 AM		MISC. SHORT DURATION MAINTENANCE
Total		7161.14			

Remarks:-

Report Version :-