

CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION

THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 15-Oct-2025

Sub - Report 15

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
TALWANDI SABO TPP	3	660.00	10/15/25, 9:16 AM		ABNORMAL BOILER OPERATIONAL PARAMETER
INDIRA GANDHI STPP	3	500.00	10/15/25, 4:26 PM	2025-10-15 21:06:00	MAL-FUNCTION OF RELAY
RAJASTHAN A.P.S.	4	220.00	10/15/25, 12:00 AM		Miscellaneous
JALIPA KAPURDI TPP	1	135.00	10/15/25, 11:12 AM	2025-10-15 13:42:00	BOILER MISC. PROBLEM
CHHABRA-II TPP	6	660.00	10/15/25, 9:30 PM		BOILER MISC. PROBLEM
OBRA TPS	9		10/15/25, 5:22 PM	2025-10-15 18:56:00	CONDENSER LOW VACCUM
OBRA TPS	9	200.00	10/15/25, 2:21 PM	2025-10-15 17:16:00	CONDENSER LOW VACCUM
DADRI (NCTPP)	5	490.00	10/15/25, 12:14 AM		BOILER OVERHAUL/ ANNUAL MAINTENANCE
AURAIYA CCPP	1	111.19	10/15/25, 6:56 PM	2025-10-15	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	2	111.19	10/15/25, 6:54 PM	2025-10-15	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	1	130.19	10/15/25, 6:56 PM	2025-10-15	CONSERVATION OF MAIN FUEL/RSD
BALCO TPS	2	300.00	10/15/25, 3:54 PM	2025-10-15 17:34:00	TURBINE MISC.
UCHPINDA TPP	4	360.00	10/15/25, 8:53 AM	2025-10-15 16:45:00	UNIT AUX. TRANSFORMER PROBLEM
VINDHYACHAL STPS	9	500.00	10/15/25, 8:33 AM	2025-10-15	ECONOMISER TUBE LEAKAGE
GANDHAR CCPP	2	144.30	10/15/25, 7:12 PM	2025-10-15	CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	3	144.30	10/15/25, 7:20 PM	2025-10-15	CONSERVATION OF MAIN FUEL/RSD
KHAPARKHEDA TPS	2	210.00	10/15/25, 2:47 PM		WATER WALL TUBE LEAKAGE
RAICHUR TPS	2	210.00	10/15/25, 11:18 PM		WATER WALL TUBE LEAKAGE
TUTICORIN TPS	4	210.00	10/15/25, 10:38 PM		CONDENSER TUBE LEAKAGE/ CLEANING
OPG Power Generation Private Limited	2	77.00	10/15/25, 11:59 PM		RSD/LOW SCHEDULE
RAMAGUNDEM STPS	4	500.00	10/15/25, 9:30 AM		RESERVE SHUT DOWN / STANDBY UNIT
NABINAGAR STPP	3	660.00	10/15/25, 3:42 AM	2025-10-15 07:13:00	ECONOMISER TUBE LEAKAGE
HIRANMAYE TPP	1	150.00	10/15/25, 10:31 PM		TURBINE VIBRATIONS HIGH
AGARTALA GT	2	21.00	10/15/25, 12:00 AM	2025-10-15 23:59:59	Fuel Shortage
LAKWA REPLACEMENT POWER PROJECT	3	9.96	10/15/25, 6:00 PM	2025-10-15 18:42:00	MISC. SHORT DURATION MAINTENANCE
LAKWA REPLACEMENT POWER PROJECT	5	9.96	10/15/25, 8:58 PM		GRID DISTURBENCE
KATHALGURI CCPP	5	33.50	10/15/25, 8:23 PM	2025-10-15 21:14:00	MINOR MAINTENANCE WORKS
KATHALGURI CCPP	6	33.50	10/15/25, 12:00 AM	2025-10-15 23:59:59	MISCELLANEOUS PLANNED MAINTENANCE
KATHALGURI CCPP	7	30.00	10/15/25, 12:00 AM	2025-10-15 23:59:59	MISC. SHORT DURATION MAINTENANCE

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
KATHALGURI CCPP	9	30.00	10/15/25, 12:00 AM		MISCELLANEOUS PLANNED MAINTENANCE
Total		6851.10			

Remarks:-

Report Version :-