

**CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION**

THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 16-01-2025

Sub-Report - 15

Station	Unit No	Capacity (MW)	Date of Maintanance	Expected/Sync Date of return	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
BARADARHA TPS	2	600.00	16/01/2025 10:33	18/01/2025	BOILER MISC. PROBLEM
BELA TPS	1	270.00	16/01/2025 13:55	19/01/2025	BOILER MISC. PROBLEM
DAMODARAM SANJEEVAIAH TPS	1	800.00	16/01/2025 14:14		WATER WALL TUBE LEAKAGE
NEYVELI TPS-II	5	210.00	16/01/2025 15:52		I.D. FANS PROBLEM
NEYVELI TPS(Z)	1	250.00	16/01/2025 06:41		WATER WALL TUBE LEAKAGE
TENUGHAT TPS	2	210.00	16/01/2025 17:17		VIBRATIONS
RAGHUNATHPUR TPP	2	600.00	16/01/2025 11:26	18/01/2025	WATER WALL TUBE LEAKAGE
BANDEL TPS	2	60.00	16/01/2025 11:34		SUPER HEATER TUBE LEAKAGE
BUDGE BUDGE TPS	3	250.00	16/01/2025 06:06		INSTRUMENTATION PROBLEM
LAKWA REPLACEMENT POWER PROJECT	3	9.96	16/01/2025 20:28	17/01/2025	GRID DISTURBANCE
LAKWA REPLACEMENT POWER PROJECT	4	9.96	16/01/2025 01:50		MISCELLANOUS
AGARTALA GT	1	21.00	16/01/2025 00:00		Fuel Shortage
AGARTALA GT	2	21.00	16/01/2025 00:00		Fuel Shortage
AGARTALA GT	5	25.50	16/01/2025 00:00		Fuel Shortage
Total		3337.43			