

**CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION**

THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 16-03-2023

Sub-Report - 15

Station	Unit No	Capacity (MW)	Date of Maintanance	Expected/Sync Date of return	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
ANTA CCPP	1	88.71	16/03/2023 13:38	16/03/2023	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	3	88.71	16/03/2023 14:27	16/03/2023	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	4	153.20	16/03/2023 13:51	16/03/2023	CONSERVATION OF MAIN FUEL/RSD
SURATGARH TPS	4	250.00	16/03/2023 23:50		FUEL OIL PROBLEM
AURAIYA CCPP	1	111.19	16/03/2023 12:53	16/03/2023	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	1	130.19	16/03/2023 13:03	16/03/2023	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	5	154.51	16/03/2023 00:00		CONSERVATION OF MAIN FUEL/RSD
DSPM TPS	1	250.00	16/03/2023 14:01	24/03/2023	TURBINE MISC. PROBLEM
BALCO TPS	2	300.00	16/03/2023 00:20		COAL FEEDING SYSTEM FAILURE.
BALCO TPS	2		16/03/2023 00:10		COAL FEEDING SYSTEM FAILURE.
OP JINDAL TPS	4	250.00	16/03/2023 01:02		TURBINE MISC. PROBLEM
GANDHAR CCPP	1	144.30	16/03/2023 00:00		CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	4	106.00	16/03/2023 12:59		CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	6	116.10	16/03/2023 18:24		OVERHAULING WORKS
GANDHI NAGAR TPS	4	210.00	16/03/2023 23:46		STATOR EARTH FAULT
SALAYA TPP	1	600.00	16/03/2023 19:15		BOILER MISC. PROBLEM
SALAYA TPP	2	600.00	16/03/2023 15:22		BOILER MISC. PROBLEM
ANUPPUR TPP	1	600.00	16/03/2023 09:16	16/03/2023	LINE BREAKER TRIPPED DISTANCE PROTECTION
ANUPPUR TPP	2	600.00	16/03/2023 09:16	16/03/2023	LINE BREAKER TRIPPED DISTANCE PROTECTION
BINA TPS	2	250.00	16/03/2023 23:21		BOILER FEED PUMP/MOTOR PROBLEM
MAUDA TPS	4	660.00	16/03/2023 15:19	16/03/2023	WATER WALL TUBE LEAKAGE
RATNAGIRI CCPP	4	213.00	16/03/2023 19:59	20/03/2023	Fuel Shortage
RATNAGIRI CCPP	5	213.00	16/03/2023 13:25		Fuel Shortage
RATNAGIRI CCPP	6	237.54	16/03/2023 13:23		Fuel Shortage
RAICHUR TPS	8	250.00	16/03/2023 20:02		I.D. FANS PROBLEM
UDUPI TPP	2	600.00	16/03/2023 01:00	23/03/2023	AIR PREHEATERS PROBLEM
KOTHAGUDEM TPS (STAGE-7)	12	800.00	16/03/2023 14:03		SUPER HEATER TUBE LEAKAGE
KAHALGAON TPS	6	500.00	16/03/2023 05:51	16/03/2023	TUBE LKG. AT LOW TEMP. SUPERHEATER ZONE
TENUGHAT TPS	2	210.00	16/03/2023 19:44		DRUM LEVEL HIGH/ low
TENUGHAT TPS	2		16/03/2023 17:40		FURNACE FIRE OUT /FLAME FAILURE
DERANG TPP	2	600.00	16/03/2023 13:00		TUBE LKG. AT LOW TEMP. SUPERHEATER ZONE
HIRANMAYE TPP	1	150.00	16/03/2023 23:40		MISCELLANEOUS

Station	Unit No	Capacity (MW)	Date of Maintanance	Expected/Sync Date of return	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
HIRANMAYE TPP	2	150.00	16/03/2023 23:40		MISCELLANEOUS
LAKWA REPLACEMENT POWER PROJECT	4	9.96	16/03/2023 09:11		MISCELLANEOUS
NAMRUP CCPP	7	62.25	16/03/2023 04:06	16/03/2023	GRID DISTURBANCE
AGARTALA GT	2	21.00	16/03/2023 06:15		MISCELLANEOUS
Total		9679.67			