

**DAILY MAINTENANCE REPORT (THERMAL AND NUCLEAR UNITS) FOR 500 AND ABOVE 16-04-2026**

State/System	Power Station	Unit No.	Planned Maintenance (MW)	Forced Maintenance (Major) (MW)	Forced Maintenance (Minor) (MW)	Others Maintenance (MW)	Date & Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6	7	8	9	10
Haryana	MAHATMA GANDHI TPS	2	660.00	0.00	0.00	0.00	11/03/2026 03:42		SCHEDULED ANNUAL MAINTENANCE
Punjab	TALWANDI SABO TPP	2	0.00	0.00	660.00	0.00	16/04/2026 09:30		ABNORMAL BOILER OPERATIONAL PARAMETER
Rajasthan	RAJASTHAN A.P.S.	7	0.00	0.00	700.00	0.00	06/04/2026 06:21	16/04/2026 17:04	Turbine Misc
Rajasthan	KALISINDH TPS	2	0.00	0.00	600.00	0.00	14/04/2026 23:55		SUPER HEATER TUBE LEAKAGE
Uttar Pradesh	KHURJA TPP	1	0.00	0.00	660.00	0.00	01/04/2026 04:03		AIR PREHEATERS PROBLEM
Uttar Pradesh	ANPARA TPS	5	0.00	0.00	500.00	0.00	16/04/2026 17:09		ELECTRICAL MISCELLANEOUS PROBLEMS
Uttar Pradesh	JAWAHARPUR STPP	2	0.00	0.00	660.00	0.00	15/04/2026 18:10		GENERATOR MISCELLANEOUS MAINTENANCE
Chhatisgarh	SIPAT STPS	2	0.00	0.00	0.00	0.00	14/04/2026 00:32	16/04/2026 00:38	MAIN STEAM LINE PROBLEM
Chhatisgarh	Vedanta Ltd Chhattisgarh TPP	1	0.00	0.00	600.00	0.00	14/04/2026 14:33		P.A. FANS PROBLEM
Gujarat	MUNDRA UMTTP	1	0.00	0.00	800.00	0.00	10/04/2026 21:30		BOILER MISC. PROBLEM
Madhya Pradesh	VINDHYACHAL STPS	12	500.00	0.00	0.00	0.00	08/03/2026 00:05		OVERHAULING WORKS
Madhya Pradesh	SASAN UMTTP	2	660.00	0.00	0.00	0.00	01/04/2026 23:21		BOILER OVERHAUL/ ANNUAL MAINTENANCE
Maharashtra	KORADI TPS	10	0.00	0.00	660.00	0.00	13/04/2026 03:33	16/04/2026 16:14	BOILER MISC. PROBLEM
Karnataka	BELLARY TPS	2	0.00	0.00	500.00	0.00	15/04/2026 23:04	16/04/2026 16:19	TURBINE VIBRATIONS HIGH
Tamil Nadu	NEYVELI NEW TPP	1	0.00	0.00	500.00	0.00	15/04/2026 16:35		ELECTRICAL MISCELLANEOUS PROBLEMS
Tamil Nadu	NORTH CHENNAI TPS STAGE 2	4	0.00	0.00	600.00	0.00	14/04/2026 07:49	16/04/2026 14:59	WATER WALL TUBE LEAKAGE
Tamil Nadu	NORTH CHENNAI TPS STAGE 2	5	0.00	0.00	0.00	0.00	16/04/2026 21:35		GENERATOR PROTECTION RELAY OPERATION PROBLEM
Tamil Nadu	NORTH CHENNAI TPS STAGE 3	6	0.00	0.00	0.00	0.00	15/04/2026 16:07	16/04/2026 02:00	H.P. AND L.P. bypass system
Telangana	YADADRI TPS	2	0.00	0.00	800.00	0.00	16/04/2026 19:28		BOILER MISC. PROBLEM

**DAILY MAINTENANCE REPORT (THERMAL AND NUCLEAR UNITS) FOR 500 AND ABOVE 16-04-2026**

State/System	Power Station	Unit No.	Planned Maintenance (MW)	Forced Maintenance (Major) (MW)	Forced Maintenance (Minor) (MW)	Others Maintenance (MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6	7	8	9	10
Bihar	BUXAR TPP	1	0.00	0.00	660.00	0.00	11/04/2026 12:50		COAL SHORTAGE
Bihar	NABINAGAR STPP	3	0.00	0.00	660.00	0.00	10/04/2026 12:59		TURBINE VIBRATIONS HIGH
Jharkhand	NORTH KARANPURA TPP	2	660.00	0.00	0.00	0.00	24/03/2026 18:47		OVERHAULING WORKS
West Bengal	MEJIA TPS	7	500.00	0.00	0.00	0.00	26/02/2026 00:12		BOILER OVERHAUL/ ANNUAL MAINTENANCE
West Bengal	RAGHUNATHPUR TPP	1	0.00	0.00	600.00	0.00	13/04/2026 01:20	16/04/2026 16:50	TUBE LKG. AT LOW TEMP. SUPERHEATER ZONE
West Bengal	RAGHUNATHPUR TPP	2	0.00	0.00	600.00	0.00	14/04/2026 17:51		TURBINE VIBRATIONS HIGH
<b>Total</b>			<b>2,980.00</b>	<b>0.00</b>	<b>10,760.00</b>	<b>0.00</b>			

" \*\* " CAPACITY FIGURES ARE TAKEN FROM MONTHLY REPORT OF P.D.M DIVISION AS ON THE LAST DAY OF THE PREVIOUS MONTH

Note: 1.Actual generation is generation from stations above 25 MW. It excludes generation from RES.

2.Data published in this report is for operational purpose only and not for commercial purpose.

3.Generation data/Outage data are compiled based on data submitted directly by the utilities."

**Remarks:-**

**Report Version :-**