

CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION

THERMAL/NUCLEAR UNITS OUT OF GRID FOR MORE THAN 15 DAYS DURING 2026-27 as on: 16-Apr-2026

Sub - Report 12

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
PRAGATI CCPP	1		7/28/25, 4:31 PM	28-07-2025	MISCELLANEOUS
PRAGATI CCPP	1		7/9/25, 5:36 PM	09-07-2025	GRID DISTURBENCE
PRAGATI CCPP	1		5/19/25, 4:49 PM	20-05-2025	MINOR MAINTENANCE WORKS
PRAGATI CCPP	1		5/25/25, 7:15 PM	25-05-2025	MISCELLANEOUS
PRAGATI CCPP	1		5/25/25, 2:19 PM	25-05-2025	LOW SYSTEM DEMAND
PRAGATI CCPP	1	104.60	7/17/25, 10:45 PM	25-07-2025	Low system demand/ costly fuel
PRAGATI CCPP	1		6/29/25, 4:39 AM	29-06-2025	GRID DISTURBENCE
PRAGATI CCPP	1		1/13/26, 8:11 PM		Low system demand/ costly fuel
PRAGATI CCPP	1		12/31/25, 3:02 AM	01-01-2026	GT-MISCELLANEOUS PROBLEMS
PRAGATI CCPP	1		7/25/25, 10:15 AM	26-07-2025	GT- LUB OIL SYSTEM PROB.
PRAGATI CCPP	2	104.60	5/21/25, 8:21 PM	21-05-2025	GRID DISTURBENCE
PRAGATI CCPP	2		5/2/25, 11:00 AM	02-05-2025	Electrical Scheduled Maitenance
PRAGATI CCPP	2		1/6/26, 8:03 PM		Low system demand/ costly fuel
PRAGATI CCPP	2		5/2/25, 5:22 AM	02-05-2025	GRID DISTURBENCE
PRAGATI CCPP	2		5/22/25, 6:08 PM	22-05-2025	Cooling Water System Abnormal/ Maintenance
PRAGATI CCPP	2		5/24/25, 2:00 AM	24-05-2025	Cooling Water System Abnormal/ Maintenance
PRAGATI CCPP	2		12/14/25, 7:35 AM	14-12-2025	MINOR MAINTENANCE WORKS
PRAGATI CCPP	2		6/15/25, 3:53 AM	15-06-2025	GRID DISTURBENCE
PRAGATI CCPP	3		5/2/25, 6:22 AM	02-05-2025	GRID DISTURBENCE
PRAGATI CCPP	3	121.20	1/6/26, 11:31 AM		Low system demand/ costly fuel
PRAGATI CCPP	3		5/2/25, 11:00 AM		Electrical Scheduled Maitenance
YAMUNA NAGAR TPS	2	300.00	2/15/26, 12:22 AM		BOILER OVERHAUL/ ANNUAL MAINTENANCE
RAJIV GANDHI TPS	2	600.00	10/6/25, 10:33 PM		Turbine Misc
MAHATMA GANDHI TPS	2		10/16/25, 11:52 PM		WATER WALL TUBE LEAKAGE
MAHATMA GANDHI TPS	2	660.00	3/11/26, 3:42 AM		SCHEDULED ANNUAL MAINTENANCE
FARIDABAD CCPP	1	137.76	3/2/26, 8:04 AM	16-04-2026	CONSERVATION OF MAIN FUEL/RSD
FARIDABAD CCPP	2	137.76	3/2/26, 8:04 AM	16-04-2026	CONSERVATION OF MAIN FUEL/RSD
FARIDABAD CCPP	3	156.07	2/24/26, 8:35 PM	16-04-2026	CONSERVATION OF MAIN FUEL/RSD
GH TPS (LEH.MOH.)	2		5/2/25, 9:14 PM	04-05-2025	WATER WALL TUBE LEAKAGE

THERMAL/NUCLEAR UNITS OUT OF GRID FOR MORE THAN 15 DAYS DURING 2026-27 as on: 16-Apr-2026

Sub - Report 12

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
GH TPS (LEH.MOH.)	2		8/29/25, 8:37 AM	31-08-2025	GT-TURBINE BEARING PROBLEM
GH TPS (LEH.MOH.)	2		8/31/25, 11:00 AM	08-09-2025	LOW SYSTEM DEMAND
GH TPS (LEH.MOH.)	2	210.00	8/25/25, 1:31 PM	29-08-2025	INSPECTION /MTCE
ROPAR TPS	4		10/17/25, 10:35 AM		FURNACE DRAFT ABNORMAL
ROPAR TPS	4	210.00	3/14/26, 10:56 AM		BOILER OVERHAUL/ ANNUAL MAINTENANCE
ROPAR TPS	5	210.00	10/17/25, 3:22 PM		REHEATER TUBE LEAKAGE
ROPAR TPS	6	210.00	8/10/25, 7:25 AM		REHEATER TUBE LEAKAGE
KOTA TPS	2	110.00	10/28/25, 5:55 AM		BOILER AUX. MISC. PROMLEMS
KOTA TPS	4	210.00	3/3/26, 12:00 AM		BOILER OVERHAUL/ ANNUAL MAINTENANCE
SURATGARH TPS	2	250.00	3/15/26, 4:50 AM		ELECTRICAL MISCELLANEOUS PROBLEMS
SURATGARH TPS	6	250.00	6/2/25, 7:48 AM		RSD/LOW SCHEDULE
JALIPA KAPURDI TPP	6	135.00	3/25/26, 12:16 PM		BOILER MISC. PROBLEM
RAMGARH CCPP	1	3.00	5/9/25, 4:07 PM		Fuel Shortage
ANTA CCPP	1	88.71	3/2/26, 8:05 AM	16-04-2026	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	2	88.71	3/2/26, 8:05 AM	16-04-2026	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	3	88.71	3/2/26, 8:05 AM	16-04-2026	CONSERVATION OF MAIN FUEL/RSD
JAWAHARPUR STPP	2	660.00	3/18/26, 11:03 PM		MAIN STEAM LINE PROBLEM
PANKI TPS EXT	1	660.00	7/9/25, 3:30 PM		ELECTRICAL MISCELLANEOUS PROBLEMS
GHATAMPUR TPP	2	660.00	1/29/26, 7:00 AM	07-02-2026	COAL FEEDING PROBLEM IN PLANT
TANDA TPS	1	110.00	6/30/25, 11:05 PM	04-09-2025	CONSERVATION OF MAIN FUEL/RSD
TANDA TPS	2	110.00	6/30/25, 11:17 PM	04-09-2025	CONSERVATION OF MAIN FUEL/RSD
TANDA TPS	3	110.00	8/31/25, 11:58 PM	04-09-2025	CONSERVATION OF MAIN FUEL/RSD
TANDA TPS	4	110.00	8/31/25, 11:58 PM		RESERVE SHUT DOWN / STANDBY UNIT
AURAIYA CCPP	1	111.19	3/24/26, 12:00 AM	16-04-2026	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	2	111.19	3/2/26, 8:03 AM	16-04-2026	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	3	111.19	3/2/26, 8:04 AM	16-04-2026	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	4	111.19	3/2/26, 8:03 AM	16-04-2026	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	5	109.30	2/22/26, 12:00 AM	16-04-2026	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	5		9/20/25, 10:33 PM	15-04-2026	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	6	109.30	2/2/26, 8:29 AM	16-04-2026	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	1	130.19	3/2/26, 8:08 AM	16-04-2026	CONSERVATION OF MAIN FUEL/RSD

THERMAL/NUCLEAR UNITS OUT OF GRID FOR MORE THAN 15 DAYS DURING 2026-27 as on: 16-Apr-2026

Sub - Report 12

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
DADRI CCPP	2	130.19	3/2/26, 8:08 AM	16-04-2026	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	3	130.19	3/2/26, 8:09 AM	16-04-2026	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	4	130.19	3/13/26, 8:00 PM	15-04-2026	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	5	154.51	12/27/25, 11:15 AM	16-04-2026	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	6	154.51	3/13/26, 10:00 AM	16-04-2026	CONSERVATION OF MAIN FUEL/RSD
NARORA A.P.S.	2	220.00	3/15/26, 11:50 PM	27-04-2026	ANNUAL MAINTENANCE
KUNDARKI TPS	1	45.00	10/11/25, 11:41 PM		RSD/LOW SCHEDULE
KUNDARKI TPS	2	45.00	2/6/26, 4:13 PM		BOILER OVERHAUL/ ANNUAL MAINTENANCE
UTRAULA TPS	1		2/7/26, 10:11 PM		RSD/LOW SCHEDULE
UTRAULA TPS	1		2/16/26, 12:00 AM		ESP PROBLEM
UTRAULA TPS	1	45.00	10/11/25, 11:43 PM		RSD/LOW SCHEDULE
UKAI TPS	3		11/13/25, 10:10 PM		WATER WALL TUBE LEAKAGE
UKAI TPS	3		6/26/25, 1:57 PM		TURBINE MISC.
UKAI TPS	3		11/15/25, 3:00 AM		RESERVE SHUT DOWN / STANDBY UNIT
UKAI TPS	3	200.00	11/20/25, 12:00 AM		R AND M / REFURBISHMENT works
UKAI TPS	5	210.00	3/28/26, 11:19 AM		RSD/LOW SCHEDULE
GANDHI NAGAR TPS	3	210.00	7/23/25, 11:28 AM		BOILER MISC. PROBLEM
GANDHI NAGAR TPS	3		3/19/26, 7:11 AM		RSD/LOW SCHEDULE
GANDHI NAGAR TPS	4		12/20/25, 12:00 AM		SCHEDULED ANNUAL MAINTENANCE
GANDHI NAGAR TPS	4		3/19/26, 7:29 AM		RSD/LOW SCHEDULE
GANDHI NAGAR TPS	4		11/14/25, 6:54 PM		RSD/LOW SCHEDULE
GANDHI NAGAR TPS	4	210.00	7/23/25, 11:53 AM		BOILER MISC. PROBLEM
GANDHI NAGAR TPS	5	210.00	11/15/25, 12:02 AM		SCHEDULED ANNUAL MAINTENANCE
UTRAN CCPP	5		3/23/26, 8:00 AM		GT-NO SCHEDULE FROM BENIFICIARIES
UTRAN CCPP	5	240.00	5/17/25, 10:43 PM		RESERVE SHUT DOWN / STANDBY UNIT
UTRAN CCPP	5		5/19/25, 8:00 AM		MISC. SHORT DURATION PLANNED MAINTENANCE
UTRAN CCPP	5		3/23/26, 11:59 PM		BOILER MISC. PROBLEM
UTRAN CCPP	6		3/19/26, 8:00 AM		BOILER INSPECTION/ RE-CERTIFICATION
UTRAN CCPP	6		3/23/26, 8:00 AM		GT-NO SCHEDULE FROM BENIFICIARIES
UTRAN CCPP	6	134.00	3/24/26, 12:00 AM		BOILER MISC. PROBLEM
UTRAN CCPP	6		5/17/25, 10:40 PM		RESERVE SHUT DOWN / STANDBY UNIT

Station	Unit No.	Capacity(MW)	Date & Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
UTRAN CCPP	6		3/17/26, 7:25 PM		GT-NO SCHEDULE FROM BENEFICIARIES
UTRAN CCPP	6		5/19/25, 8:00 AM		MISC. SHORT DURATION PLANNED MAINTENACE
HAZIRA CCPP EXT	1	351.00	6/15/25, 1:22 AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	3	72.00	4/17/25, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	3		4/17/25, 12:00 AM		RESERVE SHUT DOWN/ STANDBY.
DHUVARAN CCPP	3		4/18/25, 12:00 AM		RESERVE SHUT DOWN/ STANDBY.
DHUVARAN CCPP	3		4/18/25, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
DHUVARAN CCPP	4		4/17/25, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	4		8/26/25, 10:18 PM		RESERVE SHUT DOWN/ STANDBY.
DHUVARAN CCPP	4		4/18/25, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	4	40.00	4/25/25, 7:26 PM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	5		4/17/25, 12:00 AM		RESERVE SHUT DOWN/ STANDBY.
DHUVARAN CCPP	5		4/18/25, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	5	376.10	4/18/25, 12:00 AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	5		8/12/25, 12:00 AM		RESERVE SHUT DOWN/ STANDBY.
DHUVARAN CCPP	5		4/17/25, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	5		9/11/25, 7:20 PM		RESERVE SHUT DOWN
DHUVARAN CCPP	5		4/18/25, 11:00 AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	5		5/9/25, 12:00 AM		RESERVE SHUT DOWN / STANDBY UNIT
WANAKBORI TPS	1	210.00	3/19/26, 8:29 AM		RESERVE SHUT DOWN / STANDBY UNIT
WANAKBORI TPS	2	210.00	3/19/26, 8:38 AM		RESERVE SHUT DOWN / STANDBY UNIT
WANAKBORI TPS	3	210.00	5/29/25, 1:33 PM		TURBINE MISC. PROBLEM
WANAKBORI TPS	4	210.00	3/18/26, 3:38 AM		TUBE LKG. AT LOW TEMP. SUPERHEATER ZONE
WANAKBORI TPS	5		3/19/26, 8:25 AM		RESERVE SHUT DOWN / STANDBY UNIT
WANAKBORI TPS	5	210.00	5/25/25, 2:09 PM		TURBINE BEARING PROBLEM
WANAKBORI TPS	6	210.00	1/1/26, 6:47 PM		RSD/LOW SCHEDULE
SIKKA REP. TPS	3	250.00	3/19/26, 7:20 AM		RESERVE SHUT DOWN / STANDBY UNIT
SIKKA REP. TPS	4	250.00	3/19/26, 7:19 AM		RESERVE SHUT DOWN / STANDBY UNIT
KUTCH LIG. TPS	3		1/13/26, 6:00 PM		RSD/LOW SCHEDULE
KUTCH LIG. TPS	3		1/11/26, 11:32 AM		AIR PREHEATERS PROBLEM
KUTCH LIG. TPS	3	75.00	7/29/25, 10:06 AM		WATER WALL TUBE LEAKAGE

THERMAL/NUCLEAR UNITS OUT OF GRID FOR MORE THAN 15 DAYS DURING 2026-27 as on: 16-Apr-2026

Sub - Report 12

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
SUGEN CCPP	2		3/4/26, 12:00 AM	05-03-2026	RSD/LOW SCHEDULE
SUGEN CCPP	2	382.50	7/27/25, 12:00 AM		RSD/LOW SCHEDULE
UNOSUGEN CCPP	1	382.50	3/14/26, 12:00 AM	17-03-2026	RSD/LOW SCHEDULE
SURAT LIG. TPS	2	125.00	7/28/25, 4:27 AM		WATER WALL TUBE LEAKAGE
SEIONI TPP	1	600.00	5/6/25, 6:38 PM		ELECTRICAL MISCELLANEOUS PROBLEMS
VINDHYACHAL STPS	12	500.00	3/8/26, 12:05 AM	15-04-2026	OVERHAULING WORKS
PATHADI TPP	2	300.00	12/7/25, 3:30 AM		BOILER MISC. PROBLEM
RATIJA TPS	1	50.00	5/10/25, 11:59 AM	12-05-2025	BOILER MISC. PROBLEM
RATIJA TPS	1		5/9/25, 12:00 AM		BOILER AUX. MISC. PROMLEMS
RATIJA TPS	2	50.00	1/31/26, 9:45 PM		I.D. FANS PROBLEM
JSW Mahanadi Power Company Limited	2	600.00	10/11/25, 9:00 PM		RESERVE SHUT DOWN / STANDBY UNIT
URAN CCPP	5		5/2/25, 12:32 AM		BEARING
URAN CCPP	5	108.00	2/18/26, 3:09 PM	18-02-2026	INSTRUMENTATION PROBLEM
WARDHA WARORA TPP	4	135.00	3/14/26, 9:55 PM		TURBINE VIBRATIONS HIGH
RATNAGIRI CCPP	4	213.00	12/26/25, 7:50 PM		GT- LOW SYSTEM DAMAND
RATNAGIRI CCPP	5	213.00	12/26/25, 7:21 PM		GT- LOW SYSTEM DAMAND
RATNAGIRI CCPP	6	237.54	12/26/25, 7:47 PM		GT- LOW SYSTEM DAMAND
RATNAGIRI CCPP	7	213.00	12/26/25, 7:32 PM		GT- LOW SYSTEM DAMAND
RATNAGIRI CCPP	8	213.00	12/26/25, 8:08 PM		GT- LOW SYSTEM DAMAND
RATNAGIRI CCPP	9	237.54	12/26/25, 8:08 PM		GT- LOW SYSTEM DAMAND
BELA TPS	1	270.00	1/30/26, 4:19 PM	21-04-2026	GENERATOR PROTECTION RELAY OPERATION PROBLEM
KOTHAGUDEM TPS (NEW)	10	250.00	1/25/26, 6:30 AM		WATER WALL TUBE LEAKAGE
SINGARENI TPP	1	600.00	5/24/25, 2:34 AM	24-05-2025	WATER WALL TUBE LEAKAGE
RAYALASEEMA TPS	2	210.00	7/22/25, 7:05 PM		WATER WALL TUBE LEAKAGE
RAYALASEEMA TPS	2		8/26/25, 1:12 PM		WATER WALL TUBE LEAKAGE
RAYALASEEMA TPS	3	210.00	8/27/25, 2:57 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAYALASEEMA TPS	3		8/31/25, 2:00 PM		ECONOMISER TUBE LEAKAGE
RAYALASEEMA TPS	4	210.00	8/12/25, 4:49 AM		ECONOMISER TUBE LEAKAGE
RAYALASEEMA TPS	5	210.00	3/17/26, 1:41 AM		GENERATOR PROTECTION RELAY OPERATION PROBLEM
RAYALASEEMA TPS	5		10/1/25, 9:35 AM		TURBINE VIBRATIONS HIGH
RAYALASEEMA TPS	5		1/13/26, 12:18 PM		AIR PREHEATERS PROBLEM

THERMAL/NUCLEAR UNITS OUT OF GRID FOR MORE THAN 15 DAYS DURING 2026-27 as on: 16-Apr-2026

Sub - Report 12

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
SIMHAPURI TPS	3	150.00	10/19/25, 12:06 AM		P.A. FANS PROBLEM
MEENAKSHI ENERGY LTD	1		3/15/26, 3:20 PM	19-03-2026	P.A. FANS PROBLEM
MEENAKSHI ENERGY LTD	1	150.00	9/1/25, 3:01 PM	08-02-2026	BOILER MISC. PROBLEM
MEENAKSHI ENERGY LTD	2	150.00	7/7/25, 10:40 PM		GENERATOR PROTECTION RELAY OPERATION PROBLEM
VIZAG TPP	2		10/18/25, 2:31 AM		GEN.PROTECTION RELAY OPERATION
VIZAG TPP	2	520.00	9/27/25, 11:31 PM		MISCELLANEOUS
RAMAGUNDEM STPS	1	200.00	3/22/26, 10:29 AM		RSD/LOW SCHEDULE
RAMAGUNDEM STPS	6	500.00	3/5/26, 1:12 AM	11-03-2026	SUPER HEATER TUBE LEAKAGE
TELANGANA STPP PH-1	1	800.00	3/21/26, 10:51 AM		RSD/LOW SCHEDULE
TELANGANA STPP PH-1	2	800.00	3/28/26, 10:20 AM		RSD/LOW SCHEDULE
YADADRI TPS	2	800.00	10/20/25, 9:05 PM		BREAKER/ISOLATOR PROBLEM
RAICHUR TPS	5	210.00	8/31/25, 9:12 AM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	5		8/14/25, 9:34 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	6	210.00	2/14/26, 12:44 AM		TUBE LKG. AT LOW TEMP. SUPERHEATER ZONE
RAICHUR TPS	7	210.00	7/27/25, 8:07 AM		RSD/LOW SCHEDULE
RAICHUR TPS	8	250.00	8/7/25, 8:45 AM	08-08-2025	ECONOMISER TUBE LEAKAGE
BELLARY TPS	1	500.00	5/24/25, 12:09 AM	06-06-2025	RSD/LOW SCHEDULE
BELLARY TPS	3	700.00	5/26/25, 2:28 PM		WATER WALL TUBE LEAKAGE
TUTICORIN TPS	3		5/28/25, 8:47 AM		BOILER AUX. MISC. PROMLEMS
TUTICORIN TPS	3	210.00	11/2/25, 10:55 AM	03-11-2025	TURBINE PIPES AND VALVES PROBLEM
TUTICORIN TPS	3		5/20/25, 11:40 PM		BOILER AUX. MISC. PROMLEMS
TUTICORIN TPS	3		8/15/25, 11:29 AM		DRUM LEVEL HIGH/ low
TUTICORIN TPS	4	210.00	9/18/25, 7:16 PM		CONDENSER TUBE LEAKAGE/ CLEANING
TUTICORIN TPS	4		10/31/25, 3:04 PM		BOILER AUX. MISC. PROMLEMS
TUTICORIN TPS	4		7/15/25, 8:02 PM		CONDENSER LOW VACCUM
TUTICORIN TPS	5	210.00	9/14/25, 10:48 AM		CONDENSER TUBE LEAKAGE/ CLEANING
VALUTHUR CCPP	3	59.80	3/18/26, 9:52 AM		MISCELLANEOUS PLANNED MAINTENANCE
VALUTHUR CCPP	4	32.40	3/18/26, 9:34 AM		MISCELLANEOUS PLANNED MAINTENANCE
MUTHIARA TPP	1	600.00	10/10/25, 1:20 AM		MILLING SYSTEM /RC FEEDER PROBLEM
NEYVELI TPS-II	1		3/20/26, 1:30 PM		RESERVE SHUT DOWN / STANDBY UNIT
NEYVELI TPS-II	1	210.00	12/2/25, 7:59 AM		I.D. FANS PROBLEM

THERMAL/NUCLEAR UNITS OUT OF GRID FOR MORE THAN 15 DAYS DURING 2026-27 as on: 16-Apr-2026

Sub - Report 12

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
NEYVELI TPS-II	2	210.00	8/18/25, 5:20 PM		MILLING SYSTEM /RC FEEDER PROBLEM
NEYVELI TPS-II	3	210.00	11/24/25, 9:20 AM		COAL FEEDING PROBLEM IN PLANT
NEYVELI TPS-II	4	210.00	11/15/25, 10:22 AM		WATER WALL TUBE LEAKAGE
NEYVELI TPS-II	5	210.00	3/28/26, 9:40 AM		RESERVE SHUT DOWN / STANDBY UNIT
NEYVELI TPS-II	5		10/19/25, 11:38 AM		RESERVE SHUT DOWN / STANDBY UNIT
NEYVELI TPS-II	6	210.00	11/28/25, 11:58 PM		RESERVE SHUT DOWN / STANDBY UNIT
NEYVELI TPS-II	6		12/1/25, 3:30 PM		BOILER AUX. MISC. PROMLEMS
NEYVELI TPS-II	7	210.00	1/4/26, 12:00 AM		RESERVE SHUT DOWN / STANDBY UNIT
KUDANKULAM	1		8/3/25, 12:00 AM	30-09-2025	ANNUAL MAINTENANCE
KUDANKULAM	1	1,000.00	10/3/25, 12:30 AM	07-10-2025	MISC. SHORT DURATION PLANNED MAINTENACE
KUDANKULAM	1		8/1/25, 4:30 AM		RSD/LOW SCHEDULE
ITPCL TPP	2	600.00	5/24/25, 12:53 AM		RSD/LOW SCHEDULE
BARAUNI TPS	8	250.00	3/9/26, 11:43 PM	16-04-2026	OVERHAULING WORKS
NABINAGAR TPP	1	250.00	12/4/25, 10:25 AM		STATOR/ STATOR EARTH FAULT
NABINAGAR TPP	2	250.00	12/31/25, 1:30 AM	10-01-2026	GENERATOR STATOR DAMAGED
NORTH KARANPURA TPP	2	660.00	3/24/26, 6:47 PM	16-04-2026	OVERHAULING WORKS
MEJIA TPS	2	210.00	1/7/26, 8:28 PM		STATOR/ STATOR EARTH FAULT
MEJIA TPS	7	500.00	2/26/26, 12:12 AM		BOILER OVERHAUL/ ANNUAL MAINTENANCE
IB VALLEY TPS	1	210.00	3/6/26, 1:08 AM		AIR PREHEATERS PROBLEM
NAMRUP CCPP	2	17.00	8/6/25, 9:14 AM		GENEATOR TRANSFORMER MISC.
NAMRUP CCPP	6	9.00	8/6/25, 9:10 AM		GT-MISCELLANEOUS PROBLEMS
LAKWA GT	6	20.00	6/1/25, 12:00 AM	02-06-2025	GRID DISTURBENCE
LAKWA GT	8	37.20	6/1/25, 12:00 AM	02-06-2025	GRID DISTURBANCE
LAKWA REPLACEMENT POWER PROJECT	3	9.96	10/14/25, 8:59 PM		GRID DISTURBENCE
KATHALGURI CCPP	1	33.50	4/22/25, 12:00 AM		MISCELLANOUS
KATHALGURI CCPP	2	33.50	7/16/25, 11:59 PM		LOW SYSTEM DEMAND
KATHALGURI CCPP	2		7/16/25, 12:00 AM		LOW SYSTEM DEMAND
TRIPURA CCPP	2	363.30	3/14/26, 9:10 AM		GENERATOR MISCLLANEOUS MAINTENANCE
MONARCHAK CCPP	2	35.60	7/18/25, 12:14 AM		ROTOR EARTH FAULT

Total	32,693.70			
--------------	-----------	--	--	--

" ** " CAPACITY FIGURES ARE TAKEN FROM MONTHLY REPORT OF P.D.M DIVISION AS ON THE LAST DAY OF THE PREVIOUS MONTH

Note: 1.Actual generation is generation from stations above 25 MW. It excludes generation from RES.

2.Data published in this report is for operational purpose only and not for commercial purpose.

3.Generation data/Outage data are compiled based on data submitted directly by the utilities."

Remarks:-

Report Version :-