

CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION

RECOMMISSIONNING OF THERMAL/NUCLEAR UNITS AS: 16-Jul-2026

Sub - Report 14

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
ROPAR TPS	6	210.0	7/16/26, 10:07AM		ELECTRICAL FAULT
FARIDABAD CCPP	3	156.07	7/16/26, 1:50AM		CONSERVATION OF MAIN FUEL/RSD
KOTA TPS	4	210.0	7/15/26, 11:13PM		TURBINE MISC.
JALIPA KAPURDI TPP	5	135.0	7/16/26, 4:44AM		ELECTRICAL FAULT
JALIPA KAPURDI TPP	6	135.0	7/16/26, 4:44AM		ELECTRICAL FAULT
JALIPA KAPURDI TPP	7	135.0	7/16/26, 4:44AM		ELECTRICAL FAULT
JALIPA KAPURDI TPP	8	135.0	7/16/26, 4:44AM		ELECTRICAL FAULT
CHHABRA-I PH-2 TPP	3	250.0	7/15/26, 9:00PM		BOILER MISC. PROBLEM
DHOLPUR CCPP	1	110.0	7/16/26, 1:55AM		Low system demand/ costly fuel
DHOLPUR CCPP	2	110.0	7/16/26, 1:55AM		Low system demand/ costly fuel
ANTA CCPP	1	88.71	7/16/26, 1:59AM		CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	2	88.71	7/16/26, 1:27AM		CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	3	88.71	7/16/26, 1:02AM		CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	4	153.2	7/16/26, 1:35AM		CONSERVATION OF MAIN FUEL/RSD
SHREE CEMENT LTD TPS	3	19.0	7/16/26, 8:00AM		RSD/LOW SCHEDULE
SHREE CEMENT LTD TPS	4	19.0	7/16/26, 8:00AM		RSD/LOW SCHEDULE
SHREE CEMENT LTD TPS	5	6.0	7/16/26, 7:51AM		RSD/LOW SCHEDULE
AURAIYA CCPP	1	111.19	7/16/26, 2:32AM		CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	2	111.19	7/16/26, 2:20AM		CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	5	109.3	7/16/26, 2:24AM		CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	1	130.19	7/16/26, 1:39AM		CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	2	130.19	7/16/26, 1:47AM		CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	3	130.19	7/16/26, 1:54AM		CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	4	130.19	7/16/26, 1:46AM		CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	5	154.51	7/16/26, 1:41AM		CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	6	154.51	7/16/26, 1:48AM		CONSERVATION OF MAIN FUEL/RSD
BINA TPS	1		7/13/26, 5:00AM		BOILER AUX. MISC. PROMLEMS
BINA TPS	1	250.0	7/16/26, 7:57AM		GEN. COOLING SYSTEM FAILURE
GADARWARA TPP	1	800.0	7/13/26, 2:36PM		WATER WALL TUBE LEAKAGE

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
SIKKA REP. TPS	4	250.0	7/15/26, 12:15PM		MISC. SHORT DURATION MAINTENANCE
ADANI POWER LIMITED MUNDRA TPP - III	8	660.0	7/6/26, 10:17AM		MISCELLANEOUS
KAWAS CCPP	1	106.0	7/16/26, 2:37AM		CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	2	106.0	7/16/26, 2:41AM		CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	3	106.0	7/16/26, 2:39AM		CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	4	106.0	7/16/26, 2:37AM		CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	5	116.1	7/16/26, 2:35AM		CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	1	144.3	7/16/26, 1:56AM		CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	2	144.3	7/16/26, 2:00AM		CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	3	144.3	7/16/26, 2:06AM		CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	4	224.49	7/16/26, 2:01AM		CONSERVATION OF MAIN FUEL/RSD
BHUSAWAL TPS	6	660.0	7/12/26, 11:59PM		AIR PREHEATERS PROBLEM
URAN CCPP	6	108.0	7/16/26, 12:00AM		Fuel Shortage
METTUR TPS-II	1	600.0	7/13/26, 12:19AM		BOILER MISC. PROBLEM
KOTHAGUDEM TPS (NEW)	11	500.0	7/16/26, 7:45PM		WATER WALL TUBE LEAKAGE
SIMHAPURI TPS	1	150.0	7/7/26, 1:44AM		BOILER AUX. MISC. PROMLEMS
MEENAKSHI ENERGY LTD	2	150.0	6/23/26, 4:59AM		MAIN STEAM LINE PROBLEM
SGPL TPP	1	660.0	7/14/26, 8:10AM		C.W. PUMP PROBLEM
BARH STPS	3	660.0	7/12/26, 9:58PM		WATER WALL TUBE LEAKAGE
IB VALLEY TPS	3	660.0	7/14/26, 8:10PM		BOILER MISC. PROBLEM
TALCHER STPS	6	500.0	6/10/26, 2:12AM		OVERHAULING WORKS
AGARTALA GT	1	21.0	7/16/26, 12:00AM		Fuel Shortage
AGARTALA GT	2	21.0	7/16/26, 12:00AM		MINOR MAINTENANCE WORKS
AGARTALA GT	3	21.0	7/16/26, 12:00AM		Fuel Shortage
AGARTALA GT	4	21.0	7/16/26, 2:51PM		Fuel Shortage
AGARTALA GT	5	25.5	7/16/26, 12:00AM		Fuel Shortage
LAKWA REPLACEMENT POWER PROJECT	4	9.965	7/16/26, 9:03AM		GRID DISTURBENCE
KATHALGURI CCPP	1	33.5	7/16/26, 12:00AM		MINOR MAINTENANCE WORKS

Total	11169.32			
-------	----------	--	--	--

Remarks:-

Report Version :-