

CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION

THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 16-Jul-2026

Sub - Report 15

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
ROPAR TPS	6	210.00	7/16/26, 10:07AM	2026-07-16 14:25:00	ELECTRICAL FAULT
FARIDABAD CCPP	3	156.07	7/16/26, 1:50AM	2026-07-16 17:00:00	CONSERVATION OF MAIN FUEL/RSD
KOTA TPS	4	210.00	7/16/26, 10:59PM		TURBINE BEARING PROBLEM
JALIPA KAPURDI TPP	4	135.00	7/16/26, 4:43AM		ELECTRICAL FAULT
JALIPA KAPURDI TPP	5	135.00	7/16/26, 4:44AM	2026-07-16 10:07:00	ELECTRICAL FAULT
JALIPA KAPURDI TPP	6	135.00	7/16/26, 4:44AM	2026-07-16 07:59:00	ELECTRICAL FAULT
JALIPA KAPURDI TPP	7	135.00	7/16/26, 4:44AM	2026-07-16 07:52:00	ELECTRICAL FAULT
JALIPA KAPURDI TPP	8	135.00	7/16/26, 4:44AM	2026-07-16 09:18:00	ELECTRICAL FAULT
DHOLPUR CCPP	1	110.00	7/16/26, 1:55AM	2026-07-16 21:51:12	Low system demand/ costly fuel
DHOLPUR CCPP	2	110.00	7/16/26, 1:55AM	2026-07-16 21:54:25	Low system demand/ costly fuel
ANTA CCPP	1	88.71	7/16/26, 1:59AM	2026-07-16 18:00:00	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	2	88.71	7/16/26, 1:27AM	2026-07-16 13:48:00	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	3	88.71	7/16/26, 1:02AM	2026-07-16 16:01:00	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	4	153.20	7/16/26, 1:35AM	2026-07-16 15:35:00	CONSERVATION OF MAIN FUEL/RSD
SHREE CEMENT LTD TPS	3	19.00	7/16/26, 8:00AM	2026-07-16 16:32:00	RSD/LOW SCHEDULE
SHREE CEMENT LTD TPS	4	19.00	7/16/26, 8:00AM	2026-07-16 16:30:00	RSD/LOW SCHEDULE
SHREE CEMENT LTD TPS	5	6.00	7/16/26, 7:51AM	2026-07-16 16:35:00	RSD/LOW SCHEDULE
SINGRAULI STPS	3	200.00	7/16/26, 12:06AM		BOILER MISC. PROBLEM
AURAIYA CCPP	1	111.19	7/16/26, 2:32AM	2026-07-16 14:57:00	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	2	111.19	7/16/26, 2:20AM	2026-07-16 17:09:00	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	5	109.30	7/16/26, 2:24AM	2026-07-16 17:18:00	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	1	130.19	7/16/26, 1:39AM	2026-07-16 17:18:00	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	2	130.19	7/16/26, 1:47AM	2026-07-16 14:34:00	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	3	130.19	7/16/26, 1:54AM	2026-07-16 17:13:00	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	4	130.19	7/16/26, 1:46AM	2026-07-16 14:32:00	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	5	154.51	7/16/26, 1:41AM	2026-07-16 16:37:00	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	6	154.51	7/16/26, 1:48AM	2026-07-16 16:45:00	CONSERVATION OF MAIN FUEL/RSD
ROSA TPP Ph-I	4	300.00	7/16/26, 4:31AM		SUPER HEATER TUBE LEAKAGE
TAMNAR TPP	3	600.00	7/16/26, 4:30AM		AIR PREHEATERS PROBLEM

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
UCHPINDA TPP	2	360.00	7/16/26, 4:20AM		BOILER MISC. PROBLEM
BINA TPS	1	250.00	7/16/26, 7:57AM	2026-07-16 12:12:00	GEN. COOLING SYSTEM FAILURE
KAWAS CCPP	1	106.00	7/16/26, 2:37AM	2026-07-16 16:30:00	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	2	106.00	7/16/26, 2:41AM	2026-07-16 14:47:00	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	3	106.00	7/16/26, 2:39AM	2026-07-16 17:11:00	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	4	106.00	7/16/26, 2:37AM	2026-07-16 14:17:00	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	5	116.10	7/16/26, 2:35AM	2026-07-16 16:46:00	CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	1	144.30	7/16/26, 1:56AM	2026-07-16 14:16:00	CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	2	144.30	7/16/26, 2:00AM	2026-07-16 16:15:00	CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	3	144.30	7/16/26, 2:06AM	2026-07-16 17:30:00	CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	4	224.49	7/16/26, 2:01AM	2026-07-16 16:16:00	CONSERVATION OF MAIN FUEL/RSD
URAN CCPP	6	108.00	7/16/26, 12:00AM	2026-07-16 05:14:00	Fuel Shortage
RAICHUR TPS	7	210.00	7/16/26, 7:27PM		WATER WALL TUBE LEAKAGE
TUTICORIN TPS	3	210.00	7/16/26, 12:27PM		BOILER AUX. MISC. PROMLEMS
KOTHAGUDEM TPS (NEW)	11	500.00	7/16/26, 7:45PM	2026-07-16 21:58:00	WATER WALL TUBE LEAKAGE
PAINAMPURAM TPP	2	660.00	7/16/26, 4:59AM	2026-08-10	SCHEDULED ANNUAL MAINTENANCE
FARAKKA STPS	5	500.00	7/16/26, 12:16PM		BOILER MISC. PROBLEM
KODARMA TPP	1	500.00	7/16/26, 11:34AM		WATER WALL TUBE LEAKAGE
JSW Energy Utkal Limited	1	350.00	7/16/26, 1:30PM		EXCITATION PROBLEM
AGARTALA GT	1	21.00	7/16/26, 12:00AM	2026-07-16 23:59:59	Fuel Shortage
AGARTALA GT	2	21.00	7/16/26, 12:00AM	2026-07-16 23:59:59	MINOR MAINTENANCE WORKS
AGARTALA GT	3	21.00	7/16/26, 12:00AM	2026-07-16 13:00:00	Fuel Shortage
AGARTALA GT	4	21.00	7/16/26, 2:51PM	2026-07-16 23:59:59	Fuel Shortage
AGARTALA GT	5	25.50	7/16/26, 12:00AM	2026-07-16 23:59:59	Fuel Shortage
NAMRUP CCPP	8	36.15	7/16/26, 4:30PM		TURBINE OIL SYSTEM PROBLEM
LAKWA REPLACEMENT POWER PROJECT	4	9.96	7/16/26, 9:03AM	2026-07-16 16:27:00	GRID DISTURBENCE
KATHALGURI CCPP	1	33.50	7/16/26, 12:00AM	2026-07-16 23:59:59	MINOR MAINTENANCE WORKS

Total	9230.47			
-------	---------	--	--	--

Remarks:-

Report Version :-