

**CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION**

RECOMMISSIONING OF THERMAL/NUCLEAR UNITS AS ON: 16-09-2020

Sub-Report - 14

Station	Unit No	Capacity (MW)	Date of Maintanance	Sync Date	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
GH TPS (LEH.MOH.)	1	210.00	30/07/2020 06:36	16/09/2020 10:24	RSD/LOW SCHEDULE
ROPAR TPS	3	210.00	19/08/2020 13:15	16/09/2020 08:47	RSD/LOW SCHEDULE
KOTA TPS	7	195.00	10/08/2020 12:15	16/09/2020 19:58	P.A. FANS PROBLEM
UKAI TPS	4	200.00	09/09/2020 08:15	16/09/2020 15:04	WATER WALL TUBE LEAKAGE
HAZIRA CCPP	1	52.00	10/09/2020 05:51	16/09/2020 17:19	Fuel Shortage
HAZIRA CCPP	2	52.00	10/09/2020 05:40	16/09/2020 09:22	Fuel Shortage
HAZIRA CCPP	3	52.10	10/09/2020 05:45	16/09/2020 12:46	Fuel Shortage
HAZIRA CCPP EXT	1	351.00	15/09/2020 20:45	16/09/2020 11:31	SCHEDULED ANNUAL MAINTENANCE
GODAVARI CCPP	2	47.00	28/08/2020 19:09	16/09/2020 15:04	Fuel Shortage
LAKWA REPLACEMENT POWER PROJECT	1	9.96	16/09/2020 02:46	16/09/2020 06:09	Fuel Shortage
LAKWA REPLACEMENT POWER PROJECT	5	9.96	16/09/2020 10:33	16/09/2020 21:20	Fuel Shortage
LAKWA REPLACEMENT POWER PROJECT	6	9.96	15/09/2020 09:22	16/09/2020 21:51	Fuel Shortage
Total		1,398.99			