

**CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION**

THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 16-09-2020

Sub-Report - 15

Station	Unit No	Capacity (MW)	Date of Maintanance	Expected/Sync Date of return	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
PARICHHA TPS	5	250.00	16/09/2020 17:14		WATER WALL TUBE LEAKAGE
HAZIRA CCPP	1	52.00	16/09/2020 23:23		RSD/LOW SCHEDULE
HAZIRA CCPP	2	52.00	16/09/2020 22:44		RSD/LOW SCHEDULE
HAZIRA CCPP	3	52.10	16/09/2020 23:26		RSD/LOW SCHEDULE
KOTHAGUDEM TPS (NEW)	9	250.00	16/09/2020 00:00		RESERVE SHUT DOWN / STANDBY UNIT
TALCHER (OLD) TPS	3	60.00	16/09/2020 23:48	17/09/2020	WATER WALL TUBE LEAKAGE
LAKWA REPLACEMENT POWER PROJECT	1	9.96	16/09/2020 02:46		Fuel Shortage
LAKWA REPLACEMENT POWER PROJECT	1		16/09/2020 07:40		Fuel Shortage
LAKWA REPLACEMENT POWER PROJECT	5	9.96	16/09/2020 10:33		Fuel Shortage
LAKWA REPLACEMENT POWER PROJECT	6	9.96	16/09/2020 23:06		Fuel Shortage
Total		746.00			