

**CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION**

RECOMMISSIONING OF THERMAL/NUCLEAR UNITS AS ON: 16-10-2020

Sub-Report - 14

Station	Unit No	Capacity (MW)	Date of Maintanance	Sync Date	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
CHHABRA TPP	2	250.00	13/10/2020 00:00	16/10/2020 19:23	TURBINE OIL SYSTEM PROBLEM
OBRA TPS	12	200.00	13/10/2020 00:12	16/10/2020 12:56	BOILER MISC. PROBLEM
MARWA TPS	1	500.00	14/10/2020 09:30	16/10/2020 17:18	ASH HANDLING SYSTEM PROBLEM
KHAPARKHEDA TPS	3	210.00	14/10/2020 18:15	16/10/2020 04:17	WATER WALL TUBE LEAKAGE
KORADI TPS	10	660.00	16/10/2020 03:10	16/10/2020 07:45	BOILER MISC. PROBLEM
VALLUR TPP	2	500.00	12/10/2020 13:59	16/10/2020 18:18	RESERVE SHUT DOWN / STANDBY UNIT
VALLUR TPP	3	500.00	13/10/2020 00:29	16/10/2020 14:47	RESERVE SHUT DOWN / STANDBY UNIT
TALCHER (OLD) TPS	2	60.00	26/09/2020 00:08	16/10/2020 20:32	OVERHAULING WORKS
SAGARDIGHI TPS	1	300.00	16/10/2020 12:47	16/10/2020 18:06	BOILER FEED PUMP/MOTOR PROBLEM
LAKWA REPLACEMENT POWER PROJECT	5	9.96	16/10/2020 10:24	16/10/2020 23:59	Fuel Shortage
LAKWA REPLACEMENT POWER PROJECT	6	9.96	16/10/2020 17:54	16/10/2020 23:59	Fuel Shortage
LAKWA REPLACEMENT POWER PROJECT	6		15/10/2020 17:00	16/10/2020 16:28	Fuel Shortage
Total		3,199.93			