

**CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION**

THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 16-10-2020

Sub-Report - 15

Station	Unit No	Capacity (MW)	Date of Maintanance	Expected/Sync Date of return	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
PARICHHA TPS	3	210.00	16/10/2020 00:01		RSD/LOW SCHEDULE
PARICHHA TPS	4	210.00	16/10/2020 23:59		RSD/LOW SCHEDULE
BALCO TPS	2	300.00	16/10/2020 06:51		ASH HANDLING SYSTEM PROBLEM
BARADARHA TPS	1	600.00	16/10/2020 01:18	16/10/2020	TURBINE PIPES AND VALVES PROBLEM
SATPURA TPS	6	200.00	16/10/2020 13:10		REHEATER TUBE LEAKAGE
SASAN UMTTP	6	660.00	16/10/2020 01:52	17/10/2020	AIR PREHEATERS PROBLEM
KORADI TPS	10	660.00	16/10/2020 03:10		BOILER MISC. PROBLEM
NEYVELI TPS-II	2	210.00	16/10/2020 08:34		WATER WALL TUBE LEAKAGE
VALLUR TPP	1	500.00	16/10/2020 17:35		WATER WALL TUBE LEAKAGE
KOTHAGUDEM TPS (NEW)	11	500.00	16/10/2020 21:40		WATER WALL TUBE LEAKAGE
SAGARDIGHI TPS	1	300.00	16/10/2020 12:47		BOILER FEED PUMP/MOTOR PROBLEM
LAKWA REPLACEMENT POWER PROJECT	5	9.96	16/10/2020 10:24		Fuel Shortage
LAKWA REPLACEMENT POWER PROJECT	6	9.96	16/10/2020 17:54		Fuel Shortage
Total		4369.93			