

**CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION**

THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 17-01-2025

Sub-Report - 15

Station	Unit No	Capacity (MW)	Date of Maintanance	Expected/Sync Date of return	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
ROPAR TPS	5	210.00	17/01/2025 20:29		AIR PREHEATERS PROBLEM
OBRA TPS	12	200.00	17/01/2025 11:58		FURNACE FIRE OUT /FLAME FAILURE
KHAMBARKHERA TPS	1	45.00	17/01/2025 06:54		BOILER MISC. PROBLEM
SIMHAPURI TPS	1	150.00	17/01/2025 00:21		BOILER MISC. PROBLEM
MUTHIARA TPP	2	600.00	17/01/2025 12:51		BOILER MISC. PROBLEM
KODARMA TPP	2	500.00	17/01/2025 05:40		DRUM LEVEL HIGH/ low
KOLAGHAT TPS	6	210.00	17/01/2025 17:58		MISCELLANEOUS PLANNED MAINTENANCE
BONGAIGAON TPP	3	250.00	17/01/2025 21:50	18/01/2025	WET / POOR QUALITY COAL
KATHALGURI CCPP	1	33.50	17/01/2025 12:28		MISCELLANEOUS
KATHALGURI CCPP	1		17/01/2025 13:22		MISCELLANEOUS
KATHALGURI CCPP	4	33.50	17/01/2025 12:28		MISCELLANEOUS
KATHALGURI CCPP	4		17/01/2025 13:22		MISCELLANEOUS
LAKWA REPLACEMENT POWER PROJECT	3	9.96	17/01/2025 19:31	18/01/2025	FUEL SUPPLY & OTHER MISC. PROBLEMS
LAKWA REPLACEMENT POWER PROJECT	4	9.96	17/01/2025 11:05		GRID DISTURBANCE
LAKWA REPLACEMENT POWER PROJECT	6	9.96	17/01/2025 20:30		GRID DISTURBENCE
LAKWA REPLACEMENT POWER PROJECT	6		17/01/2025 19:24		MISCELLANOUS
AGARTALA GT	1	21.00	17/01/2025 00:00		Fuel Shortage
AGARTALA GT	2	21.00	17/01/2025 00:00		Fuel Shortage
Total		2303.90			