

CENTRAL ELECTRICITY AUTHORITY  
G O & D WING  
OPERATION PERFORMANCE MONITORING DIVISION

THERMAL/NUCLEAR UNITS OUT OF GRID FOR MORE THAN 15 DAYS DURING 2025-26 as on: 17-Feb-2026

Sub - Report 12

| Station            | Unit No. | Capacity(MW) | Date& Time of Maintenance<br><br>DD/MM/YYYY HH24:MM | Expected/sync Date of Return<br><br>DD/MM/YYYY HH24:MM | Reasons/Present Status                       |
|--------------------|----------|--------------|-----------------------------------------------------|--------------------------------------------------------|----------------------------------------------|
| 1                  | 2        | 3            | 4                                                   | 5                                                      | 6                                            |
| PRAGATI CCPP       | 1        |              | 12/31/25, 3:02 AM                                   | 01-01-2026                                             | GT-MISCELLANEOUS PROBLEMS                    |
| PRAGATI CCPP       | 1        | 104.60       | 5/25/25, 2:19 PM                                    | 25-05-2025                                             | LOW SYSTEM DEMAND                            |
| PRAGATI CCPP       | 1        |              | 6/29/25, 4:39 AM                                    | 29-06-2025                                             | GRID DISTURBENCE                             |
| PRAGATI CCPP       | 1        |              | 7/25/25, 10:15 AM                                   | 26-07-2025                                             | GT- LUB OIL SYSTEM PROB.                     |
| PRAGATI CCPP       | 1        |              | 7/17/25, 10:45 PM                                   | 25-07-2025                                             | Low system demand/ costly fuel               |
| PRAGATI CCPP       | 1        |              | 5/25/25, 7:15 PM                                    | 25-05-2025                                             | MISCELLANOUS                                 |
| PRAGATI CCPP       | 1        |              | 1/13/26, 8:11 PM                                    |                                                        | Low system demand/ costly fuel               |
| PRAGATI CCPP       | 1        |              | 7/28/25, 4:31 PM                                    | 28-07-2025                                             | MISCELLANOUS                                 |
| PRAGATI CCPP       | 1        |              | 7/9/25, 5:36 PM                                     | 09-07-2025                                             | GRID DISTURBENCE                             |
| PRAGATI CCPP       | 1        |              | 5/19/25, 4:49 PM                                    | 20-05-2025                                             | MINOR MAINTENANCE WORKS                      |
| PRAGATI CCPP       | 2        |              | 5/22/25, 6:08 PM                                    | 22-05-2025                                             | Cooling Water System Abnormal/ Maintenance   |
| PRAGATI CCPP       | 2        | 104.60       | 5/24/25, 2:00 AM                                    | 24-05-2025                                             | Cooling Water System Abnormal/ Maintenance   |
| PRAGATI CCPP       | 2        |              | 1/6/26, 8:03 PM                                     |                                                        | Low system demand/ costly fuel               |
| PRAGATI CCPP       | 2        |              | 12/14/25, 7:35 AM                                   | 14-12-2025                                             | MINOR MAINTENANCE WORKS                      |
| PRAGATI CCPP       | 2        |              | 5/2/25, 11:00 AM                                    | 02-05-2025                                             | Electrical Scheduled Maitenance              |
| PRAGATI CCPP       | 2        |              | 5/2/25, 5:22 AM                                     | 02-05-2025                                             | GRID DISTURBENCE                             |
| PRAGATI CCPP       | 2        |              | 6/15/25, 3:53 AM                                    | 15-06-2025                                             | GRID DISTURBENCE                             |
| PRAGATI CCPP       | 2        |              | 5/21/25, 8:21 PM                                    | 21-05-2025                                             | GRID DISTURBENCE                             |
| PRAGATI CCPP       | 3        | 121.20       | 1/6/26, 11:31 AM                                    |                                                        | Low system demand/ costly fuel               |
| PRAGATI CCPP       | 3        |              | 5/2/25, 11:00 AM                                    |                                                        | Electrical Scheduled Maitenance              |
| PRAGATI CCPP       | 3        |              | 5/2/25, 6:22 AM                                     | 02-05-2025                                             | GRID DISTURBENCE                             |
| PANIPAT TPS        | 6        | 210.00       | 10/20/25, 12:33 AM                                  |                                                        | RESERVE SHUT DOWN / STANDBY UNIT             |
| RAJIV GANDHI TPS   | 2        | 600.00       | 1/23/26, 8:30 AM                                    |                                                        | RESERVE SHUT DOWN / STANDBY UNIT             |
| RAJIV GANDHI TPS   | 2        |              | 10/6/25, 10:33 PM                                   |                                                        | Turbine Misc                                 |
| INDIRA GANDHI STPP | 1        | 500.00       | 5/2/25, 5:14 AM                                     |                                                        | GENERATOR PROTECTION                         |
| INDIRA GANDHI STPP | 1        |              | 5/2/25, 5:45 PM                                     |                                                        | GOVERNING SYSTEM PROBLEM                     |
| INDIRA GANDHI STPP | 1        |              | 8/9/25, 12:01 AM                                    |                                                        | GENERATOR PROTECTION RELAY OPERATION PROBLEM |
| INDIRA GANDHI STPP | 1        |              | 8/31/25, 1:34 PM                                    |                                                        | GENERATOR PROTECTION RELAY OPERATION PROBLEM |
| MAHATMA GANDHI TPS | 2        | 660.00       | 10/16/25, 11:52 PM                                  |                                                        | WATER WALL TUBE LEAKAGE                      |

| Station            | Unit No. | Capacity(MW) | Date& Time of Maintenance<br><br>DD/MM/YYYY HH24:MM | Expected/sync Date of Return<br><br>DD/MM/YYYY HH24:MM | Reasons/Present Status             |
|--------------------|----------|--------------|-----------------------------------------------------|--------------------------------------------------------|------------------------------------|
| 1                  | 2        | 3            | 4                                                   | 5                                                      | 6                                  |
| FARIDABAD CCPP     | 1        | 137.76       | 9/9/25, 11:33 PM                                    | 09-09-2025                                             | CONSERVATION OF MAIN FUEL/RSD      |
| FARIDABAD CCPP     | 2        | 137.76       | 9/9/25, 11:32 PM                                    | 09-09-2025                                             | CONSERVATION OF MAIN FUEL/RSD      |
| FARIDABAD CCPP     | 3        | 156.07       | 7/23/25, 10:38 PM                                   | 20-08-2025                                             | CONSERVATION OF MAIN FUEL/RSD      |
| GH TPS (LEH.MOH.)  | 1        | 210.00       | 3/21/25, 3:58 PM                                    | 01-04-2025                                             | STATOR EARTH FAULT                 |
| GH TPS (LEH.MOH.)  | 2        |              | 8/29/25, 8:37 AM                                    | 31-08-2025                                             | GT-TURBINE BEARING PROBLEM         |
| GH TPS (LEH.MOH.)  | 2        | 210.00       | 8/31/25, 11:00 AM                                   | 08-09-2025                                             | LOW SYSTEM DEMAND                  |
| GH TPS (LEH.MOH.)  | 2        |              | 8/25/25, 1:31 PM                                    | 29-08-2025                                             | INSPECTION /MTCE                   |
| GH TPS (LEH.MOH.)  | 4        | 250.00       | 5/7/25, 10:55 PM                                    | 10-05-2025                                             | MISC. SHORT DURATION MAINTENANCE   |
| ROPAR TPS          | 3        | 210.00       | 1/2/26, 10:24 PM                                    |                                                        | SCHEDULED ANNUAL MAINTENANCE       |
| ROPAR TPS          | 3        |              | 8/16/25, 10:36 PM                                   |                                                        | FUEL SUPPLY & OTHER MISC. PROBLEMS |
| ROPAR TPS          | 3        |              | 8/25/25, 9:37 AM                                    |                                                        | FURNACE DRAFT ABNORMAL             |
| ROPAR TPS          | 4        |              | 8/10/25, 9:22 AM                                    |                                                        | FURNACE DRAFT ABNORMAL             |
| ROPAR TPS          | 4        |              | 10/17/25, 10:35 AM                                  |                                                        | FURNACE DRAFT ABNORMAL             |
| ROPAR TPS          | 4        | 210.00       | 6/18/25, 12:09 AM                                   |                                                        | WATER WALL TUBE LEAKAGE            |
| ROPAR TPS          | 5        |              | 10/17/25, 3:22 PM                                   |                                                        | REHEATER TUBE LEAKAGE              |
| ROPAR TPS          | 5        | 210.00       | 8/16/25, 9:25 AM                                    |                                                        | FUEL SUPPLY & OTHER MISC. PROBLEMS |
| ROPAR TPS          | 6        | 210.00       | 10/13/25, 4:37 PM                                   |                                                        | BOILER MISC. PROBLEM               |
| ROPAR TPS          | 6        |              | 8/10/25, 7:25 AM                                    |                                                        | REHEATER TUBE LEAKAGE              |
| ROPAR TPS          | 6        |              | 8/28/25, 8:30 PM                                    |                                                        | RSD/LOW SCHEDULE                   |
| ROPAR TPS          | 6        |              | 8/27/25, 2:48 PM                                    |                                                        | AIR PREHEATERS PROBLEM             |
| GOINDWAL SAHIB TPP | 1        | 270.00       | 12/25/25, 11:15 PM                                  |                                                        | GEN. TRANSFORMER TRIPPING/ DAMAGED |
| KOTA TPS           | 2        | 110.00       | 10/28/25, 5:55 AM                                   |                                                        | BOILER AUX. MISC. PROMLEMS         |
| RAJASTHAN A.P.S.   | 6        | 220.00       | 1/30/26, 11:48 PM                                   | 28-02-2026                                             | ANNUAL MAINTENANCE                 |
| SURATGARH TPS      | 6        | 250.00       | 6/2/25, 7:48 AM                                     |                                                        | RSD/LOW SCHEDULE                   |
| CHHABRA-II TPP     | 6        | 660.00       | 12/24/25, 10:48 PM                                  |                                                        | WATER WALL TUBE LEAKAGE            |
| RAMGARH CCPP       | 1        | 3.00         | 5/9/25, 4:07 PM                                     |                                                        | Fuel Shortage                      |
| ANTA CCPP          | 1        |              | 5/3/25, 4:09 AM                                     | 03-05-2025                                             | NO Power purchase agreement        |
| ANTA CCPP          | 1        | 88.71        | 8/26/25, 12:00 AM                                   | 26-08-2025                                             | CONSERVATION OF MAIN FUEL/RSD      |
| ANTA CCPP          | 2        |              | 3/12/25, 11:14 PM                                   | 16-03-2025                                             | NO/REDUCED IRRIGATION DEMAND       |
| ANTA CCPP          | 2        | 88.71        | 8/26/25, 12:00 AM                                   | 26-08-2025                                             | CONSERVATION OF MAIN FUEL/RSD      |
| ANTA CCPP          | 2        |              | 2/19/25, 7:30 AM                                    | 20-02-2025                                             | CONSERVATION OF MAIN FUEL/RSD      |

| Station         | Unit No. | Capacity(MW) | Date& Time of Maintenance<br><br>DD/MM/YYYY HH24:MM | Expected/sync Date of Return<br><br>DD/MM/YYYY HH24:MM | Reasons/Present Status              |
|-----------------|----------|--------------|-----------------------------------------------------|--------------------------------------------------------|-------------------------------------|
| 1               | 2        | 3            | 4                                                   | 5                                                      | 6                                   |
| ANTA CCPP       | 2        |              | 2/18/25, 11:36 AM                                   | 19-02-2025                                             | CONSERVATION OF MAIN FUEL/RSD       |
| ANTA CCPP       | 3        | 88.71        | 8/26/25, 12:00 AM                                   | 26-08-2025                                             | CONSERVATION OF MAIN FUEL/RSD       |
| ANTA CCPP       | 4        | 153.20       | 9/17/25, 12:23 AM                                   | 18-09-2025                                             | CONSERVATION OF MAIN FUEL/RSD       |
| HARDUAGANJ TPS  | 7        | 105.00       | 10/3/25, 11:17 PM                                   |                                                        | RESERVE SHUT DOWN / STANDBY UNIT    |
| HARDUAGANJ TPS  | 8        | 250.00       | 1/14/26, 10:17 PM                                   |                                                        | RESERVE SHUT DOWN / STANDBY UNIT    |
| HARDUAGANJ TPS  | 9        | 250.00       | 1/14/26, 10:03 PM                                   |                                                        | RESERVE SHUT DOWN / STANDBY UNIT    |
| PARICHHA TPS    | 6        | 250.00       | 1/28/26, 12:00 AM                                   |                                                        | RSD/LOW SCHEDULE                    |
| ANPARA TPS      | 3        | 210.00       | 1/29/26, 3:13 AM                                    |                                                        | SCHEDULED CAPITAL MAINTENACE        |
| JAWAHARPUR STPP | 1        | 660.00       | 1/14/26, 11:21 PM                                   |                                                        | RSD/LOW SCHEDULE                    |
| JAWAHARPUR STPP | 2        | 660.00       | 12/24/25, 8:10 AM                                   |                                                        | P.A. FANS PROBLEM                   |
| PANKI TPS EXT   | 1        | 660.00       | 7/9/25, 3:30 PM                                     |                                                        | ELECTRICAL MISCELLANEOUS PROBLEMS   |
| RIHAND STPS     | 5        | 500.00       | 1/18/26, 7:31 PM                                    | 17-02-2026                                             | OVERHAULING WORKS                   |
| GHATAMPUR TPP   | 2        | 660.00       | 1/29/26, 7:00 AM                                    | 07-02-2026                                             | COAL FEEDING PROBLEM IN PLANT       |
| DADRI (NCTPP)   | 1        | 210.00       | 2/1/26, 12:00 AM                                    |                                                        | BOILER OVERHAUL/ ANNUAL MAINTENANCE |
| DADRI (NCTPP)   | 1        |              | 1/29/26, 1:29 PM                                    | 12-02-2026                                             | RSD/LOW SCHEDULE                    |
| DADRI (NCTPP)   | 2        | 210.00       | 6/18/25, 11:47 AM                                   |                                                        | RSD/LOW SCHEDULE                    |
| DADRI (NCTPP)   | 5        | 490.00       | 5/23/25, 11:35 AM                                   | 25-05-2025                                             | BOILER AUX. MISC. PROMLEMS          |
| TANDA TPS       | 1        | 110.00       | 6/30/25, 11:05 PM                                   | 04-09-2025                                             | CONSERVATION OF MAIN FUEL/RSD       |
| TANDA TPS       | 2        | 110.00       | 6/30/25, 11:17 PM                                   | 04-09-2025                                             | CONSERVATION OF MAIN FUEL/RSD       |
| TANDA TPS       | 3        | 110.00       | 8/31/25, 11:58 PM                                   | 04-09-2025                                             | CONSERVATION OF MAIN FUEL/RSD       |
| TANDA TPS       | 4        | 110.00       | 3/27/25, 2:55 AM                                    | 28-03-2025                                             | BOILER AUX. MISC. PROMLEMS          |
| TANDA TPS       | 4        |              | 8/31/25, 11:58 PM                                   |                                                        | RESERVE SHUT DOWN / STANDBY UNIT    |
| AURAIYA CCPP    | 1        | 111.19       | 11/28/25, 6:16 PM                                   | 30-11-2025                                             | CONSERVATION OF MAIN FUEL/RSD       |
| AURAIYA CCPP    | 2        |              | 11/28/25, 6:12 PM                                   | 30-11-2025                                             | CONSERVATION OF MAIN FUEL/RSD       |
| AURAIYA CCPP    | 2        |              | 3/25/25, 12:00 AM                                   | 27-03-2025                                             | NO/REDUCED IRRIGATION DEMAND        |
| AURAIYA CCPP    | 2        | 111.19       | 3/12/25, 11:13 PM                                   | 25-03-2025                                             | NO/REDUCED IRRIGATION DEMAND        |
| AURAIYA CCPP    | 4        | 111.19       | 9/8/25, 11:40 PM                                    | 08-09-2025                                             | CONSERVATION OF MAIN FUEL/RSD       |
| AURAIYA CCPP    | 5        |              | 9/20/25, 10:33 PM                                   | 17-02-2026                                             | CONSERVATION OF MAIN FUEL/RSD       |
| AURAIYA CCPP    | 5        |              | 3/25/25, 12:00 PM                                   | 26-03-2025                                             | NO/REDUCED IRRIGATION DEMAND        |
| AURAIYA CCPP    | 5        | 109.30       | 3/24/25, 12:00 PM                                   | 25-03-2025                                             | NO/REDUCED IRRIGATION DEMAND        |
| AURAIYA CCPP    | 6        | 109.30       | 9/20/25, 10:44 PM                                   | 06-02-2026                                             | CONSERVATION OF MAIN FUEL/RSD       |

| Station          | Unit No. | Capacity(MW) | Date& Time of Maintenance<br><br>DD/MM/YYYY HH24:MM | Expected/sync Date of Return<br><br>DD/MM/YYYY HH24:MM | Reasons/Present Status                  |
|------------------|----------|--------------|-----------------------------------------------------|--------------------------------------------------------|-----------------------------------------|
| 1                | 2        | 3            | 4                                                   | 5                                                      | 6                                       |
| DADRI CCPP       | 1        | 130.19       | 11/19/25, 6:14 PM                                   | 19-11-2025                                             | A.V.R. PROBLEM                          |
| DADRI CCPP       | 2        | 130.19       | 2/25/25, 12:16 PM                                   | 26-02-2025                                             | CONSERVATION OF MAIN FUEL/RSD           |
| DADRI CCPP       | 2        |              | 7/9/25, 12:43 AM                                    |                                                        | CONSERVATION OF MAIN FUEL/RSD           |
| DADRI CCPP       | 2        |              | 10/13/25, 7:49 PM                                   | 13-10-2025                                             | CONSERVATION OF MAIN FUEL/RSD           |
| DADRI CCPP       | 2        |              | 4/13/25, 8:19 AM                                    | 14-04-2025                                             | GENERATOR TRANSFORMER                   |
| DADRI CCPP       | 3        | 130.19       | 8/25/25, 8:51 PM                                    | 27-08-2025                                             | CONSERVATION OF MAIN FUEL/RSD           |
| DADRI CCPP       | 4        | 130.19       | 3/5/25, 7:56 PM                                     | 07-03-2025                                             | NO/REDUCED IRRIGATION DEMAND            |
| DADRI CCPP       | 5        | 154.51       | 7/23/25, 10:29 PM                                   | 21-08-2025                                             | CONSERVATION OF MAIN FUEL/RSD           |
| DADRI CCPP       | 6        | 154.51       | 7/5/25, 12:39 AM                                    | 21-07-2025                                             | CONSERVATION OF MAIN FUEL/RSD           |
| KUNDARKI TPS     | 1        | 45.00        | 10/11/25, 11:41 PM                                  |                                                        | RSD/LOW SCHEDULE                        |
| UTRAULA TPS      | 1        | 45.00        | 10/11/25, 11:43 PM                                  |                                                        | RSD/LOW SCHEDULE                        |
| UKAI TPS         | 3        |              | 6/26/25, 1:57 PM                                    |                                                        | TURBINE MISC.                           |
| UKAI TPS         | 3        | 200.00       | 11/13/25, 10:10 PM                                  |                                                        | WATER WALL TUBE LEAKAGE                 |
| UKAI TPS         | 3        |              | 11/20/25, 12:00 AM                                  |                                                        | R AND M / REFURBISHMENT works           |
| UKAI TPS         | 3        |              | 2/22/25, 7:45 AM                                    |                                                        | WATER WALL TUBE LEAKAGE                 |
| UKAI TPS         | 3        |              | 11/15/25, 3:00 AM                                   |                                                        | RESERVE SHUT DOWN / STANDBY UNIT        |
| GANDHI NAGAR TPS | 3        | 210.00       | 7/23/25, 11:28 AM                                   |                                                        | RAW WATER SUPPLY MISC.                  |
| GANDHI NAGAR TPS | 3        |              | 1/1/26, 10:47 AM                                    |                                                        | RSD/LOW SCHEDULE                        |
| GANDHI NAGAR TPS | 4        | 210.00       | 12/20/25, 12:00 AM                                  |                                                        | SCHEDULED ANNUAL MAINTENANCE            |
| GANDHI NAGAR TPS | 4        |              | 11/14/25, 6:54 PM                                   |                                                        | RSD/LOW SCHEDULE                        |
| GANDHI NAGAR TPS | 4        |              | 7/23/25, 11:53 AM                                   |                                                        | RAW WATER SUPPLY MISC.                  |
| GANDHI NAGAR TPS | 5        | 210.00       | 11/15/25, 12:02 AM                                  |                                                        | SCHEDULED ANNUAL MAINTENANCE            |
| GANDHI NAGAR TPS | 5        |              | 3/7/25, 5:17 PM                                     |                                                        | WATER WALL TUBE LEAKAGE                 |
| GANDHI NAGAR TPS | 5        |              | 1/28/26, 2:00 PM                                    |                                                        | RESERVE SHUT DOWN / STANDBY UNIT        |
| UTRAN CCPP       | 5        |              | 5/19/25, 8:00 AM                                    |                                                        | MISC. SHORT DURATION PLANNED MAINTENACE |
| UTRAN CCPP       | 5        | 240.00       | 5/17/25, 10:43 PM                                   |                                                        | RESERVE SHUT DOWN / STANDBY UNIT        |
| UTRAN CCPP       | 6        |              | 5/17/25, 10:40 PM                                   |                                                        | RESERVE SHUT DOWN / STANDBY UNIT        |
| UTRAN CCPP       | 6        | 134.00       | 5/19/25, 8:00 AM                                    |                                                        | MISC. SHORT DURATION PLANNED MAINTENACE |
| HAZIRA CCPP EXT  | 1        | 351.00       | 6/15/25, 1:22 AM                                    |                                                        | RESERVE SHUT DOWN / STANDBY UNIT        |
| DHUVARAN CCPP    | 3        |              | 4/17/25, 11:59 PM                                   |                                                        | RESERVE SHUT DOWN / STANDBY UNIT        |
| DHUVARAN CCPP    | 3        |              | 4/17/25, 12:00 AM                                   |                                                        | RESERVE SHUT DOWN/ STANDBY.             |

| Station       | Unit No. | Capacity(MW) | Date& Time of Maintenance<br><br>DD/MM/YYYY HH24:MM | Expected/sync Date of Return<br><br>DD/MM/YYYY HH24:MM | Reasons/Present Status           |
|---------------|----------|--------------|-----------------------------------------------------|--------------------------------------------------------|----------------------------------|
| 1             | 2        | 3            | 4                                                   | 5                                                      | 6                                |
| DHUVARAN CCPP | 3        |              | 4/8/25, 12:00 AM                                    |                                                        | RESERVE SHUT DOWN / STANDBY UNIT |
| DHUVARAN CCPP | 3        |              | 4/3/25, 12:00 AM                                    |                                                        | RESERVE SHUT DOWN / STANDBY UNIT |
| DHUVARAN CCPP | 3        |              | 4/2/25, 12:00 AM                                    |                                                        | RESERVE SHUT DOWN / STANDBY UNIT |
| DHUVARAN CCPP | 3        |              | 4/4/25, 12:00 AM                                    |                                                        | RESERVE SHUT DOWN / STANDBY UNIT |
| DHUVARAN CCPP | 3        |              | 4/18/25, 11:59 PM                                   |                                                        | RESERVE SHUT DOWN/ STANDBY.      |
| DHUVARAN CCPP | 3        | 72.00        | 3/20/25, 3:06 PM                                    |                                                        | RESERVE SHUT DOWN / STANDBY UNIT |
| DHUVARAN CCPP | 3        |              | 4/18/25, 12:00 AM                                   |                                                        | RESERVE SHUT DOWN/ STANDBY.      |
| DHUVARAN CCPP | 3        |              | 4/1/25, 12:00 AM                                    |                                                        | RESERVE SHUT DOWN / STANDBY UNIT |
| DHUVARAN CCPP | 4        |              | 4/2/25, 12:00 AM                                    |                                                        | RESERVE SHUT DOWN / STANDBY UNIT |
| DHUVARAN CCPP | 4        |              | 4/18/25, 11:59 PM                                   |                                                        | RESERVE SHUT DOWN / STANDBY UNIT |
| DHUVARAN CCPP | 4        |              | 4/17/25, 11:59 PM                                   |                                                        | RESERVE SHUT DOWN / STANDBY UNIT |
| DHUVARAN CCPP | 4        |              | 4/4/25, 12:00 AM                                    |                                                        | RESERVE SHUT DOWN / STANDBY UNIT |
| DHUVARAN CCPP | 4        |              | 4/25/25, 7:26 PM                                    |                                                        | RESERVE SHUT DOWN / STANDBY UNIT |
| DHUVARAN CCPP | 4        |              | 3/20/25, 1:45 PM                                    |                                                        | RESERVE SHUT DOWN / STANDBY UNIT |
| DHUVARAN CCPP | 4        |              | 4/1/25, 12:00 AM                                    |                                                        | RESERVE SHUT DOWN / STANDBY UNIT |
| DHUVARAN CCPP | 4        |              | 2/28/25, 12:00 AM                                   |                                                        | RESERVE SHUT DOWN/ STANDBY.      |
| DHUVARAN CCPP | 4        |              | 4/3/25, 12:00 AM                                    |                                                        | RESERVE SHUT DOWN / STANDBY UNIT |
| DHUVARAN CCPP | 4        |              | 4/8/25, 12:00 AM                                    |                                                        | RESERVE SHUT DOWN / STANDBY UNIT |
| DHUVARAN CCPP | 4        | 40.00        | 8/26/25, 10:18 PM                                   |                                                        | RESERVE SHUT DOWN/ STANDBY.      |
| DHUVARAN CCPP | 5        |              | 4/4/25, 12:00 AM                                    |                                                        | RESERVE SHUT DOWN / STANDBY UNIT |
| DHUVARAN CCPP | 5        |              | 4/18/25, 11:00 AM                                   |                                                        | RESERVE SHUT DOWN / STANDBY UNIT |
| DHUVARAN CCPP | 5        |              | 4/1/25, 12:00 AM                                    |                                                        | RESERVE SHUT DOWN / STANDBY UNIT |
| DHUVARAN CCPP | 5        |              | 5/9/25, 12:00 AM                                    |                                                        | RESERVE SHUT DOWN / STANDBY UNIT |
| DHUVARAN CCPP | 5        |              | 8/12/25, 12:00 AM                                   |                                                        | RESERVE SHUT DOWN/ STANDBY.      |
| DHUVARAN CCPP | 5        |              | 4/17/25, 12:00 AM                                   |                                                        | RESERVE SHUT DOWN/ STANDBY.      |
| DHUVARAN CCPP | 5        |              | 4/17/25, 11:59 PM                                   |                                                        | RESERVE SHUT DOWN / STANDBY UNIT |
| DHUVARAN CCPP | 5        |              | 4/18/25, 12:00 AM                                   |                                                        | RESERVE SHUT DOWN / STANDBY UNIT |
| DHUVARAN CCPP | 5        |              | 3/20/25, 12:00 AM                                   |                                                        | RESERVE SHUT DOWN / STANDBY UNIT |
| DHUVARAN CCPP | 5        |              | 4/18/25, 11:59 PM                                   |                                                        | RESERVE SHUT DOWN / STANDBY UNIT |
| DHUVARAN CCPP | 5        | 376.10       | 4/8/25, 12:00 AM                                    |                                                        | RESERVE SHUT DOWN / STANDBY UNIT |
| DHUVARAN CCPP | 5        |              | 9/11/25, 7:20 PM                                    |                                                        | RESERVE SHUT DOWN                |

| Station          | Unit No. | Capacity(MW) | Date& Time of Maintenance<br><br>DD/MM/YYYY HH24:MM | Expected/sync Date of Return<br><br>DD/MM/YYYY HH24:MM | Reasons/Present Status                     |
|------------------|----------|--------------|-----------------------------------------------------|--------------------------------------------------------|--------------------------------------------|
| 1                | 2        | 3            | 4                                                   | 5                                                      | 6                                          |
| DHUVARAN CCPP    | 5        |              | 4/2/25, 12:00 AM                                    |                                                        | RESERVE SHUT DOWN / STANDBY UNIT           |
| DHUVARAN CCPP    | 5        |              | 4/3/25, 12:00 AM                                    |                                                        | RESERVE SHUT DOWN / STANDBY UNIT           |
| WANAKBORI TPS    | 1        | 210.00       | 1/1/26, 11:39 AM                                    |                                                        | RSD/LOW SCHEDULE                           |
| WANAKBORI TPS    | 2        | 210.00       | 1/2/26, 10:45 AM                                    |                                                        | RSD/LOW SCHEDULE                           |
| WANAKBORI TPS    | 3        |              | 1/28/26, 3:16 PM                                    |                                                        | RSD/LOW SCHEDULE                           |
| WANAKBORI TPS    | 3        | 210.00       | 5/29/25, 1:33 PM                                    |                                                        | TURBINE MISC. PROBLEM                      |
| WANAKBORI TPS    | 4        |              | 1/1/26, 10:44 AM                                    |                                                        | RSD/LOW SCHEDULE                           |
| WANAKBORI TPS    | 4        | 210.00       | 4/8/25, 10:33 PM                                    |                                                        | WATER WALL TUBE LEAKAGE                    |
| WANAKBORI TPS    | 5        |              | 1/2/26, 11:38 AM                                    |                                                        | RSD/LOW SCHEDULE                           |
| WANAKBORI TPS    | 5        | 210.00       | 5/25/25, 2:09 PM                                    |                                                        | TURBINE BEARING PROBLEM                    |
| WANAKBORI TPS    | 6        | 210.00       | 1/1/26, 6:47 PM                                     |                                                        | RSD/LOW SCHEDULE                           |
| WANAKBORI TPS    | 7        | 210.00       | 1/28/26, 12:01 PM                                   |                                                        | RSD/LOW SCHEDULE                           |
| SIKKA REP. TPS   | 3        | 250.00       | 12/29/25, 8:53 AM                                   |                                                        | RESERVE SHUT DOWN / STANDBY UNIT           |
| SIKKA REP. TPS   | 4        | 250.00       | 1/1/26, 5:39 AM                                     |                                                        | RESERVE SHUT DOWN / STANDBY UNIT           |
| KUTCH LIG. TPS   | 3        |              | 1/11/26, 11:32 AM                                   |                                                        | AIR PREHEATERS PROBLEM                     |
| KUTCH LIG. TPS   | 3        |              | 1/13/26, 6:00 PM                                    |                                                        | RSD/LOW SCHEDULE                           |
| KUTCH LIG. TPS   | 3        | 75.00        | 7/29/25, 10:06 AM                                   |                                                        | WATER WALL TUBE LEAKAGE                    |
| AKRIMOTA LIG TPS | 2        | 125.00       | 2/1/26, 9:15 AM                                     |                                                        | WATER WALL TUBE LEAKAGE                    |
| SUGEN CCPP       | 1        | 382.50       | 12/25/25, 12:00 AM                                  | 31-12-2025                                             | RSD/LOW SCHEDULE                           |
| SUGEN CCPP       | 2        | 382.50       | 7/27/25, 12:00 AM                                   |                                                        | RSD/LOW SCHEDULE                           |
| SURAT LIG. TPS   | 2        | 125.00       | 7/28/25, 4:27 AM                                    |                                                        | WATER WALL TUBE LEAKAGE                    |
| MUNDRA UMTTP     | 1        | 800.00       | 7/3/25, 11:54 AM                                    |                                                        | AIR PREHEATERS PROBLEM                     |
| MUNDRA UMTTP     | 2        | 800.00       | 7/2/25, 10:59 PM                                    |                                                        | F.D. FANS PROBLEM                          |
| MUNDRA UMTTP     | 3        | 800.00       | 7/2/25, 12:22 AM                                    |                                                        | TURBINE CONTROL VALVE PROBLEM              |
| MUNDRA UMTTP     | 4        | 800.00       | 7/1/25, 8:55 AM                                     |                                                        | COOLING WATER SYSTEM PROBLEM/PIPES REPLACE |
| MUNDRA UMTTP     | 5        | 800.00       | 7/2/25, 8:55 AM                                     |                                                        | TURBINE MISC. PROBLEMS                     |
| KAWAS CCPP       | 1        | 106.00       | 10/11/25, 7:20 PM                                   | 12-10-2025                                             | CONSERVATION OF MAIN FUEL/RSD              |
| KAWAS CCPP       | 2        | 106.00       | 9/21/25, 12:30 AM                                   | 21-09-2025                                             | CONSERVATION OF MAIN FUEL/RSD              |
| KAWAS CCPP       | 3        | 106.00       | 6/4/25, 11:35 PM                                    | 05-06-2025                                             | CONSERVATION OF MAIN FUEL/RSD              |
| KAWAS CCPP       | 3        |              | 8/25/25, 11:57 PM                                   | 27-08-2025                                             | CONSERVATION OF MAIN FUEL/RSD              |
| KAWAS CCPP       | 4        | 106.00       | 3/27/25, 11:00 PM                                   | 27-03-2025                                             | NO/REDUCED IRRIGATION DEMAND               |

| Station           | Unit No. | Capacity(MW) | Date& Time of Maintenance<br><br>DD/MM/YYYY HH24:MM | Expected/sync Date of Return<br><br>DD/MM/YYYY HH24:MM | Reasons/Present Status              |
|-------------------|----------|--------------|-----------------------------------------------------|--------------------------------------------------------|-------------------------------------|
| 1                 | 2        | 3            | 4                                                   | 5                                                      | 6                                   |
| KAWAS CCPP        | 4        |              | 9/23/25, 7:44 PM                                    | 24-09-2025                                             | CONSERVATION OF MAIN FUEL/RSD       |
| KAWAS CCPP        | 4        |              | 3/25/25, 5:42 PM                                    | 27-03-2025                                             | NO/REDUCED IRRIGATION DEMAND        |
| KAWAS CCPP        | 5        |              | 3/25/25, 12:00 PM                                   | 26-03-2025                                             | NO/REDUCED IRRIGATION DEMAND        |
| KAWAS CCPP        | 5        | 116.10       | 9/21/25, 12:32 AM                                   | 21-09-2025                                             | CONSERVATION OF MAIN FUEL/RSD       |
| KAWAS CCPP        | 5        |              | 3/23/25, 12:00 PM                                   | 24-03-2025                                             | NO/REDUCED IRRIGATION DEMAND        |
| KAWAS CCPP        | 5        |              | 3/24/25, 12:00 PM                                   | 25-03-2025                                             | NO/REDUCED IRRIGATION DEMAND        |
| KAWAS CCPP        | 5        |              | 3/7/25, 12:00 PM                                    | 12-03-2025                                             | NO/REDUCED IRRIGATION DEMAND        |
| KAWAS CCPP        | 5        |              | 3/12/25, 12:00 AM                                   | 13-03-2025                                             | NO/REDUCED IRRIGATION DEMAND        |
| KAWAS CCPP        | 5        |              | 3/22/25, 12:00 PM                                   | 23-03-2025                                             | NO/REDUCED IRRIGATION DEMAND        |
| KAWAS CCPP        | 5        |              | 3/21/25, 12:00 PM                                   | 22-03-2025                                             | NO/REDUCED IRRIGATION DEMAND        |
| KAWAS CCPP        | 5        |              | 3/17/25, 8:23 PM                                    | 21-03-2025                                             | NO/REDUCED IRRIGATION DEMAND        |
| KAWAS CCPP        | 5        |              | 3/2/25, 12:00 AM                                    | 03-03-2025                                             | NO/REDUCED IRRIGATION DEMAND        |
| KAWAS CCPP        | 5        |              | 2/26/25, 12:00 PM                                   | 28-02-2025                                             | GT/WHRB/ST PLANNED OVERHAUL         |
| KAWAS CCPP        | 5        |              | 3/13/25, 12:00 PM                                   | 14-03-2025                                             | NO/REDUCED IRRIGATION DEMAND        |
| KAWAS CCPP        | 6        |              | 7/25/25, 5:15 PM                                    | 07-08-2025                                             | CONSERVATION OF MAIN FUEL/RSD       |
| KAWAS CCPP        | 6        |              | 4/21/25, 11:12 PM                                   | 22-04-2025                                             | NO/REDUCED IRRIGATION DEMAND        |
| KAWAS CCPP        | 6        | 116.10       | 5/17/25, 7:37 PM                                    | 05-06-2025                                             | CONSERVATION OF MAIN FUEL/RSD       |
| GANDHAR CCPP      | 1        |              | 3/21/25, 8:23 PM                                    | 22-03-2025                                             | NO/REDUCED IRRIGATION DEMAND        |
| GANDHAR CCPP      | 1        | 144.30       | 8/26/25, 12:00 AM                                   | 26-08-2025                                             | CONSERVATION OF MAIN FUEL/RSD       |
| GANDHAR CCPP      | 1        |              | 3/22/25, 11:55 PM                                   | 22-03-2025                                             | NO/REDUCED IRRIGATION DEMAND        |
| GANDHAR CCPP      | 4        | 224.49       | 4/21/25, 7:40 PM                                    | 27-04-2025                                             | NO/REDUCED IRRIGATION DEMAND        |
| GANDHAR CCPP      | 4        |              | 9/13/25, 11:11 PM                                   | 14-09-2025                                             | CONSERVATION OF MAIN FUEL/RSD       |
| GANDHAR CCPP      | 4        |              | 4/27/25, 12:55 AM                                   | 30-05-2025                                             | NO/REDUCED IRRIGATION DEMAND        |
| KAKRAPARA         | 1        | 220.00       | 3/14/25, 6:39 AM                                    | 15-03-2025                                             | Turbine Misc                        |
| KAKRAPARA         | 1        |              | 3/13/25, 6:39 AM                                    | 14-03-2025                                             | Miscellaneous                       |
| SANJAY GANDHI TPS | 4        | 210.00       | 1/21/26, 12:00 AM                                   |                                                        | BOILER OVERHAUL/ ANNUAL MAINTENANCE |
| SEIONI TPP        | 1        | 600.00       | 5/6/25, 6:38 PM                                     |                                                        | ELECTRICAL MISCELLANEOUS PROBLEMS   |
| KORBA STPS        | 2        | 200.00       | 4/16/25, 12:00 AM                                   | 24-04-2025                                             | BOILER OVERHAUL/ ANNUAL MAINTENANCE |
| KORBA STPS        | 2        |              | 4/15/25, 11:59 PM                                   | 16-04-2025                                             | BOILER OVERHAUL/ ANNUAL MAINTENANCE |
| VINDHYACHAL STPS  | 13       | 500.00       | 1/15/26, 12:17 AM                                   |                                                        | BOILER OVERHAUL/ ANNUAL MAINTENANCE |
| GADARWARA TPP     | 2        | 800.00       | 4/10/25, 10:59 PM                                   | 11-04-2025                                             | GENERATOR INSPECTION/TESTING/MTCE   |



| Station                            | Unit No. | Capacity(MW) | Date& Time of Maintenance<br><br>DD/MM/YYYY HH24:MM | Expected/sync Date of Return<br><br>DD/MM/YYYY HH24:MM | Reasons/Present Status                       |
|------------------------------------|----------|--------------|-----------------------------------------------------|--------------------------------------------------------|----------------------------------------------|
| 1                                  | 2        | 3            | 4                                                   | 5                                                      | 6                                            |
| PATHADI TPP                        | 2        | 300.00       | 12/7/25, 3:30 AM                                    |                                                        | BOILER MISC. PROBLEM                         |
| RATIJA TPS                         | 1        |              | 5/9/25, 12:00 AM                                    |                                                        | BOILER AUX. MISC. PROMLEMS                   |
| RATIJA TPS                         | 1        | 50.00        | 5/10/25, 11:59 AM                                   | 12-05-2025                                             | BOILER MISC. PROBLEM                         |
| RATIJA TPS                         | 2        | 50.00        | 1/31/26, 9:45 PM                                    |                                                        | I.D. FANS PROBLEM                            |
| JSW Mahanadi Power Company Limited | 2        | 600.00       | 10/11/25, 9:00 PM                                   |                                                        | RESERVE SHUT DOWN / STANDBY UNIT             |
| MAUDA TPS                          | 3        | 660.00       | 1/21/26, 12:36 AM                                   | 22-01-2026                                             | OVERHAULING WORKS                            |
| SOLAPUR STPS                       | 2        | 660.00       | 6/22/25, 1:16 AM                                    |                                                        | CONSERVATION OF MAIN FUEL/RSD                |
| BHUSAWAL TPS                       | 3        | 210.00       | 10/1/25, 12:05 AM                                   |                                                        | RESERVE SHUT DOWN / STANDBY UNIT             |
| URAN CCPP                          | 5        |              | 5/2/25, 12:32 AM                                    |                                                        | BEARING                                      |
| URAN CCPP                          | 5        | 108.00       | 2/19/25, 7:29 AM                                    |                                                        | TURBINE VIBRATIONS HIGH                      |
| URAN CCPP                          | 6        | 108.00       | 4/13/25, 7:59 PM                                    |                                                        | TRANSMISSION CONSTRAINTS                     |
| URAN CCPP                          | 8        | 108.00       | 1/15/26, 12:00 AM                                   | 28-02-2026                                             | Fuel Shortage                                |
| WARDHA WARORA TPP                  | 4        | 135.00       | 1/20/26, 12:13 AM                                   |                                                        | TURBINE VIBRATIONS HIGH                      |
| RATNAGIRI CCPP                     | 4        | 213.00       | 12/26/25, 7:50 PM                                   |                                                        | GT- LOW SYSTEM DAMAND                        |
| RATNAGIRI CCPP                     | 5        | 213.00       | 12/26/25, 7:21 PM                                   |                                                        | GT- LOW SYSTEM DAMAND                        |
| RATNAGIRI CCPP                     | 6        | 237.54       | 12/26/25, 7:47 PM                                   |                                                        | GT- LOW SYSTEM DAMAND                        |
| RATNAGIRI CCPP                     | 7        | 213.00       | 12/26/25, 7:32 PM                                   |                                                        | GT- LOW SYSTEM DAMAND                        |
| RATNAGIRI CCPP                     | 8        | 213.00       | 12/26/25, 8:08 PM                                   |                                                        | GT- LOW SYSTEM DAMAND                        |
| RATNAGIRI CCPP                     | 9        | 237.54       | 12/26/25, 8:08 PM                                   |                                                        | GT- LOW SYSTEM DAMAND                        |
| BELA TPS                           | 1        | 270.00       | 1/30/26, 4:19 PM                                    | 28-02-2026                                             | GENERATOR PROTECTION RELAY OPERATION PROBLEM |
| KOTHAGUDEM TPS (NEW)               | 10       | 250.00       | 1/25/26, 6:30 AM                                    |                                                        | WATER WALL TUBE LEAKAGE                      |
| SINGARENI TPP                      | 1        | 600.00       | 5/24/25, 2:34 AM                                    | 24-05-2025                                             | WATER WALL TUBE LEAKAGE                      |
| RAYALASEEMA TPS                    | 1        | 210.00       | 1/31/26, 12:02 AM                                   |                                                        | RESERVE SHUT DOWN / STANDBY UNIT             |
| RAYALASEEMA TPS                    | 2        |              | 8/26/25, 1:12 PM                                    |                                                        | WATER WALL TUBE LEAKAGE                      |
| RAYALASEEMA TPS                    | 2        | 210.00       | 7/22/25, 7:05 PM                                    |                                                        | WATER WALL TUBE LEAKAGE                      |
| RAYALASEEMA TPS                    | 2        |              | 4/10/25, 8:21 PM                                    |                                                        | REHEATER TUBE LEAKAGE                        |
| RAYALASEEMA TPS                    | 3        | 210.00       | 8/31/25, 2:00 PM                                    |                                                        | ECONOMISER TUBE LEAKAGE                      |
| RAYALASEEMA TPS                    | 3        |              | 8/27/25, 2:57 PM                                    |                                                        | RESERVE SHUT DOWN / STANDBY UNIT             |
| RAYALASEEMA TPS                    | 4        |              | 8/12/25, 4:49 AM                                    |                                                        | ECONOMISER TUBE LEAKAGE                      |
| RAYALASEEMA TPS                    | 4        | 210.00       | 1/31/26, 12:46 PM                                   |                                                        | RESERVE SHUT DOWN / STANDBY UNIT             |
| RAYALASEEMA TPS                    | 5        |              | 10/1/25, 9:35 AM                                    |                                                        | TURBINE VIBRATIONS HIGH                      |



| Station              | Unit No. | Capacity(MW) | Date& Time of Maintenance<br><br>DD/MM/YYYY HH24:MM | Expected/sync Date of Return<br><br>DD/MM/YYYY HH24:MM | Reasons/Present Status                       |
|----------------------|----------|--------------|-----------------------------------------------------|--------------------------------------------------------|----------------------------------------------|
| 1                    | 2        | 3            | 4                                                   | 5                                                      | 6                                            |
| RAYALASEEMA TPS      | 5        | 210.00       | 1/13/26, 12:18 PM                                   |                                                        | AIR PREHEATERS PROBLEM                       |
| SIMHAPURI TPS        | 2        | 150.00       | 1/23/26, 9:42 PM                                    |                                                        | BOILER AUX. MISC. PROMLEMS                   |
| SIMHAPURI TPS        | 3        | 150.00       | 10/19/25, 12:06 AM                                  |                                                        | P.A. FANS PROBLEM                            |
| MEENAKSHI ENERGY LTD | 1        | 150.00       | 9/1/25, 3:01 PM                                     | 08-02-2026                                             | BOILER MISC. PROBLEM                         |
| MEENAKSHI ENERGY LTD | 2        | 150.00       | 7/7/25, 10:40 PM                                    |                                                        | GENERATOR PROTECTION RELAY OPERATION PROBLEM |
| VIZAG TPP            | 2        |              | 9/27/25, 11:31 PM                                   |                                                        | MISCELLANEOUS                                |
| VIZAG TPP            | 2        | 520.00       | 10/18/25, 2:31 AM                                   |                                                        | GEN.PROTECTION RELAY OPERATION               |
| RAMAGUNDEM STPS      | 3        | 200.00       | 7/3/25, 11:30 PM                                    | 07-07-2025                                             | GENERATOR MISCLLANEOUS MAINTENANCE           |
| RAMAGUNDEM STPS      | 6        |              | 10/10/25, 12:49 PM                                  |                                                        | ELECTRICAL MISCELLANEOUS PROBLEMS            |
| RAMAGUNDEM STPS      | 6        | 500.00       | 8/10/25, 10:15 AM                                   |                                                        | RESERVE SHUT DOWN / STANDBY UNIT             |
| YADADRI TPS          | 2        | 800.00       | 10/20/25, 9:05 PM                                   |                                                        | BREAKER/ISOLATOR PROBLEM                     |
| RAICHUR TPS          | 2        | 210.00       | 4/14/25, 12:26 PM                                   | 20-04-2025                                             | BOILER AUX. MISC. PROMLEMS                   |
| RAICHUR TPS          | 5        | 210.00       | 8/14/25, 9:34 PM                                    |                                                        | RESERVE SHUT DOWN/ STANDBY.                  |
| RAICHUR TPS          | 5        |              | 8/31/25, 9:12 AM                                    |                                                        | RESERVE SHUT DOWN / STANDBY UNIT             |
| RAICHUR TPS          | 7        | 210.00       | 7/27/25, 8:07 AM                                    |                                                        | RSD/LOW SCHEDULE                             |
| RAICHUR TPS          | 8        | 250.00       | 8/7/25, 8:45 AM                                     | 08-08-2025                                             | ECONOMISER TUBE LEAKAGE                      |
| KAIGA                | 1        | 220.00       | 3/31/25, 11:11 PM                                   |                                                        | MISCELLANEOUS PLANNED MAINTENANCE            |
| KUDGI STPP           | 2        | 800.00       | 5/31/25, 1:35 PM                                    |                                                        | RSD/LOW SCHEDULE                             |
| BELLARY TPS          | 1        | 500.00       | 5/24/25, 12:09 AM                                   | 06-06-2025                                             | RSD/LOW SCHEDULE                             |
| BELLARY TPS          | 3        |              | 5/26/25, 2:28 PM                                    |                                                        | WATER WALL TUBE LEAKAGE                      |
| BELLARY TPS          | 3        | 700.00       | 4/10/25, 4:08 AM                                    | 13-04-2025                                             | ECONOMISER TUBE LEAKAGE                      |
| YERMARUS TPP         | 2        | 800.00       | 11/26/25, 12:16 AM                                  |                                                        | SCHEDULED ANNUAL MAINTENANCE                 |
| TUTICORIN TPS        | 1        | 210.00       | 3/15/25, 9:50 PM                                    |                                                        | FIRE IN CABLE GALLERY.                       |
| TUTICORIN TPS        | 2        |              | 3/15/25, 10:01 PM                                   |                                                        | FIRE IN CABLE GALLERY                        |
| TUTICORIN TPS        | 2        | 210.00       | 3/15/25, 5:30 AM                                    |                                                        | RESERVE SHUT DOWN / STANDBY UNIT             |
| TUTICORIN TPS        | 2        |              | 3/5/25, 12:21 AM                                    |                                                        | REHEATER TUBE LEAKAGE                        |
| TUTICORIN TPS        | 2        |              | 3/14/25, 12:01 AM                                   | 15-03-2025                                             | BOILER AUX. MISC. PROMLEMS                   |
| TUTICORIN TPS        | 3        |              | 5/28/25, 8:47 AM                                    |                                                        | BOILER AUX. MISC. PROMLEMS                   |
| TUTICORIN TPS        | 3        |              | 11/2/25, 10:55 AM                                   | 03-11-2025                                             | TURBINE PIPES AND VALVES PROBLEM             |
| TUTICORIN TPS        | 3        | 210.00       | 5/20/25, 11:40 PM                                   |                                                        | BOILER AUX. MISC. PROMLEMS                   |
| TUTICORIN TPS        | 3        |              | 4/7/25, 12:02 AM                                    |                                                        | BOILER MISC. PROBLEM                         |

| Station        | Unit No. | Capacity(MW) | Date& Time of Maintenance<br><br>DD/MM/YYYY HH24:MM | Expected/sync Date of Return<br><br>DD/MM/YYYY HH24:MM | Reasons/Present Status                   |
|----------------|----------|--------------|-----------------------------------------------------|--------------------------------------------------------|------------------------------------------|
| 1              | 2        | 3            | 4                                                   | 5                                                      | 6                                        |
| TUTICORIN TPS  | 3        |              | 8/15/25, 11:29 AM                                   |                                                        | DRUM LEVEL HIGH/ low                     |
| TUTICORIN TPS  | 4        | 210.00       | 9/18/25, 7:16 PM                                    |                                                        | CONDENSER TUBE LEAKAGE/ CLEANING         |
| TUTICORIN TPS  | 4        |              | 7/15/25, 8:02 PM                                    |                                                        | CONDENSER LOW VACCUM                     |
| TUTICORIN TPS  | 4        |              | 10/31/25, 3:04 PM                                   |                                                        | BOILER AUX. MISC. PROMLEMS               |
| TUTICORIN TPS  | 4        |              | 4/9/25, 10:05 PM                                    |                                                        | CONDENSER LOW VACCUM                     |
| TUTICORIN TPS  | 5        | 210.00       | 9/14/25, 10:48 AM                                   |                                                        | CONDENSER TUBE LEAKAGE/ CLEANING         |
| VALUTHUR CCPP  | 2        | 34.00        | 1/22/26, 6:04 PM                                    |                                                        | STATION TRANSFORMER PROBLEM              |
| VALUTHUR CCPP  | 3        | 59.80        | 1/20/26, 7:25 PM                                    |                                                        | MISCELLANEOUS PLANNED MAINTENANCE        |
| VALUTHUR CCPP  | 4        | 32.40        | 1/20/26, 7:07 PM                                    |                                                        | MISCELLANEOUS PLANNED MAINTENANCE        |
| MUTHIARA TPP   | 1        | 600.00       | 10/10/25, 1:20 AM                                   |                                                        | MILLING SYSTEM /RC FEEDER PROBLEM        |
| NEYVELI TPS-II | 1        | 210.00       | 12/2/25, 7:59 AM                                    |                                                        | I.D. FANS PROBLEM                        |
| NEYVELI TPS-II | 2        | 210.00       | 8/18/25, 5:20 PM                                    |                                                        | MILLING SYSTEM /RC FEEDER PROBLEM        |
| NEYVELI TPS-II | 3        | 210.00       | 11/24/25, 9:20 AM                                   |                                                        | COAL FEEDING PROBLEM IN PLANT            |
| NEYVELI TPS-II | 4        | 210.00       | 11/15/25, 10:22 AM                                  |                                                        | WATER WALL TUBE LEAKAGE                  |
| NEYVELI TPS-II | 5        | 210.00       | 10/19/25, 11:38 AM                                  |                                                        | RESERVE SHUT DOWN / STANDBY UNIT         |
| NEYVELI TPS-II | 6        |              | 12/1/25, 3:30 PM                                    |                                                        | BOILER AUX. MISC. PROMLEMS               |
| NEYVELI TPS-II | 6        | 210.00       | 11/28/25, 11:58 PM                                  |                                                        | RESERVE SHUT DOWN / STANDBY UNIT         |
| NEYVELI TPS-II | 7        |              | 1/4/26, 12:00 AM                                    |                                                        | RESERVE SHUT DOWN / STANDBY UNIT         |
| NEYVELI TPS-II | 7        | 210.00       | 1/5/26, 12:00 AM                                    |                                                        | SCHEDULED ANNUAL MAINTENANCE             |
| KUDANKULAM     | 1        | 1,000.00     | 10/3/25, 12:30 AM                                   | 07-10-2025                                             | MISC. SHORT DURATION PLANNED MAINTENANCE |
| KUDANKULAM     | 1        |              | 8/3/25, 12:00 AM                                    | 30-09-2025                                             | ANNUAL MAINTENANCE                       |
| KUDANKULAM     | 1        |              | 8/1/25, 4:30 AM                                     |                                                        | RSD/LOW SCHEDULE                         |
| ITPCL TPP      | 2        | 600.00       | 5/24/25, 12:53 AM                                   |                                                        | RSD/LOW SCHEDULE                         |
| KARAIKAL CCPP  | 1        | 32.50        | 4/15/25, 11:57 PM                                   |                                                        | SCHEDULED ANNUAL MAINTENANCE             |
| BARH STPS      | 1        | 660.00       | 1/18/26, 12:26 PM                                   | 17-02-2026                                             | TURBINE VIBRATIONS HIGH                  |
| NABINAGAR TPP  | 1        | 250.00       | 12/4/25, 10:25 AM                                   |                                                        | STATOR/ STATOR EARTH FAULT               |
| NABINAGAR TPP  | 2        | 250.00       | 12/31/25, 1:30 AM                                   | 10-01-2026                                             | GENERATOR STATOR DAMAGED                 |
| MEJIA TPS      | 2        | 210.00       | 1/7/26, 8:28 PM                                     |                                                        | STATOR/ STATOR EARTH FAULT               |
| MEJIA TPS      | 6        | 250.00       | 1/16/26, 12:31 AM                                   |                                                        | CAPITAL MAINTENANCE                      |
| TALCHER STPS   | 5        | 500.00       | 3/9/25, 10:40 PM                                    | 09-03-2025                                             | WATER WALL TUBE LEAKAGE                  |
| TALCHER STPS   | 5        |              | 3/10/25, 12:00 AM                                   | 10-03-2025                                             | WATER WALL TUBE LEAKAGE                  |

| Station                         | Unit No. | Capacity(MW) | Date& Time of Maintenance<br><br>DD/MM/YYYY HH24:MM | Expected/sync Date of Return<br><br>DD/MM/YYYY HH24:MM | Reasons/Present Status              |
|---------------------------------|----------|--------------|-----------------------------------------------------|--------------------------------------------------------|-------------------------------------|
| 1                               | 2        | 3            | 4                                                   | 5                                                      | 6                                   |
| DARLIPALI STPS                  | 2        | 800.00       | 6/25/25, 5:53 PM                                    | 15-07-2025                                             | WATER WALL TUBE LEAKAGE             |
| SANTALDIH TPS                   | 5        | 250.00       | 1/12/26, 1:50 AM                                    |                                                        | BOILER OVERHAUL/ ANNUAL MAINTENANCE |
| SAGARDIGHI TPS                  | 4        | 500.00       | 1/30/26, 10:49 AM                                   |                                                        | REHEATER TUBE LEAKAGE               |
| FARAKKA STPS                    | 5        | 500.00       | 9/2/25, 2:43 AM                                     |                                                        | DRUM LEVEL HIGH/ low                |
| NAMRUP CCPP                     | 2        | 17.00        | 8/6/25, 9:14 AM                                     |                                                        | GENEATOR TRANSFORMER MISC.          |
| NAMRUP CCPP                     | 6        | 9.00         | 8/6/25, 9:10 AM                                     |                                                        | GT-MISCELLANEOUS PROBLEMS           |
| LAKWA GT                        | 6        | 20.00        | 6/1/25, 12:00 AM                                    | 02-06-2025                                             | GRID DISTURBENCE                    |
| LAKWA GT                        | 8        | 37.20        | 6/1/25, 12:00 AM                                    | 02-06-2025                                             | GRID DISTURBANCE                    |
| LAKWA REPLACEMENT POWER PROJECT | 3        | 9.96         | 10/14/25, 8:59 PM                                   |                                                        | GRID DISTURBENCE                    |
| KATHALGURI CCPP                 | 1        | 33.50        | 4/22/25, 12:00 AM                                   |                                                        | MISCELLANOUS                        |
| KATHALGURI CCPP                 | 2        |              | 7/16/25, 12:00 AM                                   |                                                        | LOW SYSTEM DEMAND                   |
| KATHALGURI CCPP                 | 2        | 33.50        | 7/16/25, 11:59 PM                                   |                                                        | LOW SYSTEM DEMAND                   |
| MONARCHAK CCPP                  | 2        | 35.60        | 7/18/25, 12:14 AM                                   |                                                        | ROTOR EARTH FAULT                   |
| Total                           |          | 48,109.90    |                                                     |                                                        |                                     |

Note: 1.Actual generation is gross generation from stations above 25 MW. It excludes generation from RES.  
2.Data published in this report is for operational purpose only and not for commercial purpose.  
3.Generation data/Outage data are compiled based on data submitted directly by the utilities."

Remarks:-

Report Version :-