

**CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION**

RECOMMISSIONNING OF THERMAL/NUCLEAR UNITS AS: 17-Feb-2026

Sub - Report 14

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance	Expected/sync Date of Return	Reasons/Present Status
			DD/MM/YYYY HH24:MM	DD/MM/YYYY HH24:MM	
1	2	3	4	5	6
PANIPAT TPS	7	250.0	2/17/26, 10:07 AM		FURNACE FIRE OUT /FLAME FAILURE
BARSINGSAR LIGNITE	1	125.0	2/8/26, 8:20 PM		BOILER AUX. MISC. PROMLEMS
SHREE CEMENT LTD TPS	3	19.0	2/17/26, 12:00 AM		RSD/LOW SCHEDULE
SHREE CEMENT LTD TPS	4	19.0	2/17/26, 12:00 AM		RSD/LOW SCHEDULE
SHREE CEMENT LTD TPS	5	6.0	2/17/26, 12:00 AM		RSD/LOW SCHEDULE
RIHAND STPS	5	500.0	1/18/26, 7:31 PM		OVERHAULING WORKS
GHATAMPUR TPP	1	660.0	2/17/26, 9:35 AM		P.A. FANS PROBLEM
SASAN UMTPP	1	660.0	2/16/26, 4:42 AM		ECONOMISER TUBE LEAKAGE
GANDHAR CCPP	3	144.3	2/17/26, 7:52 AM		CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	3		2/16/26, 7:49 AM		CONSERVATION OF MAIN FUEL/RSD
WARDHA WARORA TPP	1	135.0	2/16/26, 11:42 PM		TUBE LKG. AT LOW TEMP. SUPERHEATER ZONE
RAICHUR TPS	6	210.0	2/15/26, 6:53 AM		TUBE LKG. AT LOW TEMP. SUPERHEATER ZONE
NORTH CHENNAI TPS STAGE 1	1	210.0	2/15/26, 6:10 PM		ECONOMISER TUBE LEAKAGE
NORTH CHENNAI TPS STAGE 2	4	600.0	2/14/26, 6:55 AM		WATER WALL TUBE LEAKAGE
NEYVELI TPS-II	7	210.0	1/5/26, 12:00 AM		SCHEDULED ANNUAL MAINTENANCE
DAMODARAM SANJEEVAIAH TPS	3	800.0	2/15/26, 12:55 AM		WATER WALL TUBE LEAKAGE
SAGARDIGHI TPS	1	300.0	2/17/26, 12:45 AM		ELECTRICAL MISCELLANEOUS PROBLEMS
JSW Energy Utkal Limited	2	350.0	2/17/26, 10:59 AM		P.A. FANS PROBLEM
AGARTALA GT	2	21.0	2/17/26, 12:00 AM		MISCELLANEOUS PLANNED MAINTENANCE
MONARCHAK CCPP	1	65.4	2/17/26, 12:00 AM		MISCELLANEOUS PLANNED MAINTENANCE
MONARCHAK CCPP	2	35.6	2/17/26, 12:00 AM		MISCELLANEOUS PLANNED MAINTENANCE
LAKWA GT	6	20.0	2/17/26, 4:50 PM		GEN. TRANSFORMER TRIPPING/ DAMAGED
LAKWA REPLACEMENT POWER PROJECT	4	9.965	2/17/26, 12:00 AM		GRID DISTURBENCE
KATHALGURI CCPP	1	33.5	2/17/26, 12:00 AM		Low system demand/ costly fuel
KATHALGURI CCPP	7	30.0	2/17/26, 12:00 AM		MISC. SHORT DURATION MAINTENANCE WORKS

Total	5413.77			
--------------	---------	--	--	--

Note: 1. Actual generation is gross generation from stations above 25 MW. It excludes generation from RES.

2. Data published in this report is for operational purpose only and not for commercial purpose.

3. Generation data/Outage data are compiled based on data submitted directly by the utilities."

Remarks:-

Report Version :-