

**CENTRAL ELECTRICITY AUTHORITY  
G O & D WING  
OPERATION PERFORMANCE MONITORING DIVISION**

**THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 17-Feb-2026**

Sub - Report 15

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance	Expected/sync Date of Return	Reasons/Present Status
			DD/MM/YYYY HH24:MM	DD/MM/YYYY HH24:MM	
1	2	3	4	5	6
PANIPAT TPS	7	250.00	2/17/26, 10:07 AM	2026-02-17 12:07:23	FURNACE FIRE OUT /FLAME FAILURE
KOTA TPS	5	210.00	2/17/26, 9:00 PM		MAIN INLET VALVE
JALIPA KAPURDI TPP	4	135.00	2/17/26, 1:11 AM		BOILER MISC. PROBLEM
SHREE CEMENT LTD TPS	3	19.00	2/17/26, 12:00 AM	2026-02-17 17:34:00	RSD/LOW SCHEDULE
SHREE CEMENT LTD TPS	4	19.00	2/17/26, 12:00 AM	2026-02-17 17:30:00	RSD/LOW SCHEDULE
SHREE CEMENT LTD TPS	5	6.00	2/17/26, 12:00 AM	2026-02-17 17:37:00	RSD/LOW SCHEDULE
GHATAMPUR TPP	1	660.00	2/17/26, 9:35 AM	2026-02-17 12:03:00	P.A. FANS PROBLEM
KORBA STPS	7	500.00	2/17/26, 6:03 PM	2026-02-17	WATER WALL TUBE LEAKAGE
SUGEN CCPP	2	382.50	2/17/26, 12:00 AM	2026-02-20	RSD/LOW SCHEDULE
GANDHAR CCPP	3	144.30	2/17/26, 7:19 PM	2026-02-17	CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	3		2/17/26, 7:52 AM	2026-02-17 17:59:00	CONSERVATION OF MAIN FUEL/RSD
JSW RATNAGIRI TPP	1	300.00	2/17/26, 9:41 PM		TURBINE VIBRATIONS HIGH
BUTIBORI TPP	2	300.00	2/17/26, 12:02 AM		ELECTRICAL MISCELLANEOUS PROBLEMS
NORTH CHENNAI TPS STAGE 2	4	600.00	2/17/26, 5:53 PM		BOILER MISC. PROBLEM
SAGARDIGHI TPS	1	300.00	2/17/26, 12:45 AM	2026-02-17 03:52:01	ELECTRICAL MISCELLANEOUS PROBLEMS
SOUTHERN REPL. TPS	2	67.50	2/17/26, 10:26 AM	2026-02-18	ECONOMISER TUBE LEAKAGE
JSW Energy Utkal Limited	2	350.00	2/17/26, 10:59 AM	2026-02-17 20:33:00	P.A. FANS PROBLEM
AGARTALA GT	2	21.00	2/17/26, 12:00 AM	2026-02-17 23:59:59	MISCELLANEOUS PLANNED MAINTENANCE
MONARCHAK CCPP	1	65.40	2/17/26, 12:00 AM	2026-02-17 23:59:59	MISCELLANEOUS PLANNED MAINTENANCE
MONARCHAK CCPP	2	35.60	2/17/26, 12:00 AM	2026-02-17 23:59:59	MISCELLANEOUS PLANNED MAINTENANCE
LAKWA GT	6	20.00	2/17/26, 4:50 PM	2026-02-17 18:25:00	GEN. TRANSFORMER TRIPPING/ DAMAGED
LAKWA REPLACEMENT POWER PROJECT	3	9.96	2/17/26, 9:02 AM		GRID DISTURBENCE
LAKWA REPLACEMENT POWER PROJECT	4	9.96	2/17/26, 12:00 AM	2026-02-17 06:26:00	GRID DISTURBENCE
KATHALGURI CCPP	1	33.50	2/17/26, 12:00 AM	2026-02-17 23:59:59	Low system demand/ costly fuel
KATHALGURI CCPP	7	30.00	2/17/26, 12:00 AM	2026-02-17 23:59:59	MISC. SHORT DURATION MAINTENANCE WORKS

<b>Total</b>	4468.73			
--------------	---------	--	--	--

Note: 1. Actual generation is gross generation from stations above 25 MW. It excludes generation from RES.

2. Data published in this report is for operational purpose only and not for commercial purpose.

3. Generation data/Outage data are compiled based on data submitted directly by the utilities."

**Remarks:-**

**Report Version :-**