

**CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION**

THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 18-01-2020

Sub-Report - 15

Station	Unit No	Capacity (MW)	Date of Maintanance	Expected/Sync Date of return	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
INDIRA GANDHI STPP	1	500.00	18/01/2020 13:48		TURBINE VIBRATIONS HIGH
INDIRA GANDHI STPP	1		18/01/2020 16:32		TURBINE VIBRATIONS HIGH
UNCHAHAR TPS	6	500.00	18/01/2020 12:13		WATER WALL TUBE LEAKAGE
UTRAULA TPS	1	45.00	18/01/2020 12:00		RSD/LOW SCHEDULE
UTRAULA TPS	2	45.00	18/01/2020 12:00		RSD/LOW SCHEDULE
WANAKBORI TPS	5	210.00	18/01/2020 19:41		RESERVE SHUT DOWN / STANDBY UNIT
SATPURA TPS	8	210.00	18/01/2020 10:46		RSD/LOW SCHEDULE
CHANDRAPUR(MAHARASHTRA) STPS	3	210.00	18/01/2020 12:35		SWITCH YARD/TRIPPING OF TRANSMISSION LINES/BUS BAR PROBLEM
CHANDRAPUR(MAHARASHTRA) STPS	4	210.00	18/01/2020 12:35		SWITCH YARD/TRIPPING OF TRANSMISSION LINES/BUS BAR PROBLEM
CHANDRAPUR(MAHARASHTRA) STPS	5	500.00	18/01/2020 12:30		SWITCH YARD/TRIPPING OF TRANSMISSION LINES/BUS BAR PROBLEM
CHANDRAPUR(MAHARASHTRA) STPS	6	500.00	18/01/2020 12:37		SWITCH YARD/TRIPPING OF TRANSMISSION LINES/BUS BAR PROBLEM
NEYVELI TPS-II	6	210.00	18/01/2020 17:18	19/01/2020	DC SUPPLY PROBLEM
VALLUR TPP	3	500.00	18/01/2020 18:22		GT-MISCELLANEOUS PROBLEMS
KAMALANGA TPS	1	350.00	18/01/2020 22:35		ASH HANDLING SYSTEM PROBLEM
SAGARDIGHI TPS	4	500.00	18/01/2020 03:19		ELECTRICAL MISCELLANEOUS PROBLEMS
HALDIA TPP	1	300.00	18/01/2020 14:48		FURNACE FIRE OUT /FLAME FAILURE
KATHALGURI CCPP	6	33.50	18/01/2020 12:09		Fuel Shortage
KATHALGURI CCPP	9	30.00	18/01/2020 12:09		Fuel Shortage
LAKWA REPLACEMENT POWER PROJECT	2	9.96	18/01/2020 09:00	23/01/2020	MISCELLANEOUS PLANNED MAINTENANCE
Total		4863.47			