

**CENTRAL ELECTRICITY AUTHORITY  
G O & D WING  
OPERATION PERFORMANCE MONITORING DIVISION**

**RECOMMISSIONING OF THERMAL/NUCLEAR UNITS AS ON: 18-03-2020**

Sub-Report - 14

Station	Unit No	Capacity (MW)	Date of Maintanance	Sync Date	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
MAHATMA GANDHI TPS	2	660.00	09/03/2020 20:54	18/03/2020 02:23	RSD/LOW SCHEDULE
CHHABRA TPP	5	660.00	18/03/2020 13:40	18/03/2020 16:18	TURBINE OIL SYSTEM PROBLEM
SINGRAULI STPS	6	500.00	14/03/2020 22:18	18/03/2020 20:06	BOILER MISC. PROBLEM
KORBA-III	2	120.00	16/03/2020 17:45	18/03/2020 21:50	BOILER MISC. PROBLEM
CHAKABURA TPP	2	30.00	16/03/2020 23:59	18/03/2020 22:47	ECONOMISER TUBE LEAKAGE
GANDHI NAGAR TPS	4	210.00	05/03/2020 12:38	18/03/2020 04:27	RSD/LOW SCHEDULE
UKAI TPS	5	210.00	18/03/2020 10:18	18/03/2020 14:23	ELECTRICAL MISCELLANEOUS PROBLEMS
WANAKBORI TPS	5	210.00	13/03/2020 19:22	18/03/2020 04:24	RESERVE SHUT DOWN / STANDBY UNIT
HAZIRA CCPP EXT	1	351.00	18/03/2020 10:15	18/03/2020 15:14	GRID DISTURBANCE
MUNDRA TPS	5	660.00	09/03/2020 07:59	18/03/2020 04:55	AIR PREHEATERS PROBLEM
VINDHYACHAL STPS	11	500.00	14/03/2020 10:54	18/03/2020 04:22	MAIN STEAM LINE PROBLEM
SOLAPUR	2	660.00	09/10/2019 03:15	18/03/2020 20:10	RSD/LOW SCHEDULE
WARDHA WARORA TPP	3	135.00	22/02/2020 00:00	18/03/2020 09:19	ASH HANDLING SYSTEM PROBLEM
RAYALASEEMA TPS	6	600.00	07/03/2020 22:12	18/03/2020 22:02	RSD/LOW SCHEDULE
RAICHUR TPS	5	210.00	18/03/2020 14:48	18/03/2020 18:57	GEN. TRANSORMER PROTECTION RELAY OPERATION PROBLEM
NEYVELI NEW TPP	1	500.00	05/03/2020 22:04	18/03/2020 23:24	VARIOUS STEAM LEAKAGES
KOVIKALPAL CCPP	2	38.23	06/03/2020 13:00	18/03/2020 11:30	CONDENSER TUBE LEAKAGE/ CLEANING
RAMAGUNDEM STPS	1	200.00	17/03/2020 22:26	18/03/2020 01:17	ELECTRICAL MISCELLANEOUS PROBLEMS
SAGARDIGHI TPS	3	500.00	19/01/2020 23:59	18/03/2020 04:45	CAPITAL MAINTENANCE
Total		6,954.23			