

**CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION**

THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 18-03-2020

Sub-Report - 15

Station	Unit No	Capacity (MW)	Date of Maintanance	Expected/Sync Date of return	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
CHHABRA TPP	5	660.00	18/03/2020 13:40		TURBINE OIL SYSTEM PROBLEM
UKAI TPS	5	210.00	18/03/2020 10:18		ELECTRICAL MISCELLANEOUS PROBLEMS
WANAKBORI TPS	8	800.00	18/03/2020 15:54		RESERVE SHUT DOWN / STANDBY UNIT
HAZIRA CCPP EXT	1	351.00	18/03/2020 10:15	18/03/2020	GRID DISTURBANCE
RAICHUR TPS	5	210.00	18/03/2020 14:48		GEN. TRANSORMER PROTECTION RELAY OPERATION PROBLEM
TORANGALLU TPS(SBU-I)	1	130.00	18/03/2020 00:32		CONDENSER TUBE LEAKAGE/ CLEANING
NORTH CHENNAI TPS	4	600.00	18/03/2020 08:43		RSD/LOW SCHEDULE
KAMALANGA TPS	1	350.00	18/03/2020 11:21		COAL SHORTAGE
FARAKKA STPS	2	200.00	18/03/2020 22:54		WATER WALL TUBE LEAKAGE
SAGARDIGHI TPS	2	300.00	18/03/2020 12:20		ELECTRICAL MISCELLANEOUS PROBLEMS
LAKWA REPLACEMENT POWER PROJECT	3	9.96	18/03/2020 05:00		MINOR MAINTENANCE WORKS
Total		3820.97			