

**DAILY MAINTENANCE REPORT (THERMAL AND NUCLEAR UNITS) FOR 500 AND ABOVE 18-05-2026**

State/System	Power Station	Unit No.	Planned Maintenance (MW)	Forced Maintenance (Major) (MW)	Forced Maintenance (Minor) (MW)	Others Maintenance (MW)	Date & Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6	7	8	9	10
Punjab	TALWANDI SABO TPP	3	0.00	0.00	660.00	0.00	16/05/2026 22:00		ABNORMAL BOILER OPERATIONAL PARAMETER
Rajasthan	KALISINDH TPS	1	0.00	0.00	0.00	0.00	18/05/2026 22:49		TUBE LKG. AT LOW TEMP. SUPERHEATER ZONE
Uttar Pradesh	GHATAMPUR TPP	2	0.00	0.00	660.00	0.00	06/05/2026 22:26		I.D. FANS PROBLEM
Uttar Pradesh	ANPARA TPS	7	0.00	0.00	500.00	0.00	18/05/2026 10:30		ECONOMISER TUBE LEAKAGE
Uttar Pradesh	LALITPUR TPS	3	0.00	0.00	660.00	0.00	17/05/2026 02:46		BOILER MISC. PROBLEM
Chhatisgarh	KORBA STPS	5	500.00	0.00	0.00	0.00	15/05/2026 12:07		OVERHAULING WORKS
Chhatisgarh	JSW Mahanadi Power Company Limited	2	0.00	0.00	600.00	0.00	13/05/2026 16:16		FUEL OIL PROBLEM
Chhatisgarh	JSW Mahanadi Power Company Limited	3	0.00	0.00	600.00	0.00	13/05/2026 16:16		FUEL OIL PROBLEM
Chhatisgarh	JSW Mahanadi Power Company Limited	4	0.00	0.00	600.00	0.00	13/05/2026 16:16		FUEL OIL PROBLEM
Chhatisgarh	Vedanta Ltd Chhattisgarh TPP	1	0.00	600.00	0.00	0.00	14/04/2026 14:33		P.A. FANS PROBLEM
Madhya Pradesh	SHREE SINGAJI TPP	3	0.00	0.00	660.00	0.00	17/05/2026 05:15		AIR PREHEATERS PROBLEM
Andhra Pradesh	DAMODARAM SANJEEVAIAH TPS	3	0.00	0.00	800.00	0.00	17/05/2026 07:15	18/05/2026 19:10	WATER WALL TUBE LEAKAGE
Andhra Pradesh	VIZAG TPP	2	0.00	0.00	0.00	0.00	16/05/2026 14:50	18/05/2026 11:25	WATER WALL TUBE LEAKAGE
Karnataka	ADANI POWER LIMITED UDUPI TPP	2	0.00	0.00	600.00	0.00	06/05/2026 00:01		RESERVE SHUT DOWN / STANDBY UNIT
Tamil Nadu	NORTH CHENNAI TPS STAGE 2	5	0.00	600.00	0.00	0.00	16/04/2026 21:35		GENERATOR PROTECTION RELAY OPERATION PROBLEM
Tamil Nadu	NORTH CHENNAI TPS STAGE 3	6	0.00	0.00	0.00	0.00	18/05/2026 23:30		TRIPPING OF TRANSMISSION LINE
Tamil Nadu	ITPCL TPP	1	0.00	0.00	600.00	0.00	05/05/2026 22:27		AIR PREHEATERS PROBLEM
Telangana	YADADRI TPS	4	0.00	800.00	0.00	0.00	30/04/2026 16:48		ECONOMISER TUBE LEAKAGE

**DAILY MAINTENANCE REPORT (THERMAL AND NUCLEAR UNITS) FOR 500 AND ABOVE 18-05-2026**

State/System	Power Station	Unit No.	Planned Maintenance (MW)	Forced Maintenance (Major) (MW)	Forced Maintenance (Minor) (MW)	Others Maintenance (MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6	7	8	9	10
Bihar	BARH STPS	2	0.00	0.00	660.00	0.00	18/05/2026 17:14		AIR SUPPLY FAILURE
Jharkhand	NORTH KARANPURA TPP	2	0.00	0.00	660.00	0.00	18/05/2026 12:50		CONDENSATE PUMP problem
Odisha	TALCHER STPS	6	0.00	0.00	500.00	0.00	18/05/2026 15:23	18/05/2026 19:12	ELECTRICAL MISCELLANEOUS PROBLEMS
West Bengal	RAGHUNATHPUR TPP	2	0.00	600.00	0.00	0.00	14/04/2026 17:51		TURBINE VIBRATIONS HIGH
West Bengal	SAGARDIGHI TPS	4	0.00	0.00	500.00	0.00	11/05/2026 22:49		TURBINE MISC. PROBLEM
West Bengal	SAGARDIGHI TPS	5	0.00	0.00	0.00	0.00	16/05/2026 09:17	18/05/2026 05:09	AIR PREHEATERS PROBLEM
<b>Total</b>			<b>500.00</b>	<b>2,600.00</b>	<b>9,260.00</b>	<b>0.00</b>			

Note: 1.Actual generation is gross generation from stations above 25 MW. It excludes generation from RES.  
 2.Data published in this report is for operational purpose only and not for commercial purpose.  
 3.Generation data/Outage data are compiled based on data submitted directly by the utilities."

**Remarks:-**

**Report Version**

:-