

**CENTRAL ELECTRICITY AUTHORITY  
G O & D WING  
OPERATION PERFORMANCE MONITORING DIVISION**

**RECOMMISSIONING OF THERMAL/NUCLEAR UNITS AS: 18-May-2026**

Sub - Report 14

Station	Unit No.	Capacity(MW)	Date of Maintanance DD/MM/YYYY HH24:MM	Sync Date DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
SHREE CEMENT LTD TPS	3	19.0	5/18/26, 5:09 AM	5/18/26, 4:04 PM	RSD/LOW SCHEDULE
SHREE CEMENT LTD TPS	4	19.0	5/18/26, 5:09 AM	5/18/26, 3:55 PM	RSD/LOW SCHEDULE
SHREE CEMENT LTD TPS	5	6.0	5/18/26, 5:06 AM	5/18/26, 4:03 PM	RSD/LOW SCHEDULE
NIWARI TPP	2	45.0	5/7/26, 9:54 PM	5/18/26, 3:47 PM	WATER WALL TUBE LEAKAGE
UKAI TPS	5	210.0	5/17/26, 3:45 AM	5/18/26, 4:08 PM	RESERVE SHUT DOWN / STANDBY UNIT
WANAKBORI TPS	1	210.0	5/16/26, 12:30 AM	5/18/26, 2:13 PM	RSD/LOW SCHEDULE
WANAKBORI TPS	2	210.0	5/17/26, 4:44 AM	5/18/26, 3:02 PM	RESERVE SHUT DOWN / STANDBY UNIT
WANAKBORI TPS	5	210.0	5/17/26, 4:12 AM	5/18/26, 2:52 PM	RESERVE SHUT DOWN / STANDBY UNIT
RATNAGIRI CCPP	4	213.0	5/17/26, 11:25 AM	5/18/26, 1:25 PM	GT- LOW SYSTEM DAMAND
RATNAGIRI CCPP	5	213.0	5/17/26, 1:41 AM	5/18/26, 4:00 PM	GT- LOW SYSTEM DAMAND
RATNAGIRI CCPP	6	237.54	5/17/26, 11:17 AM	5/18/26, 3:39 PM	GT- LOW SYSTEM DAMAND
RATNAGIRI CCPP	7	213.0	5/17/26, 11:00 AM	5/18/26, 4:25 PM	GT- LOW SYSTEM DAMAND
RATNAGIRI CCPP	8	213.0	5/17/26, 1:13 AM	5/18/26, 1:45 PM	GT-MISCELLANEOUS PROBLEMS
RATNAGIRI CCPP	9	237.54	5/17/26, 10:57 AM	5/18/26, 3:47 PM	GT- LOW SYSTEM DAMAND
TUTICORIN TPS	3	210.0	5/17/26, 12:57 AM	5/18/26, 5:51 AM	TURBINE MISC.
NEYVELI TPS-II	5	210.0	5/18/26, 7:31 AM	5/18/26, 1:15 PM	FURNACE DRAFT ABNORMAL
Dr. N.TATA RAO TPS	5	210.0	5/15/26, 5:43 PM	5/18/26, 8:19 AM	WATER WALL TUBE LEAKAGE
DAMODARAM SANJEEVAIAH TPS	3	800.0	5/17/26, 7:15 AM	5/18/26, 7:10 PM	WATER WALL TUBE LEAKAGE
VIZAG TPP	2	520.0	5/16/26, 2:50 PM	5/18/26, 11:25 AM	WATER WALL TUBE LEAKAGE
MEJIA TPS	6	250.0	5/18/26, 8:54 AM	5/18/26, 4:28 PM	GENERATOR MISCLLANEOUS MAINTENANCE
SAGARDIGHI TPS	5	660.0	5/16/26, 9:17 AM	5/18/26, 5:09 AM	AIR PREHEATERS PROBLEM
TALCHER STPS	6	500.0	5/18/26, 3:23 PM	5/18/26, 7:12 PM	ELECTRICAL MISCELLANEOUS PROBLEMS
KAMALANGA TPS	1	350.0	5/16/26, 2:00 PM	5/18/26, 12:45 PM	TURBINE OIL SYSTEM PROBLEM
JSW Energy Utkal Limited	1	350.0	5/17/26, 2:58 PM	5/18/26, 3:42 PM	CONDENSER TUBE LEAKAGE/ CLEANING
AGARTALA GT	2	21.0	5/18/26, 12:00 AM	5/18/26, 11:59 PM	Fuel Shortage
LAKWA REPLACEMENT POWER PROJECT	5	9.965	5/18/26, 2:30 AM	5/18/26, 7:28 PM	GRID DISTURBENCE
KATHALGURI CCPP	5	33.5	5/18/26, 12:00 AM	5/18/26, 11:59 PM	Low system demand/ costly fuel

<b>Total</b>	6380.55			
--------------	---------	--	--	--

Note: 1.Actual generation is gross generation from stations above 25 MW. It excludes generation from RES.  
2.Data published in this report is for operational purpose only and not for commercial purpose.  
3.Generation data/Outage data are compiled based on data submitted directly by the utilities."

**Remarks:-**

**Report Version :-**